SAN FRANCISCO PUBLIC LIBRARY
3 1223 05346 1779

5/S

San Francisco Public Library

GOVERNMENT INFORMATION CENTER
SAN FRANCISCO PUBLIC LIBRARY

REFERENCE BOOK

Not to be taken from the Library

MAY - 8 2002



Digitized by the Internet Archive
in 2014

http://archive.org/details/reportsanfrancis1199sanf

SCA PROJECT NO. B2243 APRIL 1, 1999

Report:
San Francisco Unified School District
Lead in Drinking Water Survey

Volume II of IV

Appendix B
Lab Reports

DOCUMENTS DEPT.
JUL 23 2001
SAN FRANCISCO
PUBLIC LIBRARY

3 1223 05346 1779

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century Academy

Lab Proj. ID: 9708754

Sampled: 08/13/97
Received: 08/13/97
Analyzed: see below

Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708754-01 Sample Desc : LIQUID,1				
Lead	mg/L	08/18/97	0.0050	0.024
Lab No: 9708754-02 Sample Desc : LIQUID,2				
Lead	mg/L	08/18/97	0.0050	0.017
Lab No: 9708754-03 Sample Desc : LIQUID,3				
Lead	mg/L	08/18/97	0.0050	0.0075
Lab No: 9708754-04 Sample Desc : LIQUID,4				
Lead	mg/L	08/18/97	0.0050	0.011
Lab No: 9708754-05 Sample Desc : LIQUID,5				
Lead	mg/L	08/18/97	0.0050	0.015
Lab No: 9708754-06 Sample Desc : LIQUID,6				
Lead	mg/L	08/18/97	0.015	0.056
Lab No: 9708754-07 Sample Desc : LIQUID,7				
Lead	mg/L	08/18/97	0.0050	0.0078

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

5 47612 SFPL: ECONO JRS
50 SFPL 04/12/02 96

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD	Client Proj. ID: 21st Century Academy	Sampled: 08/13/97
1551 Newcomb Ave., Rm. 103		Received: 08/13/97
San Francisco, CA 94124	Lab Proj. ID: 9708754	Analyzed: see below
Attention: Bruce Giannini		Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708754-08 Sample Desc : LIQUID,8				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708754-09 Sample Desc : LIQUID,9				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.037**
Lab No: 9708754-10 Sample Desc : LIQUID,10				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.043**
Lab No: 9708754-11 Sample Desc : LIQUID,11				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708754-12 Sample Desc : LIQUID,12				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708754-13 Sample Desc : LIQUID,13				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.026**
Lab No: 9708754-14 Sample Desc : LIQUID,14				
Lead	mg/L	08/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century Academy

Lab Proj. ID: 9708754

Sampled: 08/13/97
Received: 08/13/97
Analyzed: see below

Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708754-15 Sample Desc : **LIQUID,15**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.022**
Lab No: 9708754-16 Sample Desc : **LIQUID,16**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.069**
Lab No: 9708754-17 Sample Desc : **LIQUID,17**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708754-18 Sample Desc : **LIQUID,18**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0084**
Lab No: 9708754-19 Sample Desc : **LIQUID,19**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.074**
Lab No: 9708754-20 Sample Desc : **LIQUID,20**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.010**
Lab No: 9708754-21 Sample Desc : **LIQUID,21 (Blank)**				
Lead	mg/L	08/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century Academy

Lab Proj. ID: 9708754

Sampled: 08/13/97
Received: 08/13/97
Analyzed: see below

Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708754-22 Sample Desc : LIQUID,8 (Dup)				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708754-23 Sample Desc : LIQUID,17 (Dup)				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708754-24 Sample Desc : LIQUID,19 (Dup)				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.074**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century

Lab Proj. ID: 9708F11

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below

Reported: 09/03/97

LABORATORY ANALYSIS

Analyte		Units	Date Analyzed	Detection Limit	Sample Results	
Lab No: 9708F11-01 Sample Desc : LIQUID,21st Century 2-1						
1A	Lead	mg/L	09/02/97	0.0050	0.023	R1 ✓
Lab No: 9708F11-02 Sample Desc : LIQUID,21st Century 2-2						
1B	Lead	mg/L	09/02/97	0.0050	0.0093	R1
Lab No: 9708F11-03 Sample Desc : LIQUID,21st Century 2-3						
2A	Lead	mg/L	09/02/97	0.0050	0.011	R1
Lab No: 9708F11-04 Sample Desc : LIQUID,21st Century 2-4						
2B	Lead	mg/L	09/02/97	0.0050	0.0095	R1
Lab No: 9708F11-05 Sample Desc : LIQUID,21st Century 2-5						
5A	Lead	mg/L	09/02/97	0.0050	0.0090	R1
Lab No: 9708F11-06 Sample Desc : LIQUID,21st Century 2-6						
5B	Lead	mg/L	09/02/97	0.0050	0.0061	R1
Lab No: 9708F11-07 Sample Desc : LIQUID,21st Century 2-7						
6A	Lead	mg/L	09/02/97	0.0050	0.055	R1 ✓✓

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century

Lab Proj. ID: 9708F11

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below

Reported: 09/03/97

LABORATORY ANALYSIS

Analyte		Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708F11-08 Sample Desc : LIQUID,21st Century 2-8					
6B	Lead	mg/L	09/02/97	0.0050	0.027
Lab No: 9708F11-09 Sample Desc : LIQUID,21st Century 2-9					
9A	Lead	mg/L	09/02/97	0.0050	N.D.
Lab No: 9708F11-10 Sample Desc : LIQUID,21st Century 2-9 Duplicate					
9A	Lead	mg/L	09/02/97	0.0050	N.D.
Lab No: 9708F11-11 Sample Desc : LIQUID,21st Century 2-10					
9B	Lead	mg/L	09/02/97	0.0050	0.0069
Lab No: 9708F11-12 Sample Desc : LIQUID,21st Century 2-11					
10A	Lead	mg/L	09/02/97	0.0050	0.064
Lab No: 9708F11-13 Sample Desc : LIQUID,21st Century 2-12					
10B	Lead	mg/L	09/02/97	0.0050	0.019
Lab No: 9708F11-14 Sample Desc : LIQUID,21st Century 2-13					
13A	Lead	mg/L	09/02/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century
Lab Proj. ID: 9708F11

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below
Reported: 09/03/97

LABORATORY ANALYSIS

Analyte		Units	Date Analyzed	Detection Limit	Sample Results	
Lab No: 9708F11-15 Sample Desc : LIQUID,21st Century 2-14						
13B	Lead	mg/L	09/02/97	0.0050	N.D.	R2
Lab No: 9708F11-16 Sample Desc : LIQUID,21st Century 2-15						
15A	Lead	mg/L	09/02/97	0.0050	0.015	R1
Lab No: 9708F11-17 Sample Desc : LIQUID,21st Century 2-16						
15B	Lead	mg/L	09/02/97	0.0050	0.011	R2
Lab No: 9708F11-18 Sample Desc : LIQUID,21st Century 2-17						
16A	Lead	mg/L	09/02/97	0.0050	0.025	R1
Lab No: 9708F11-19 Sample Desc : LIQUID,21st Century 2-18						
16B	Lead	mg/L	09/02/97	0.0050	0.019	R2
Lab No: 9708F11-20 Sample Desc : LIQUID,21st Century 2-19						
19A	Lead	mg/L	09/02/97	0.0050	0.013	R1
Lab No: 9708F11-21 Sample Desc : LIQUID,21st Century 2-19 Duplicat						
19A	Lead	mg/L	09/02/97	0.0050	0.012	D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century

Lab Proj. ID: 9708F11

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below

Reported: 09/03/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708F11-22 Sample Desc : LIQUID,21st Century 2-20				
19B Lead	mg/L	09/02/97	0.0050	0.0093
Lab No: 9708F11-23 Sample Desc : LIQUID,21st Century 2-21				
20 Lead	mg/L	09/02/97	0.0050	N.D.
Lab No: 9708F11-24 Sample Desc : LIQUID,21st Century 2-22				
Lead	mg/L	09/02/97	0.0050	N.D.
Lab No: 9708F11-25 Sample Desc : LIQUID,21st Century 2-22 Duplicat				
Lead	mg/L	09/02/97	0.0050	N.D.
Lab No: 9708F11-26 Sample Desc : LIQUID,Blank				
BL Lead	mg/L	09/02/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century Academy

Lab Proj. ID: 9709818

Sampled: 09/16/97
Received: 09/16/97
Analyzed: see below

Reported: 09/19/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709818-01 Sample Desc : **LIQUID,21st Century 3-1**				
Lead	mg/L	09/19/97	0.0050	n.d.
Lab No: 9709818-02 Sample Desc : **LIQUID,21st Century 3-2**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709818-03 Sample Desc : **LIQUID,21st Century 3-3**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709818-04 Sample Desc : **LIQUID,21st Century 3-4**				
Lead	**mg/L**	**09/19/97**	**0.0050**	**0.038**
Lab No: 9709818-05 Sample Desc : **LIQUID,21st Century 3-5**				
Lead	**mg/L**	**09/19/97**	**0.0050**	**0.022**
Lab No: 9709818-06 Sample Desc : **LIQUID,21st Century 3-6**				
Lead	**mg/L**	**09/19/97**	**0.0050**	**0.040**
Lab No: 9709818-07 Sample Desc : **LIQUID,21st Century 3-7**				
Lead	mg/L	09/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century Academy

Lab Proj. ID: 9709818

Sampled: 09/16/97
Received: 09/16/97
Analyzed: see below

Reported: 09/19/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709818-08 Sample Desc : LIQUID,21st Century 3-8				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709818-09 Sample Desc : LIQUID,21st Century 3-9				
Lead	mg/L	09/19/97	0.0050	0.057
Lab No: 9709818-10 Sample Desc : LIQUID,21st Century 3-10				
Lead	mg/L	09/19/97	0.0050	0.024
Lab No: 9709818-11 Sample Desc : LIQUID,21st Century 3-10 dup				
Lead	mg/L	09/19/97	0.0050	0.023

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century Academy

Lab Proj. ID: 9709818

Sampled:
Received: 09/16/97
Analyzed: see below

Reported: 09/19/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709818-12 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	09/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 21st Century Academy

Lab Proj. ID: 9710E45

Sampled: 10/23/97
Received: 10/24/97
Analyzed: see below

Reported: 10/30/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710E45-15 Sample Desc : **LIQUID,16-C**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.044**
Lab No: 9710E45-16 Sample Desc : **LIQUID,19-C**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.010**
Lab No: 9710E45-17 Sample Desc : **LIQUID,19-C Duplicate**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.010**
Lab No: 9710E45-18 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	10/29/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALAMO ES

Micro Log In **48023**
Total Samples 25
Date Sampled 8/27/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48023-01 SINK DRINKING FOUNTAIN ROOM 202 FIRST DRAW	2.8	1.0	
Client 2 Micro 48023-02 SINK DRINKING FOUNTAIN ROOM 204A FIRST DRAW	2.3	1.0	
Client 3 Micro 48023-03 SINK DRINKING FOUNTAIN ROOM 206 FIRST DRAW	2.5	1.0	
Client 4 Micro 48023-04 SINK DRINKING FOUNTAIN ROOM 212 FIRST DRAW	1.9	1.0	
Client 5 Micro 48023-05 SINK DRINKING FOUNTAIN ROOM 214 FIRST DRAW	1.5	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALAMO ES

Micro Log In **48023**
Total Samples **25**
Date Sampled **8/27/97**
Date Received **8/30/97**
Date Analyzed **8/30/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 48023-06 SINK DRINKING FOUNTAIN ROOM 216 FIRST DRAW	2.9	1.0	
Client 7 Micro 48023-07 SINK DRINKING FOUNTAIN ROOM 218 FIRST DRAW	3.4	1.0	
Client 8 Micro 48023-08 SINK DRINKING FOUNTAIN ROOM 217 FIRST DRAW	3.2	1.0	
Client 9 Micro 48023-09 SINK DRINKING FOUNTAIN ROOM 215 FIRST DRAW	3.1	1.0	
Client 10 Micro 48023-10 SINK DRINKING FOUNTAIN ROOM 213 FIRST DRAW	2.4	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALAMO ES

Micro Log In **48023**
Total Samples 25
Date Sampled 8/27/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 48023-11 SINK DRINKING FOUNTAIN ROOM 211 FIRST DRAW	1.9	1.0	
Client 12 Micro 48023-12 SINK DRINKING FOUNTAIN ROOM 207 FIRST DRAW	3.3	1.0	
Client 19 Micro 48023-13 SINK DRINKING FOUNTAIN ROOM 102 FIRST DRAW	2.6	1.0	
Client 20 Micro 48023-14 SINK DRINKING FOUNTAIN ROOM 106 FIRST DRAW	4.9	1.0	
Client 21 Micro 48023-15 SINK DRINKING FOUNTAIN OFFICE (WORK AREA) FIRST DRAW	2.5	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALAMO ES

Micro Log In **48023**
Total Samples 25
Date Sampled 8/27/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 22 Micro 48023-16 SINK DRINKING FOUNTAIN ROOM 110 FIRST DRAW	7.6	1.0	
Client 24 Micro 48023-17 SINK DRINKING FOUNTAIN ROOM 113A FIRST DRAW	7.7	1.0	
Client 26 Micro 48023-18 SINK DRINKING FOUNTAIN ROOM 111 FIRST DRAW	6.0	1.0	
Client 27 Micro 48023-19 SINK DRINKING FOUNTAIN ROOM 107 FIRST DRAW	3.5	1.0	
Client 28 Micro 48023-20 SINK DRINKING FOUNTAIN ROOM 103 LIBRARY FIRST DRAW	1.5	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALAMO ES

Micro Log In **48023**
Total Samples 25
Date Sampled 8/27/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 30 Micro 48023-21 DRINKING FOUNTAIN 1ST FLOOR HALL FIRST DRAW	34.0	1.0	
Client 31 Micro 48023-22 MULTIPLE DRINKING FOUNTAIN (3) PLAYGROUND SOUTH END (CENTER FIXTURE) FIRST DRAW	2.8	1.0	
Client 32 Micro 48023-23 MULTIPLE DRINKING FOUNTAIN (4) PLAYGROUND NORTH END (FIXTURE #2 FROM LEFT) FIRST DRAW	6.3	1.0	
Client 33 Micro 48023-24 SINK DRINKING FOUNTAIN ROOM 101D (EXT. STORAGE) FIRST DRAW	2.1	1.0	
Client 34 Micro 48023-25 FIELD BLANK	< 1.0	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALAMO ES

Micro Log In **48043**
Total Samples 5
Date Sampled 8/26/97
Date Received 9/4/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 14 Micro 48043-01 SINK FAUCET ROOM 205 FIRST DRAW	6.1	1.0	
Client 15 Micro 48043-02 SINK DRINKING FOUNTAIN ROOM 203A FIRST DRAW	1.6	1.0	
Client 16 Micro 48043-03 SINK DRINKING FOUNTAIN ROOM 201 FIRST DRAW	2.2	1.0	
Client 17 Micro 48043-04 SINK FAUCET SR-2; KITCHEN OFF AUDITORIUM FIRST DRAW	11.4	1.0	
Client 18 Micro 48043-05 DRINKING FOUNTAIN AUDITORIUM FIRST DRAW	2.4	1.0	

Technical Supervisor: F Ramezanzadeh 9/8/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
APTOS M.S.

Micro Log In **48826**
Total Samples 15
Date Sampled 9/20/97
Date Received 9/24/97
Date Analyzed 9/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48826-01 DRINKING FOUNTAIN 1ST DRAW C-91 INITIAL SCREENING	< 1.0	1.0	
Client 2 Micro 48826-02 DRINKING FOUNTAIN 1ST FLOOR C-90 (CENTER) INITIAL SCREENING	< 1.0	1.0	
Client 3 Micro 48826-03 DRINKING FOUNTAIN BASEMENT LEVEL C-90 INITIAL SCREENING	2.1	1.0	
Client 4 Micro 48826-04 DRINKING FOUNTAIN EXT. YARD 1ST FLOOR LEVEL (N) INITIAL SCREENING	< 1.0	1.0	
Client 5 Micro 48826-05 DRINKING FOUNTAIN 1ST FLOOR C-92 CORRIDOR INITIAL SCREENING	< 1.0	1.0	

Technical Supervisor: _____ 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
APTOS M.S.

Micro Log In **48826**
Total Samples 15
Date Sampled 9/20/97
Date Received 9/24/97
Date Analyzed 9/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 48826-06 DRINKING FOUNTAIN 239 BOY'S LOCKER ROOM (WEST) INITIAL SCREENING	< 1.0	1.0	
Client 7 Micro 48826-07 DRINKING FOUNTAIN 239 BOY'S LOCKER ROOM (EAST) INITIAL SCREENING	< 1.0	1.0	
Client 8 Micro 48826-08 DRINKING FOUNTAIN 2ND FLOOR CORRIDOR C-91 INITIAL SCREENING	< 1.0	1.0	
Client 9 Micro 48826-09 DRINKING FLOOR 2ND FLOOR CORRIDOR C-90 (N) INITIAL SCREENING	1.3	1.0	
Client 10 Micro 48826-10 DRINKING FOUNTAIN 2ND FLOOR CORRIDOR C-90 (SOUTH) INITIAL SCREENING	< 1.0	1.0	

Technical Supervisor: _____ 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
APTOS M.S.

Micro Log In **48826**
Total Samples 15
Date Sampled 9/20/97
Date Received 9/24/97
Date Analyzed 9/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 48826-11 DRINKING FOUNTAIN 2ND FLOOR C-95 INITIAL SCREENING	19.9	1.0	
Client 12 Micro 48826-12 DRINKING FOUNTAIN 3RD FLOOR C-91 INITIAL SCREENING	< 1.0	1.0	
Client 13 Micro 48826-13 DRINKING FOUNTAIN 3RD FLOOR C-90, NORTH INITIAL SCREENING	1.0	1.0	
Client 14 Micro 48826-14 DRINKING FOUNTAIN 3RD FLOOR C-90, SOUTH INITIAL SCREENING	< 1.0	1.0	
Client 15 Micro 48826-15 BLANK	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Alvarado

Lab Proj. ID: 9708C97

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708C97-01 Sample Desc : **LIQUID,Alvarado 1**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C97-02 Sample Desc : **LIQUID,Alvarado 1 Duplicate**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C97-03 Sample Desc : **LIQUID,Alvarado 2**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C97-04 Sample Desc : **LIQUID,Alvarado 3**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C97-05 Sample Desc : **LIQUID,Alvarado 4**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C97-06 Sample Desc : **LIQUID,Alvarado 5**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C97-07 Sample Desc : **LIQUID,Alvarado 6**				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: Alvarado

Lab Proj. ID: 9708C97

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708C97-08 Sample Desc : LIQUID,Alvarado 7				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C97-09 Sample Desc : LIQUID,Alvarado 8				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.044**

B

S

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Shella Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE CC

Micro Log In **47497**
Total Samples 5
Date Sampled 8/16/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 47497-01 DRINKING FOUNTAIN / FRONT CLASSROOM BY FRONT ENTRANCE DOOR FIRST DRAW	2.1	1.0	
Client # 2 Micro 47497-02 DRINKING FOUNTAIN / OUTSIDE SOUTH SIDE OF THE PATIO AREA FIRST DRAW	1.7	1.0	
Client # 3 Micro 47497-03 SINK FAUCET KITCHEN AREA SINK FIRST DRAW	1.2	1.0	
Client # 4 Micro 47497-04 SINK FAUCET CORRIDOR C-90 FIRST DRAW	21.3	1.0	
Client # 5 Micro 47497-05 BLANK	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Argonne E.S.

Lab Proj. ID: 9708A91

Sampled: 08/15/97
Received: 08/21/97
Analyzed: see below

Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708A91-01 Sample Desc : LIQUID,Argonne 1				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A91-02 Sample Desc : LIQUID,Argonne 1 duplicate				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A91-03 Sample Desc : LIQUID,Argonne 2				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A91-04 Sample Desc : LIQUID,Argonne 3				
Lead	**mg/L**	**08/22/97**	**0.0050**	**0.0065**
Lab No: 9708A91-05 Sample Desc : LIQUID,Argonne 4				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A91-06 Sample Desc : LIQUID,Argonne 5				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A91-07 Sample Desc : LIQUID,Argonne 6				
Lead	mg/L	08/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Argonne E.S.

Lab Proj. ID: 9708A91

Sampled: 08/15/97
Received: 08/21/97
Analyzed: see below

Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708A91-08 Sample Desc : LIQUID,Argonne 7				
Lead	mg/L	08/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Argonne ES

Lab Proj. ID: 9709987

Sampled: 09/17/97
Received: 09/17/97
Analyzed: see below

Reported: 09/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709987-01 Sample Desc : **LIQUID,1-1**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-02 Sample Desc : **LIQUID,1-2**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-03 Sample Desc : **LIQUID,1-3**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-04 Sample Desc : **LIQUID,1-4**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0052**
Lab No: 9709987-05 Sample Desc : **LIQUID,1-5**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-06 Sample Desc : **LIQUID,1-6**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-07 Sample Desc : **LIQUID,1-7**				
Lead	mg/L	09/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Argonne ES

Lab Proj. ID: 9709987

Sampled: 09/17/97
Received: 09/17/97
Analyzed: see below

Reported: 09/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709987-08 Sample Desc : LIQUID,1-8				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-09 Sample Desc : LIQUID,1-9				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0060**
Lab No: 9709987-10 Sample Desc : LIQUID,1-9 Duplicate				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0063**
Lab No: 9709987-11 Sample Desc : LIQUID,1-10				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-12 Sample Desc : LIQUID,1-11				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0057**
Lab No: 9709987-13 Sample Desc : LIQUID,1-12				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-14 Sample Desc : LIQUID,1-13				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.044**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: Argonne ES

Lab Proj. ID: 9709987

Sampled: 09/17/97
Received: 09/17/97
Analyzed: see below

Reported: 09/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709987-15 Sample Desc : **LIQUID,1-14**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.014**
Lab No: 9709987-16 Sample Desc : **LIQUID,1-15**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0054**
Lab No: 9709987-17 Sample Desc : **LIQUID,1-16**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0088**
Lab No: 9709987-18 Sample Desc : **LIQUID,1-17**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-19 Sample Desc : **LIQUID,1-18**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.010**
Lab No: 9709987-20 Sample Desc : **LIQUID,1-19**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0065**
Lab No: 9709987-21 Sample Desc : **LIQUID,1-19 Duplicate**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0070**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Argonne ES

Lab Proj. ID: 9709987

Sampled: 09/17/97
Received: 09/17/97
Analyzed: see below

Reported: 09/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709987-22 Sample Desc : LIQUID,1-20				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-23 Sample Desc : LIQUID,1-21				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-24 Sample Desc : LIQUID,1-22				
Lead	mg/L	09/22/97	0.0050	0.0057
Lab No: 9709987-25 Sample Desc : LIQUID,1-23				
Lead	mg/L	09/22/97	0.025	0.25
Lab No: 9709987-26 Sample Desc : LIQUID,1-24				
Lead	mg/L	09/22/97	0.0050	0.0080
Lab No: 9709987-27 Sample Desc : LIQUID,1-25				
Lead	mg/L	09/22/97	0.0050	0.0058
Lab No: 9709987-28 Sample Desc : LIQUID,1-26				
Lead	mg/L	09/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Argonne ES

Lab Proj. ID: 9709987

Sampled: 09/17/97
Received: 09/17/97
Analyzed: see below

Reported: 09/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709987-29 Sample Desc : LIQUID,1-27				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-30 Sample Desc : LIQUID,1-28				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0094**
Lab No: 9709987-31 Sample Desc : LIQUID,1-29				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0073**
Lab No: 9709987-32 Sample Desc : LIQUID,1-29 Duplicate				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0068**
Lab No: 9709987-33 Sample Desc : LIQUID,1-30				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-34 Sample Desc : LIQUID,1-31				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0055**
Lab No: 9709987-35 Sample Desc : LIQUID,1-32				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0075**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Argonne ES

Lab Proj. ID: 9709987

Sampled: 09/17/97
Received: 09/17/97
Analyzed: see below

Reported: 09/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709987-36 Sample Desc : **LIQUID,1-33**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-37 Sample Desc : **LIQUID,1-34**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-38 Sample Desc : **LIQUID,1-35**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-39 Sample Desc : **LIQUID,1-36**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709987-40 Sample Desc : **LIQUID,1-37**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.021**
Lab No: 9709987-41 Sample Desc : **LIQUID,1-37 Duplicate**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.021**
Lab No: 9709987-42 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	09/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE CC

Micro Log In 52537
Total Samples 9
Date Sampled 1/31/98
Date Received 2/2/98
Date Analyzed 2/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ARGONNE 13A Micro 52537-01 SINK FAUCET KIT - RESAMPLE	1.8	1.0	
Client ARGONNE 13B Micro 52537-02 SINK FAUCET KIT - RESAMPLE	1.4	1.0	
Client ARGONNE 13C Micro 52537-03 SINK FAUCET KIT - RESAMPLE	1.2	1.0	
Client ARGONNE 14A Micro 52537-04 SINK FAUCET KIT - RESAMPLE	1.8	1.0	
Client ARGONNE 14B Micro 52537-05 SINK FAUCET KIT - RESAMPLE	2.7	1.0	

Technical Supervisor: F. Ramezanzadeh 2/4/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE CC

Micro Log In 52537
Total Samples 9
Date Sampled 1/31/98
Date Received 2/2/98
Date Analyzed 2/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ARGONNE 14C Micro 52537-06 SINK FAUCET KIT - RESAMPLE	< 1.0	1.0	
Client ARGONNE 23A Micro 52537-07 SINK FAUCET KIT - 209	9.9	1.0	
Client ARGONNE 23B Micro 52537-08 SINK FAUCET KIT - 209	4.8	1.0	
Client ARGONNE 23C Micro 52537-09 SINK FAUCET KIT - 209	73.0	2.5	

Technical Supervisor: F. Ramezanzadeh 2/4/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE

Micro Log In 66564
Total Samples 36
Date Sampled 3/24/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ARGONNE 1A Micro 66564-01 1st draw, hallway (1st floor) drinking fountain	< 1	1	
Client ARGONNE 1B Micro 66564-02 2nd draw, hallway (1st floor) drinking fountain	1	1	
Client ARGONNE 2A Micro 66564-03 1ST DRAW, CAFETERIA SINK FAUCET	< 1	1	
Client ARAGONNE 2B Micro 66564-04 2ND DRAW, CAFETERIA SINK FAUCET	< 1	1	
Client ARGONNE 3A Micro 66564-05 1ST DRAW, HALLWAY (1ST FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: Hairfalleh for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported Analyst: HC

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE

Micro Log In 66564
Total Samples 36
Date Sampled 3/24/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ARGONNE 3B Micro 66564-06 2ND DRAW, HALLWAY (1ST FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 4A Micro 66564-07 1ST DRAW, HALLWAY (1ST FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 4B Micro 66564-08 2ND DRAW, HALLWAY (1ST FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 5A Micro 66564-09 1ST DRAW, HALLWAY (2ND FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 5B Micro 66564-10 2ND DRAW, HALLWAY (2ND FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported Analyst: HC

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE

Micro Log In 66564
Total Samples 36
Date Sampled 3/24/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ARGONNE 6A Micro 66564-11 1ST DRAW, HALLWAY (2ND FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 6B Micro 66564-12 2ND DRAW, HALLWAY (2ND FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 7A Micro 66564-13 1ST DRAW, HALLWAY (3RD FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 7B Micro 66564-14 2ND DRAW, HALLWAY (3RD FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 8A Micro 66564-15 1ST DRAW, HALLWAY (3RD FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported Analyst: HC

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE

Micro Log In 66564
Total Samples 36
Date Sampled 3/24/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: ARGONNE 8B Micro 66564-16 2ND DRAW, HALLWAY (3RD FLOOR) MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client: ARGONNE 9A Micro 66564-17 1ST DRAW, FACULTY LOUNGE SINK FAUCET	< 1	1	
Client: ARGONNE 9B Micro 66564-18 2ND DRAW, FACULTY LOUNGE SINK FAUCET	6	1	
Client: ARGONNE 10A Micro 66564-19 1ST DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client: ARGONNE 10B Micro 66564-20 2ND DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported Analyst: HC

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE

Micro Log In 66564
Total Samples 36
Date Sampled 3/24/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ARGONNE 11A Micro 66564-21 1ST DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 11B Micro 66564-22 2ND DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 12A Micro 66564-23 1ST DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 12B Micro 66564-24 2ND DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 13A Micro 66564-25 1ST DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported Analyst: HC

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE

Micro Log In 66564
Total Samples 36
Date Sampled 3/24/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: ARGONNE 13B Micro 66564-26 2ND DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client: ARGONNE 14A Micro 66564-27 1ST DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client: ARGONNE 14B Micro 66564-28 2ND DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client: ARGONNE 15A Micro 66564-29 1ST DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client: ARGONNE 15B Micro 66564-30 2ND DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: Hairfalee for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported Analyst: HC

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE

Micro Log In 66564
Total Samples 36
Date Sampled 3/24/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ARGONNE 16A Micro 66564-31 1ST DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 16B Micro 66564-32 2ND DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 17A Micro 66564-33 1ST DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE 17B Micro 66564-34 2ND DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client ARGONNE BL 1 Micro 66564-35 BLANK	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported Analyst: HC

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ARGONNE

Micro Log In 66564
Total Samples 36
Date Sampled 3/24/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: ARGONNE BL2 Micro 66564-36 BLANK	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported

Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BALBOA HS

Micro Log In **48578**
Total Samples 21
Date Sampled 9/17/97
Date Received 9/17/97
Date Analyzed 9/17/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **439-1** Micro 48578-01 **DRINKING FOUNTAIN** **BUNGALOW 21** **FIRST DRAW**	**20.3**	1.0	
Client **439-2** Micro 48578-02 **DRINKING FOUNTAIN** **GYM BLDG - 1ST FLOOR RM 704** **FIRST DRAW**	**1.7**	1.0	
Client **439-3** Micro 48578-03 **DRINKING FOUNTAIN** **GYM BLDG - 1ST FLOOR - RM 702** **FIRST DRAW**	**< 1.0**	1.0	
Client **439-4** Micro 48578-04 **DRINKING FOUNTAIN** **1ST FLOOR - C90B ACROSS FROM RM 108** **FIRST DRAW**	**1.6**	1.0	
Client **439-5** Micro 48578-05 **DRINKING FOUNTAIN** **1ST FLOOR - C90C ACROSS FROM RM 100** **FIRST DRAW**	**3.3**	1.0	

Technical Supervisor: _____ 9/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BALBOA HS

Micro Log In **48578**
Total Samples 21
Date Sampled 9/17/97
Date Received 9/17/97
Date Analyzed 9/17/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **439-6** Micro 48578-06 **DRINKING FOUNTAIN** **EXT. WALKWAY - C90 OUTSIDE T58A** **FIRST DRAW**	**1.7**	1.0	
Client **439-7** Micro 48578-07 **MULTI DRINKING FOUNTAIN** **EXT. WALKWAY - C90 OUTSIDE 154C** **FIRST DRAW**	**2.5**	1.0	
Client **439-8** Micro 48578-08 **MULTI DRINKING FOUNTAIN** **EXT. WALKWAY - C90 OUTSIDE 156** **FIRST DRAW**	**5.3**	1.0	
Client **439-9** Micro 48578-09 **DRINKING FOUNTAIN** **2ND FLOOR - C90A OUTSIDE RM 200** **FIRST DRAW**	**3.3**	1.0	
Client **439-10** Micro 48578-10 **DRINKING FOUNTAIN** **3RD FLOOR - C90A OUTSIDE RM 300** **FIRST DRAW**	**1.4**	1.0	

Technical Supervisor: _____ 9/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BALBOA HS

Micro Log In **48578**
Total Samples 21
Date Sampled 9/17/97
Date Received 9/17/97
Date Analyzed 9/17/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **439-11** Micro 48578-11 **DRINKING FOUNTAIN** **3RD FLOOR - C90 OUTSIDE RM 309** **FIRST DRAW**	**2.3**	1.0	
Client **439-12** Micro 48578-12 **DRINKING FOUNTAIN** **3RD FLOOR -C92 OUTSIDE RM 318** **FIRST DRAW**	**1.7**	1.0	
Client **439-13** Micro 48578-13 **DRINKING FOUNTAIN** **3RD LFOOR - C92 OUTSIDE RM 329** **FIRST DRAW**	**7.5**	1.0	
Client **439-14** Micro 48578-14 **DRINKING FOUNTAIN** **2ND FLOOR - C92 OUTSIDE RM 229** **FIRST DRAW**	**3.7**	1.0	
Client **439-15** Micro 48578-15 **DRINKING FOUNTAIN** **2ND FLOOR - C92 OUTSIDE RM 218** **FIRST DRAW**	**1.5**	1.0	

Technical Supervisor: 9/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BALBOA HS

Micro Log In **48578**
Total Samples 21
Date Sampled 9/17/97
Date Received 9/17/97
Date Analyzed 9/17/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **439-16** Micro 48578-16 **DRINKING FOUNTAIN** **1ST FLOOR - C91 OUTSIDE RM 116** **FIRST DRAW**	< 1.0	1.0	
Client **439-17** Micro 48578-17 **DRINKING FOUNTAIN** **1ST FLOOR - C92 OUTSIDE RM T62** **FIRST DRAW**	1.1	1.0	
Client **439-18** Micro 48578-18 **DRINKING FOUNTAIN** **BASEMENT FLOOR - C91 OUTSIDE RM 023** **FIRST DRAW**	11.0	1.0	
Client **439-19** Micro 48578-19 **DRINKING FOUNTAIN** **BASEMENT FLOOR - C91 OUTSIDE RM 022** **FIRST DRAW**	< 1.0	1.0	
Client **439-20** Micro 48578-20 **BLANK**	< 1.0	1.0	

Technical Supervisor: 9/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BALBOA HS

Micro Log In **48578**
Total Samples 21
Date Sampled 9/17/97
Date Received 9/17/97
Date Analyzed 9/17/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 439-21 Micro 48578-21 SINK FAUCET KITCHEN FAUCET 158D FIRST DRAW	1.4	1.0	

Technical Supervisor: 9/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BAY HS

Micro Log In **47941**
Total Samples **8**
Date Sampled **8/26/97**
Date Received **8/29/97**
Date Analyzed **9/2/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 47941-01 DRINKING FOUNTAIN RESTROOM AREA BY MAIN OFFICE INITIAL DRAW	1.2	1.0	
Client # 2 Micro 47941-02 DRINKING FOUNTAIN HOME STUDY OFFICE INITIAL DRAW	3.0	1.0	
Client # 3 Micro 47941-03 SINK FAUCET MAIN OFFICE SINK FAUCET INITIAL DRAW	1.9	1.0	
Client # 4 Micro 47941-04 DRINKING FOUNTAIN SPECIAL EDUCATION ROOM INITIAL DRAW	< 1.0	1.0	
Client # 5 Micro 47941-05 DRINKING FOUNTAIN RESTROOM BY SPECIAL ED. OFFICE INITIAL DRAW	5.2	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BAY HS

Micro Log In **47941**
Total Samples 8
Date Sampled 8/26/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 6 Micro 47941-06 DRINKING FOUNTAIN REGULAR EDUCATION OFFICE INITIAL DRAW	3.5	1.0	
Client # 7 Micro 47941-07 BLANK	< 1.0	1.0	
Client # 8 Micro 47941-08	1.8	1.0	

Technical Supervisor: 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRYANT ES

Micro Log In **47482**
Total Samples 21
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47482-01 SINK DRINKING FOUNTAIN RM 12 2ND FLOOR FIRST DRAW	8.1	1.0	
Client 2 Micro 47482-02 SINK DRINKING FOUNTAIN RM 11 FIRST DRAW	5.6	1.0	
Client 3 Micro 47482-03 SINK DRINKING FOUNTAIN RM 10 FIRST DRAW	< 1.0	1.0	
Client 4 Micro 47482-04 SINK DRINKING FOUNTAIN RM 9 FIRST DRAW	6.1	1.0	
Client 5 Micro 47482-05 SINK DRINKING FOUNTAIN RM 8 FIRST DRAW	5.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRYANT ES

Micro Log In 47482
Total Samples 21
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47482-06 SINK DRINKING FOUNTAIN RM 7 FIRST DRAW	4.8	1.0	
Client 7 Micro 47482-07 SINK DRINKING FOUNTAIN RM 6 FIRST DRAW	3.5	1.0	
Client 8 Micro 47482-08 DRINKING FOUNTAIN 2ND FLOOR CENTER / LIBRARY RESTRICTED SPACE / FILL 1" SHORT FIRST DRAW	2.8	1.0	
Client 9 Micro 47482-09 SINK DRINKING FOUNTAIN RM 5 FIRST DRAW	6.1	1.0	
Client 10 Micro 47482-10 SINK DRINKING FOUNTAIN RM 4 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRYANT ES

Micro Log In **47482**
Total Samples 21
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47482-11 SINK DRINKING FOUNTAIN RM 2 FIRST DRAW	8.0	1.0	
Client 12 Micro 47482-12 SINK DRINKING FOUNTAIN RM 3 FIRST DRAW	4.1	1.0	
Client 13 Micro 47482-13 SINK DRINKING FOUNTAIN RM 1 2ND FLOOR FIRST DRAW	2.8	1.0	
Client 14 Micro 47482-14 DRINKING FOUNTAIN MULTI-PURPOSE RM 1ST FLOOR FIRST DRAW	9.3	1.0	
Client 15 Micro 47482-15 SINK FAUCET FOOD SERVICE OFFMULTI-PURPOSE RM FIRST DRAW	< 1.0	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRYANT ES

Micro Log In **47482**
Total Samples 21
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 17 Micro 47482-16 DRINKING FOUNTAIN CHILD CARE FIRST DRAW	1.5	1.0	
Client 18 Micro 47482-17 SINK DRINKING FOUNTAIN GIRLS' RR NW 1ST FLOOR FIRST DRAW	< 1.0	1.0	
Client 19 Micro 47482-18 SINK DRINKING FOUNTAIN BOYS' RR NW 1ST FLOOR FIRST DRAW	< 1.0	1.0	
Client 20 Micro 47482-19 SINK FAUCET FACULTY LOUNGE FIRST DRAW	< 1.0	1.0	
Client 21 Micro 47482-20 SINK FAUCET NURSES' OFFICE TEAPOT NOTED FIRST DRAW	2.4	1.0	

Technical Supervisor: F. Ramezanzadeh 8/27/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRYANT ES

Micro Log In **47482**
Total Samples 21
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 22 Micro 47482-21 **FIELD BLANK**	< 1.0	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRYANT ES

Micro Log In **48022**
Total Samples 3
Date Sampled 8/23/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **23** Micro 48022-01 **SINK DRINKING FOUNTAIN KINDERGARTEN A FIRST DRAW**	**5.6**	1.0	
Client **24** Micro 48022-02 **SINK DRINKING FOUNTAIN KINDERGARTEN B FIRST DRAW**	**6.7**	1.0	
Client **25** Micro 48022-03 **DRINKING FOUNTAIN 1ST FLOOR - ENTRY HALL FIRST DRAW**	**7.8**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **47484**
Total Samples **24**
Date Sampled **8/17/97**
Date Received **8/18/97**
Date Analyzed **8/23/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47484-01 SINK FAUCET KITCHEN FIRST DRAW	21.5	1.0	
Client 2 Micro 47484-02 SINK FAUCET TEACHERS LOUNGE FIRST DRAW	44.4	1.0	
Client 3 Micro 47484-03 SINK DRINKING FOUNTAIN ROOM 3 - 1ST FLOOR FIRST DRAW	16.3	1.0	
Client 4 Micro 47484-04 SINK DRINKING FOUNTAIN ROOM 1 FIRST DRAW	35.6	1.0	
Client 5 Micro 47484-05 DRINKING FOUNTAIN HALL - 1ST FLOOR OUTSIDE ROOM 3 FIRST DRAW NOTE: DF FLOW RATE VERY LOW RESTRICTED SPACE - FILL 1/2 IN. LOW	28.4	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **47484**
Total Samples 24
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47484-06 SINK DRINKING FOUNTAIN ROOM 5 FIRST DRAW	16.5	1.0	
Client 7 Micro 47484-07 SINK DRINKING FOUNTAIN ROOM 4 FIRST DRAW	27.4	1.0	
Client 8 Micro 47484-08 SINK DRINKING FOUNTAIN NURSES' OFFICE NEXT TO ADMIN. FIRST DRAW	85.8	2.9	
Client 9 Micro 47484-09 DRINKING FOUNTAIN HALL 1ST FLOOR LOWER LEVEL OUTSIDE RESTROOMS FIRST DRAW	37.4	1.0	
Client 10 Micro 47484-10 SINK DRINKING FOUNTAIN ROOM 2 FIRST DRAW	40.8	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **47484**
Total Samples 24
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47484-11 SINK DRINKING FOUNTAIN 2ND FLOOR - ROOM 14 FIRST DRAW	75.9	2.9	
Client 12 Micro 47484-12 SINK DRINKING FOUNTAIN ROOM 16 FIRST DRAW	45.8	1.0	
Client 13 Micro 47484-13 SINK DRINKING FOUNTAIN ROOM 18 FIRST DRAW	35.0	1.0	
Client 14 Micro 47484-14 SINK DRINKING FOUNTAIN ROOM 20 FIRST DRAW	101	3.3	
Client 15 Micro 47484-15 DRINKING FOUNTAIN HALL 2ND FLOOR EAST END FIRST DRAW	42.4	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **47484**
Total Samples 24
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47484-16 SINK DRINKING FOUNTAIN ROOM 22 FIRST DRAW	21.9	1.0	
Client 17 Micro 47484-17 SINK DRINKING FOUNTAIN ROOM 21 FIRST DRAW	22.9	1.0	
Client 18 Micro 47484-18 SINK DRINKING FOUNTAIN ROOM 19 FIRST DRAW	62.6	2.5	
Client 19 Micro 47484-19 SINK DRINKING FOUNTAIN ROOM 15 FIRST DRAW	9.9	1.0	
Client 20 Micro 47484-20 SINK DRINKING FOUNTAIN ROOM 17 FIRST DRAW	15.1	1.0	

Technical Supervisor: 9/8/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **47484**
Total Samples 24
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 21 Micro 47484-21 SINK DRINKING FOUNTAIN ROOM 13 FIRST DRAW	71.5	2.5	
Client 22 Micro 47484-22 SINK DRINKING FOUNTAIN ROOM 11 FIRST DRAW	29.6	1.0	
Client 23 Micro 47484-23 SINK DRINKING FOUNTAIN ROOM 12 FIRST DRAW	14.1	1.0	
Client 24 Micro 47484-24 FIELD BLANK	<1.0	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **1A** Micro 49281-01 **SINK FAUCET KITCHEN**	**8.2**	1.0	
Client **1B** Micro 49281-02 **SINK FAUCET KITCHEN**	**4.3**	1.0	
Client **1C** Micro 49281-03 **SINK FAUCET KITCHEN FIRST DRAW**	**7.6**	1.0	
Client **2A** Micro 49281-04 **SINK FAUCET TEACHER'S LOUNGE**	**3.5**	1.0	
Client **2B** Micro 49281-05 **SINK FAUCET TEACHER'S LOUNGE**	**3.4**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **2C** Micro 49281-06 **SINK FAUCET TEACHER'S LOUNGE FIRST DRAW**	**13.8**	1.0	
Client **3A** Micro 49281-07 **SINK DRINKING FOUNTAIN ROOM 3**	**4.3**	1.0	
Client **3B** Micro 49281-08 **SINK DRINKING FOUNTAIN ROOM 3**	**2.8**	1.0	
Client **3C** Micro 49281-09 **SINK DRINKING FOUNTAIN ROOM 3 FIRST DRAW**	**6.9**	1.0	
Client **4A** Micro 49281-10 **SINK DRINKING FOUNTAIN ROOM 1**	**2.4**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **4B** Micro 49281-11 **SINK DRINKING FOUNTAIN ROOM 1**	**2.5**	1.0	
Client **4C** Micro 49281-12 **SINK DRINKING FOUNTAIN ROOM 1 FIRST DRAW**	**9.3**	1.0	
Client **6A** Micro 49281-13 **SINK DRINKING FOUNTAIN ROOM 5**	**12.6**	1.0	
Client **6B** Micro 49281-14 **SINK DRINKING FOUNTAIN ROOM 5**	**2.5**	1.0	
Client **6C** Micro 49281-15 **SINK DRINKING FOUNTAIN ROOM 5 FIRST DRAW**	**9.9**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 7A Micro 49281-16 SINK DRINKING FOUNTAIN ROOM 4	7.8	1.0	
Client 7B Micro 49281-17 SINK DRINKING FOUNTAIN ROOM 4	3.1	1.0	
Client 7C Micro 49281-18 SINK DRINKING FOUNTAIN ROOM 4 FIRST DRAW	9.8	1.0	
Client 8A Micro 49281-19 SINK DRINKING FOUNTAIN NURSE	9.9	1.0	
Client 8B Micro 49281-20 SINK DRINKING FOUNTAIN NURSE	10.5	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **8C** Micro 49281-21 **SINK DRINKING FOUNTAIN NURSE FIRST DRAW**	**18.2**	1.0	
Client **9A** Micro 49281-22 **DRINKING FOUNTAIN HALL 1ST WEST**	**17.8**	1.0	
Client **9B** Micro 49281-23 **DRINKING FOUNTAIN HALL 1ST WEST**	**3.7**	1.0	
Client **9C** Micro 49281-24 **DRINKING FOUNTAIN HALL 1ST WEST FIRST DRAW**	**12.5**	1.0	
Client **10A** Micro 49281-25 **SINK DRINKING FOUNTAIN ROOM 2**	**4.7**	1.0	

Technical Supervisor: F Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **10B** Micro 49281-26 SINK DRINKING FOUNTAIN ROOM 2	6.5	1.0	
Client **10C** Micro 49281-27 SINK DRINKING FOUNTAIN ROOM 2 FIRST DRAW	11.4	1.0	
Client **11A** Micro 49281-28 SINK DRINKING FOUNTAIN ROOM 14	1.7	1.0	
Client **11B** Micro 49281-29 SINK DRINKING FOUNTAIN ROOM 14	1.2	1.0	
Client **11C** Micro 49281-30 SINK DRINKING FOUNTAIN ROOM 14 FIRST DRAW	2.2	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **12A** Micro 49281-31 **SINK DRINKING FOUNTAIN ROOM 16**	**3.1**	1.0	
Client **12B** Micro 49281-32 **SINK DRINKING FOUNTAIN ROOM 16**	**2.7**	1.0	
Client **12C** Micro 49281-33 **SINK DRINKING FOUNTAIN ROOM 16 FIRST DRAW**	**12.1**	1.0	
Client **13A** Micro 49281-34 **SINK DRINKING FOUNTAIN ROOM 18**	**3.6**	1.0	
Client **13B** Micro 49281-35 **SINK DRINKING FOUNTAIN ROOM 18**	**2.8**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples **58**
Date Sampled **10/4/97**
Date Received **10/7/97**
Date Analyzed **10/7/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **13C** Micro 49281-36 SINK DRINKING FOUNTAIN ROOM 18 FIRST DRAW	**19.3**	1.0	
Client **14A** Micro 49281-37 SINK DRINKING FOUNTAIN ROOM 20	**7.6**	1.0	
Client **14B** Micro 49281-38 SINK DRINKING FOUNTAIN ROOM 20	**4.6**	1.0	
Client **14C** Micro 49281-39 SINK DRINKING FOUNTAIN ROOM 20 FIRST DRAW	**26.3**	1.0	
Client **15A** Micro 49281-40 DRINKING FOUNTAIN HALL 2ND EAST	**8.8**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **15B** Micro 49281-41 **DRINKING FOUNTAIN HALL 2ND EAST**	**4.1**	1.0	
Client **15C** Micro 49281-42 **DRINKING FOUNTAIN HALL 2ND EAST FIRST DRAW**	**10.9**	1.0	
Client **16A** Micro 49281-43 **SINK DRINKING FOUNTAIN ROOM 22**	**7.8**	1.0	
Client **16B** Micro 49281-44 **SINK DRINKING FOUNTAIN ROOM 22**	**4.3**	1.0	
Client **16C** Micro 49281-45 **SINK DRINKING FOUNTAIN ROOM 22 FIRST DRAW**	**11.1**	1.0	

Technical Supervisor: F Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **17A** Micro 49281-46 SINK DRINKING FOUNTAIN ROOM 21	**14.6**	1.0	
Client **17B** Micro 49281-47 SINK DRINKING FOUNTAIN ROOM 21	**4.2**	1.0	
Client **17C** Micro 49281-48 SINK DRINKING FOUNTAIN ROOM 21 FIRST DRAW	**11.9**	1.0	
Client **18A** Micro 49281-49 SINK DRINKING FOUNTAIN ROOM 19	**6.2**	1.0	
Client **18B** Micro 49281-50 SINK DRINKING FOUNTAIN ROOM 19	**6.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **18C** Micro 49281-51 **SINK DRINKING FOUNTAIN ROOM 19 FIRST DRAW**	**25.5**	1.0	
Client **21A** Micro 49281-52 **SINK DRINKING FOUNTAIN ROOM 13**	**8.5**	1.0	
Client **21B** Micro 49281-53 **SINK DRINKING FOUNTAIN ROOM 13**	**5.0**	1.0	
Client **21C** Micro 49281-54 **SINK DRINKING FOUNTAIN ROOM 13 FIRST DRAW**	**21.7**	1.0	
Client **22A** Micro 49281-55 **SINK DRINKING FOUNTAIN ROOM 11**	**3.7**	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **49281**
Total Samples 58
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **22B** Micro 49281-56 **SINK DRINKING FOUNTAIN ROOM 11**	**3.4**	1.0	
Client **22C** Micro 49281-57 **SINK DRINKING FOUNTAIN ROOM 11 FIRST DRAW**	**7.6**	1.0	
Client **24A** Micro 49281-58 **FIELD BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR
Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BUENA VISTA ES

Micro Log In **51995**
Total Samples 3
Date Sampled 1/10/98
Date Received 1/12/98
Date Analyzed 1/13/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~A20~~ 20A Micro 51995-01 SINK DRINKING FAUCET ROOM 17	2.9	1.0	
Client ~~B20~~ 20B Micro 51995-02 SINK DRINKING FAUCET ROOM 17	2.3	1.0	
Client ~~C20~~ 20C Micro 51995-03 SINK DRINKING FAUCET ROOM 17	6.4	1.0	

Technical Supervisor: F. Ramezanzadeh 1/14/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LURTHER BURBANK MS

Micro Log In **50946**
Total Samples 11
Date Sampled 11/22/97
Date Received 11/25/97
Date Analyzed 11/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 50946-01 DRINKING FOUNTAIN SOUTH END OF 1ST FLOOR CORRIDOR C92 INITIAL	1.4	1.0	
Client 2 Micro 50946-02 DRINKING FOUNTAIN OUTSIDE OF T61 IN CORRIDOR 1ST FLOOR C90 INITIAL	1.9	1.0	
Client 3 Micro 50946-03 DRINKING FOUNTAIN OUTSIDE IF T63 IN CORRIDOR 2ND FLOOR C92 INITIAL	2.1	1.0	
Client 4 Micro 50946-04 DRINKING FOUNTAIN WEST END OF CAFETERIA INITIAL	3.3	1.0	
Client 5 Micro 50946-05 DRINKING FOUNTAIN EAST END OF CAFETERIA INITIAL	17.6	1.0	

Technical Supervisor: _____ 11/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LURTHER BURBANK MS

Micro Log In **50946**
Total Samples 11
Date Sampled 11/22/97
Date Received 11/25/97
Date Analyzed 11/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 50946-06 MULTIPLE DRINKING FOUNTAIN OUTSIDE IN YARD BY CAFERTERIA INITIAL	3.9	1.0	
Client 7 Micro 50946-07 MULTIPLE DRINKING FOUNTAIN OUTSIDE IN YARD BY GYMNASIUM 337 INITIAL	71.5	2.5	
Client 8 Micro 50946-08 DRINKING FOUNTAIN BOYS' LOCKER ROOM ROOM BY ROOM T66B INITIAL	1.5	1.0	
Client 9 Micro 50946-09 DRINKING FOUNTAIN 3RD FLOOR IN CORRIDOR C94 OUTSIDE OF ROOM 329 INITIAL	1.3	1.0	
Client 10 Micro 50946-10 DRINKING FOUNTAIN 3RD FLOOR IN CORRIDOR C94 OUTSIDE OF ROOM T58 INITIAL	3.5	1.0	

Technical Supervisor: F. Ramezanzadeh 11/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LURTHER BURBANK MS

Micro Log In **50946**
Total Samples **11**
Date Sampled **11/22/97**
Date Received **11/25/97**
Date Analyzed **11/25/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 50946-11 DRINKING FOUNTAIN 3RD FLOOR IN CORRIDOR C90 BY ROOM 311 INITIAL	31.4	1.0	

Technical Supervisor: F. Ramezanzadeh 11/26/97 Analyst: FR
Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BURBANK MS

Micro Log In 52534
Total Samples 6
Date Sampled 1/31/98
Date Received 2/2/98
Date Analyzed 2/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)		Comments
Client BURBANK 5A Micro 52534-01 DRINKING FOUNTAIN CAF RESAMPLE	9.9	1.0		
Client BURBANK 5B Micro 52534-02 DRINKING FOUNTAIN CAF RESAMPLE	3.1	1.0		
Client BURBANK 5C Micro 52534-03 DRINKING FOUNTAIN CAF RESAMPLE	2.7	1.0		
Client BURBANK 7A Micro 52534-04 MULTIPLE DRINKING FOUNTAIN YARD OUTSIDE GYM 39 RESAMPLE	< 1.0	1.0		
Client BURBANK 7B Micro 52534-05 MULTIPLE DRINKING FOUNTAIN RESAMPLE	< 1.0	1.0		

Technical Supervisor: 2/4/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BURBANK MS

Micro Log In **52534**
Total Samples 6
Date Sampled 1/31/98
Date Received 2/2/98
Date Analyzed 2/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: BURBANK 7C Micro 52534-06 MULTIPLE DRINKING FOUNTAIN RESAMPLE	1.1	1.0	

Technical Supervisor: F. Ramezanzadeh 2/4/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BURNETT CC

Micro Log In **48007**
Total Samples 10
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **910-7A** Micro 48807-01 SINK DRINKING FOUNTAIN ROOM 118 SINK DRINKING FOUNTAIN FIRST DRAW	**7.4**	1.0	
Client **910-7B** Micro 48807-02 SINK DRINKING FOUNTAIN ROOM 118 SINK DRINKING FOUNTAIN SECOND DRAW	**7.3**	1.0	
Client **910-7C** Micro 48807-03 SINK DRINKING FOUNTAIN ROOM 118 SINK DRINKING FOUNTAIN FIRST DRAW	**31.5**	1.0	
Client **910-1A** Micro 48807-04 SINK DRINKING FOUNTAIN ROOM 222 SINK DRINKING FOUNTAIN FIRST DRAW	**7.0**	1.0	
Client **910-1B** Micro 48807-05 SINK DRINKING FOUNTAIN ROOM 222 SINK DRINKING FOUNTAIN SECOND DRAW	**8.2**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BURNETT CC

Micro Log In **48007**
Total Samples 10
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **910-1C** Micro 48807-06 **SINK DRINKING FOUNTAIN ROOM 222 SINK DRINKING FOUNTAIN FIRST DRAW**	**19.6**	1.0	
Client **910-2A** Micro 48807-07 **SINK DRINKING FOUNTAIN ROOM 219 SINK DRINKING FOUNTAIN FIRST DRAW**	**3.4**	1.0	
Client **910-2B** Micro 48807-08 **SINK DRINKING FOUNTAIN ROOM 219 SINK DRINKING FOUNTAIN SECOND DRAW**	**2.6**	1.0	
Client **910-2C** Micro 48807-09 **SINK DRINKING FOUNTAIN ROOM 219 SINK DRINKING FOUNTAIN FIRST DRAW**	**7.5**	1.0	
Client **BLANK** Micro 48807-10 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 9/8/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

Burnett E.S/C6

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: Burnett, Site #910

Lab Proj. ID: 9708B57

Sampled: 08/17/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B57-01 Sample Desc : **LIQUID,910-1**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.055**
Lab No: 9708B57-02 Sample Desc : **LIQUID,910-1 Duplicate**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.057**
Lab No: 9708B57-03 Sample Desc : **LIQUID,910-2**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.015**
Lab No: 9708B57-04 Sample Desc : **LIQUID,910-2 Duplicate**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.015**
Lab No: 9708B57-05 Sample Desc : **LIQUID,910-3**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.0090**
Lab No: 9708B57-06 Sample Desc : **LIQUID,910-4**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.0073**
Lab No: 9708B57-07 Sample Desc : **LIQUID,910-5**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.012**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

Burnett E.S.

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: Burnett, Site #910
Lab Proj. ID: 9708B57

Sampled: 08/17/97
Received: 08/22/97
Analyzed: see below
Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B57-08 Sample Desc : LIQUID,910-6				
Lead	mg/L	08/25/97	0.0050	0.013
Lab No: 9708B57-09 Sample Desc : LIQUID,910-7				
Lead	mg/L	08/25/97	0.0050	0.033
Lab No: 9708B57-10 Sample Desc : LIQUID,910-8				
Lead	mg/L	08/25/97	0.0050	0.0054
Lab No: 9708B57-11 Sample Desc : LIQUID,910-9				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B57-12 Sample Desc : LIQUID,910-10				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B57-13 Sample Desc : LIQUID,910-11				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B57-14 Sample Desc : LIQUID,910-12				
Lead	mg/L	08/25/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

Burnett E.S.

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Burnett, Site #910
Lab Proj. ID: 9708B57

Sampled: 08/17/97
Received: 08/22/97
Analyzed: see below
Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B57-15 Sample Desc : LIQUID,910-13				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B57-16 Sample Desc : LIQUID,910-14				
Lead	mg/L	08/25/97	0.0050	0.022
Lab No: 9708B57-17 Sample Desc : LIQUID,910-15				
Lead	mg/L	08/25/97	0.0050	0.0080
Lab No: 9708B57-18 Sample Desc : LIQUID,910-16				
Lead	mg/L	08/25/97	0.0050	0.0070
Lab No: 9708B57-19 Sample Desc : LIQUID,910-17				
Lead	mg/L	08/25/97	0.0050	0.010
Lab No: 9708B57-20 Sample Desc : LIQUID,910-18				
Lead	mg/L	08/26/97	0.0050	N.D. B

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BURNETT CC

Micro Log In **52167**
Total Samples 9
Date Sampled 1/17/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BURNETT 14A** Micro 52167-01 DRINKING FOUNTAIN 1ST FLOOR HALL	5.1	1.0	
Client **BURNETT 14B** Micro 52167-02 DRINKING FOUNTAIN 1ST FLOOR HALL	4.4	1.0	
Client **BURNETT 14C** Micro 52167-03 DRINKING FOUNTAIN 1ST FLOOR HALL	12.0	1.0	
Client **BURNETT 5A** Micro 52167-04 DRINKING FOUNTAIN 119	11.8	1.0	
Client **BURNETT 5B** Micro 52167-05 DRINKING FOUNTAIN 119	10.5	1.0	

Technical Supervisor: F. Ramezanzadeh 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BURNETT CC

Micro Log In **52167**
Total Samples 9
Date Sampled 1/17/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BURNETT 5C** Micro 52167-06 **DRINKING FOUNTAIN 119**	**31.7**	1.0	
Client **BURNETT 6A** Micro 52167-07 **DRINKING FOUNTAIN 117**	**5.9**	1.0	
Client **BURNETT 6B** Micro 52167-08 **DRINKING FOUNTAIN 117**	**7.9**	1.0	
Client **BURNETT 6C** Micro 52167-09 **DRINKING FOUNTAIN 117**	**11.3**	1.0	

Technical Supervisor: F. Ramezanzadeh 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: F & S Burton

Lab Proj. ID: 9708B65

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results	
Lab No: 9708B65-01 Sample Desc : LIQUID,Burton 1					
Lead	mg/L	08/27/97	0.0050	N.D.	B
Lab No: 9708B65-02 Sample Desc : LIQUID,Burton 2					
Lead	mg/L	08/26/97	0.0050	ND	
Lab No: 9708B65-03 Sample Desc : LIQUID,Burton 2 Duplicate					
Lead	mg/L	08/26/97	0.0050	ND	D
Lab No: 9708B65-04 Sample Desc : LIQUID,Burton 3					
Lead	mg/L	08/26/97	0.0050	0.013	
Lab No: 9708B65-05 Sample Desc : LIQUID,Burton 3 Duplicate					
Lead	mg/L	08/26/97	0.0050	0.013	D
Lab No: 9708B65-06 Sample Desc : LIQUID,Burton 4					
Lead	mg/L	08/27/97	0.0050	0.0055	
Lab No: 9708B65-07 Sample Desc : LIQUID,Burton 4 Duplicate					
Lead	mg/L	08/27/97	0.0050	0.0051	D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: F & S Burton

Lab Proj. ID: 9708B65

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B65-08 Sample Desc : **LIQUID,Burton 6**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0077**
Lab No: 9708B65-09 Sample Desc : **LIQUID,Burton 7**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B65-10 Sample Desc : **LIQUID,Burton 8**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0056**
Lab No: 9708B65-11 Sample Desc : **LIQUID,Burton 11**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0079**
Lab No: 9708B65-12 Sample Desc : **LIQUID,Burton 13**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B65-13 Sample Desc : **LIQUID,Burton 14**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.011**
Lab No: 9708B65-14 Sample Desc : **LIQUID,Burton 15**				
Lead	mg/L	08/26/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: F & S Burton

Lab Proj. ID: 9708B65

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B65-15 Sample Desc : LIQUID,Burton 16				
Lead	mg/L	08/26/97	0.0050	0.011
Lab No: 9708B65-16 Sample Desc : LIQUID,Burton 17				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B65-17 Sample Desc : LIQUID,Burton 18				
Lead	mg/L	08/26/97	0.0050	0.0085
Lab No: 9708B65-18 Sample Desc : LIQUID,Burton 19				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B65-19 Sample Desc : LIQUID,Burton 20				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B65-20 Sample Desc : LIQUID,Burton 21				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B65-21 Sample Desc : LIQUID,Burton 22				
Lead	mg/L	08/26/97	0.0050	0.014

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: F & S Burton

Lab Proj. ID: 9708B65

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B65-22 Sample Desc : LIQUID,Burton 23				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B65-23 Sample Desc : LIQUID,Burton 24				
Lead	mg/L	08/26/97	0.0050	0.020
Lab No: 9708B65-24 Sample Desc : LIQUID,Burton 25				
Lead	mg/L	08/26/97	0.0050	0.013
Lab No: 9708B65-25 Sample Desc : LIQUID,Burton 26				
Lead	mg/L	08/26/97	0.0050	0.0063
Lab No: 9708B65-26 Sample Desc : LIQUID,Burton 27				
Lead	mg/L	08/26/97	0.0050	0.0050
Lab No: 9708B65-27 Sample Desc : LIQUID,Burton 28				
Lead	mg/L	08/26/97	0.0050	0.0076
Lab No: 9708B65-28 Sample Desc : LIQUID,Burton 29				
Lead	mg/L	08/27/97	0.0050	0.035

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
F & S BURTON HS

Micro Log In **48316**
Total Samples 3
Date Sampled 9/9/97
Date Received 9/9/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 30 Micro 48316-01 SINK FOUNTAIN SECOND FLOOR ROOM 238 (7) FIRST DRAW	1.6	1.0	
Client 31 Micro 48316-02 SINK FOUNTAIN SECOND FLOOR ROOM 238 (7) FIRST DRAW	2.5	1.0	
Client 32 Micro 48316-03 SINK FOUNTAIN SECOND FLOOR ROOM 238 (7) FIRST DRAW	2.7	1.0	

Technical Supervisor: _____ 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMOUNT ES

Micro Log In **47846**
Total Samples 45
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 35 Micro 47846-36 SINK DRINKING FOUNTAIN BLDG D NEAR ENTRANCE BELOW MID LEVEL "D"	<1.0	1.0	
Client 36 Micro 47846-37 SINK FAUCET TEACHERS' ROOM BELOW MID LEVEL "D"	2.4	1.0	
Client 37 Micro 47846-38 SINK FAUCET TEACHERS' RR BELOW MID LEVEL "D"	2.1	1.0	
Client 38 Micro 47846-39 SINK FAUCET BOYS' ROOM BELOW MID LEVEL "D"	1.7	1.0	
Client 39 Micro 47846-40 SINK FAUCET GIRLS' ROOM BELOW MID LEVEL "D"	<1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMOUNT ES

Micro Log In **47846**
Total Samples 45
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 30 Micro 47846-31 BLANK	<1.0	1.0	
Client 31 Micro 47846-32 SINK FAUCET BLDG C RIGHT RR RIGHT MID LEVEL	1.1	1.0	
Client 32 Micro 47846-33 SINK FAUCET BLDG. A FACULTY ROOM MID LEVEL	1.2	1.0	
Client 33 Micro 47846-34 SINK FAUCET BLDG D SINK NEAR STOVE BELOW MID LEVEL "D"	6.6	1.0	
Client 34 Micro 47846-35 SINK FAUCET BLDG D NEAR ENTRANCE BELOW MID LEVEL "D"	2.7	1.0	

Technical Supervisor: F Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMOUNT ES

Micro Log In **47846**
Total Samples 45
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 25 Micro 47846-26 SINK FAUCET BLDG C TEACHERS' COMPUTER ROOM MID LEVEL	6.1	1.0	
Client 26 Micro 47846-27 SINK FAUCET BLDG C TEACHERS' RR SINK MID LEVEL	2.1	1.0	
Client 27 Micro 47846-28 SINK FAUCET BLDG C LEFT RR LEFT MID LEVEL	4.0	1.0	
Client 28 Micro 47846-29 SINK FAUCET BLDG C LEFT RR RIGHT MID LEVEL	2.4	1.0	
Client 29 Micro 47846-30 SINK FAUCET BLDG C RIGHT RR LEFT MID LEVEL	4.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMOUNT ES

Micro Log In **47846**
Total Samples 45
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 20 Micro 47846-21 BLANK	<1.0	1.0	
Client 21 Micro 47846-22 SINK FAUCET OFFICE AREA SINK BLDG A	3.1	1.0	
Client 22 Micro 47846-23 SINK FAUCET BLDG C NEAR STOVE MID LEVEL	2.5	1.0	
Client 23 Micro 47846-24 SINK FAUCET BLDG C SINK NEAR ENTRY MID LEVEL	6.6	1.0	
Client 24 Micro 47846-25 SINK DRINKING FOUNTAIN BLDG C NEAR ENTRY MID LEVEL	<1.0	1.0	

Technical Supervisor: F Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMOUNT ES

Micro Log In **47846**
Total Samples 45
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 15 Micro 47846-16 SINK FAUCET BLDG D LEFT RR	23.0	1.0	
Client 16 Micro 47846-17 DRINKING FOUNTAIN BLDG C MID LEVEL LEFT DRINKING FOUNTAIN MID LEVEL	8.7	1.0	
Client 17 Micro 47846-18 DRINKING FOUNTAIN BLDG C MID LEVEL RIGHT DRINKING FOUNTAIN MID LEVEL	1.0	1.0	
Client 18 Micro 47846-19 DRINKING FOUNTAIN BLDG C LEFT DRINKING FOUNTAIN UPPER FLOOR LEVEL	1.8	1.0	
Client 19 Micro 47846-20 DRINKING FOUNTAIN BLDG C RIGHT DRINKING FOUNTAIN UPPER FLOOR LEVEL	1.6	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMOUNT ES

Micro Log In **47846**
Total Samples 45
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 11 Micro 47846-11 SINK DRINKING FOUNTAIN BLDG D NEAR ENTRANCE	2.4	1.0	
Client: 97-W00760-4 Micro 47846-12 SPIKED SAMPLE	21.0	1.0	
Client: 12 Micro 47846-13 DRINKING FOUNTAIN BLDG D OUTSIDE DRINKING FOUNTAIN LEFT	1.4	1.0	
Client: 13 Micro 47846-14 DRINKING FOUNTAIN BLDG D OUTSIDE DRINKING FOUNTAIN RIGHT	<1.0	1.0	
Client: 14 Micro 47846-15 SINK FAUCET BLDG D RIGHT RR LEFT SINK FAUCET DISCONNECTED	31.2	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMOUNT ES

Micro Log In 47846
Total Samples 45
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47846-06 SINK FAUCET BLDG C RR LEFT FAUCET UPPER LEVEL BLDG C	5.8	1.0	
Client 7 Micro 47846-07 SINK FAUCET BLDG C RR RIGHT FAUCET UPPER LEVEL BLDG C	4.8	1.0	
Client 8 Micro 47846-08 SINK FAUCET BLDG D NEXT TO STOVE	5.6	1.0	
Client 9 Micro 47846-09 SINK FAUCET BLDG D SINK NEAR ENTRY	3.5	1.0	
Client 10 Micro 47846-10 BLANK	<1.0	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMOUNT ES

Micro Log In **47846**
Total Samples 45
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47846-01 SINK FAUCET BLDG C NEXT TO STOVE UPPER LEVEL BLDG. C	1.6	1.0	
Client 2 Micro 47846-02 SINK FAUCET BLDG C SINK NEAR ENTRY UPPER LEVEL BLDG C	14.2	1.0	
Client 3 Micro 47846-03 SINK DRINKING FOUNTAIN BLDG C NEAR ENTRY UPPER LEVEL BLDG C	1.5	1.0	
Client 4 Micro 47846-04 SINK FAUCET RIGHT SIDE RR BLDG C UPPER LEVEL BLDG C	35.2	1.0	
Client 5 Micro 47846-05 SINK FAUCET LEFT SIDE RR BLDG C UPPER LEVEL BLDG C	116	4.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR
Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
EXCELSIOR CC #925

Micro Log In **47561**
Total Samples 15
Date Sampled 8/18/97
Date Received 8/20/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **11** Micro 47561-11 **DRINKING FOUNTAIN C90**	**3.7**	1.0	
Client **12** Micro 47561-12 **MULTIPLE DRINKING FOUNTAIN PLAY YARD**	**2.9**	1.0	
Client **13** Micro 47561-13 **WATER FAUCET T50**	**2.8**	1.0	
Client **14** Micro 47561-14 **WATER FAUCET T50**	**4.2**	1.0	
Client **97-W00752-2** Micro 47561-15 **BLANK**	**12.2**	1.0	

Technical Supervisor: F. Ramezanzadeh 8/27/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
EXCELSIOR CC #925

Micro Log In **47561**
Total Samples **15**
Date Sampled **8/18/97**
Date Received **8/20/97**
Date Analyzed **8/20/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **6** Micro 47561-06 **WATER FAUCET** **002**	**1.4**	1.0	
Client **7** Micro 47561-07 **WATER FAUCET** **T60**	**2.6**	1.0	
Client **8** Micro 47561-08 **SINK DRINKING FOUNTAIN** **004**	**< 1.0**	1.0	
Client **9** Micro 47561-09 **SINK DRINKING FOUNTAIN** **004**	**2.5**	1.0	
Client **10** Micro 47561-10 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 8/27/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
EXCELSIOR CC #925

Micro Log In **47561**
Total Samples 15
Date Sampled 8/18/97
Date Received 8/20/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47561-01 WATER FAUCET 001	1.6	1.0	
Client 2 Micro 47561-02 WATER FAUCET 001	1.1	1.0	
Client 3 Micro 47561-03 WATER FAUCET 001	1.4	1.0	
Client 4 Micro 47561-04 WATER FAUCET 002	2.3	1.0	
Client 5 Micro 47561-05 WATER FAUCET 002	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
EVERETT MS

Micro Log In **48519**
Total Samples **7**
Date Sampled **9/15/97**
Date Received **9/15/97**
Date Analyzed **9/16/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **529-6** Micro 48519-06 **SPIKE #97-W00771-5 SPIKED**	**11.3**	1.0	
Client **529-7** Micro 48519-07 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
EVERETT MS

Micro Log In **48519**
Total Samples 7
Date Sampled 9/15/97
Date Received 9/15/97
Date Analyzed 9/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **529-1** Micro 48519-01 **DRINKING FOUNTAIN** **DRINKINF FOUNTAIN IN CORRIDOR C95** **ADJACENT TO BATHROOM T52** **FIRST DRAW**	< **1.0**	1.0	
Client **529-2** Micro 48519-02 **DRINKING FOUNTAIN** **DRINKINF FOUNTAIN IN CORRIDOR C96** **ADJACENT TO BATHROOM T60** **FIRST DRAW**	**1.9**	1.0	
Client **529-3** Micro 48519-03 **DRINKING FOUNTAIN** **DRINKINF FOUNTAIN IN CORRIDOR C96** **ADJACENT TO BATHROOM T60** **FIRST DRAW**	**1.6**	1.0	
Client **529-4** Micro 48519-04 **DRINKING FOUNTAIN** **DRINKINF FOUNTAIN IN CORRIDOR** **ADJACENT TO BATHROOM 750** **FIRST DRAW**	< **1.0**	1.0	
Client **529-5** Micro 48519-05 **DRINKING FOUNTAIN** **DRINKINF FOUNTAIN IN CORRIDOR C93A** **NEAR LOCKER ROOM** **FIRST DRAW**	**1.7**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
EL DORADO ES

Micro Log In **52162**
Total Samples 4
Date Sampled 1/17/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **EL DORADO 9A** Micro 52162-01 **SINK DRINKING FOUNTAIN** 207	**1.2**	1.0	
Client **EL DORADO 9B** Micro 52162-02 **SINK DRINKING FOUNTAIN** 207	**1.3**	1.0	
Client **EL DORADO 9C** Micro 52162-03 **SINK DRINKING FOUNTAIN** 207	**2.4**	1.0	
Client **EL DORADO BLANK** Micro 52162-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorado ES

Lab Proj. ID: 9709819

Sampled:
Received: 09/16/97
Analyzed: see below

Reported: 09/19/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709819-11				
Sample Desc : LIQUID,Blank				
Lead	mg/L	09/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorado ES

Lab Proj. ID: 9709819

Sampled: 09/16/97
Received: 09/16/97
Analyzed: see below

Reported: 09/19/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709819-08 Sample Desc : LIQUID,El Dorado 3-8				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709819-09 Sample Desc : LIQUID,El Dorado 3-9				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709819-10 Sample Desc : LIQUID,El Dorado 3-9 Dup				
Lead	mg/L	09/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorado ES

Lab Proj. ID: 9709819

Sampled: 09/16/97
Received: 09/16/97
Analyzed: see below

Reported: 09/19/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709819-01 Sample Desc : LIQUID,El Dorado 3-1				
Lead	**mg/L**	**09/19/97**	**0.0050**	**0.017**
Lab No: 9709819-02 Sample Desc : LIQUID,El Dorado 3-2				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709819-03 Sample Desc : LIQUID,El Dorado 3-3				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709819-04 Sample Desc : LIQUID,El Dorado 3-4				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709819-05 Sample Desc : LIQUID,El Dorado 3-5				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709819-06 Sample Desc : LIQUID,El Dorado 3-6				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709819-07 Sample Desc : LIQUID,El Dorado 3-7				
Lead	mg/L	09/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorado ES
Lab Proj. ID: 9708F15

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below
Reported: 09/03/97

LABORATORY ANALYSIS

Analyte		Units	Date Analyzed	Detection Limit	Sample Results	
Lab No: 9708F15-15						
Sample Desc : LIQUID,El Dorado ES 2-14						
21B	Lead	mg/L	09/02/97	0.0050	N.D.	R2
Lab No: 9708F15-16						
Sample Desc : LIQUID,El Dorado ES 2-15						
23A	Lead	mg/L	09/02/97	0.0050	N.D.	R1
Lab No: 9708F15-17						
Sample Desc : LIQUID,El Dorado ES 2-16						
23B	Lead	mg/L	09/02/97	0.0050	N.D.	R2
Lab No: 9708F15-18						
Sample Desc : LIQUID,El Dorado ES 2-17						
22A	Lead	mg/L	09/02/97	0.0050	N.D.	R1
Lab No: 9708F15-19						
Sample Desc : LIQUID,El Dorado ES 2-18						
22B	Lead	mg/L	09/02/97	0.0050	N.D.	R2
Lab No: 9708F15-20						
Sample Desc : LIQUID,El Dorado ES 2-18 Duplicat						
22B	Lead	mg/L	09/02/97	0.0050	N.D.	D
Lab No: 9708F15-21						
Sample Desc : LIQUID,Blank						
B	Lead	mg/L	09/02/97	0.0050	N.D.	B

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorado ES

Lab Proj. ID: 9708F15

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below

Reported: 09/03/97

LABORATORY ANALYSIS

Analyte		Units	Date Analyzed	Detection Limit		Sample Results
Lab No: 9708F15-08 Sample Desc : LIQUID,El Dorado ES 2-8						
17B	Lead	mg/L	09/02/97	0.0050	R2	N.D.
Lab No: 9708F15-09 Sample Desc : LIQUID,El Dorado ES 2-9						R1
18A	Lead	mg/L	09/02/97	0.0050		N.D.
Lab No: 9708F15-10 Sample Desc : LIQUID,El Dorado ES 2-9 Duplicate						D
18A	Lead	mg/L	09/02/97	0.0050		N.D.
Lab No: 9708F15-11 Sample Desc : LIQUID,El Dorado ES 2-10						
18B	Lead	mg/L	09/02/97	0.0050	R2	N.D.
Lab No: 9708F15-12 Sample Desc : LIQUID,El Dorado ES 2-11						R1
20A	Lead	mg/L	09/02/97	0.0050		N.D.
Lab No: 9708F15-13 Sample Desc : LIQUID,El Dorado ES 2-12						
20B	Lead	mg/L	09/02/97	0.0050	R2	N.D.
Lab No: 9708F15-14 Sample Desc : LIQUID,El Dorado ES 2-13						R1
21A	Lead	mg/L	09/02/97	0.0050		N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorado ES

Lab Proj. ID: 9708F15

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below

Reported: 09/03/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit		Sample Results
Lab No: 9708F15-01 R1 Sample Desc : LIQUID,El Dorado ES 2-1					
1 A Lead	mg/L	09/02/97	0.0050		N.D.
Lab No: 9708F15-02 Sample Desc : LIQUID,El Dorado ES 2-2					
1 B Lead	mg/L	09/02/97	0.0050	R2	N.D.
Lab No: 9708F15-03 R1 Sample Desc : LIQUID,El Dorado ES 2-3					
11 A Lead	mg/L	09/02/97	0.0050		N.D.
Lab No: 9708F15-04 Sample Desc : LIQUID,El Dorado ES 2-4					
11 B Lead	mg/L	09/02/97	0.0050	R2	N.D.
Lab No: 9708F15-05 R1 Sample Desc : LIQUID,El Dorado ES 2-5					
16 A Lead	mg/L	09/02/97	0.0050		N.D.
Lab No: 9708F15-06 Sample Desc : LIQUID,El Dorado ES 2-6					
16 B Lead	mg/L	09/02/97	0.0050	R2	N.D.
Lab No: 9708F15-07 R1 Sample Desc : LIQUID,El Dorado ES 2-7					
17 A Lead	mg/L	09/02/97	0.0050		N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorada ES

Lab Proj. ID: 9708760

Sampled: 08/13/97
Received: 08/14/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results	
Lab No: 9708760-22 Sample Desc : LIQUID,22					
Lead	mg/L	08/21/97	0.0050	0.10	//
Lab No: 9708760-23 Sample Desc : LIQUID,23					
Lead	mg/L	08/21/97	0.0050	0.065	//
Lab No: 9708760-24 Sample Desc : LIQUID,24					
Lead	mg/L	08/21/97	0.0050	0.0097	S
Lab No: 9708760-25 Sample Desc : LIQUID,25 (Blank)					
Lead	mg/L	08/21/97	0.0050	N.D.	B
Lab No: 9708760-26 Sample Desc : LIQUID,9 (Dup)					
Lead	mg/L	08/21/97	0.0050	0.012	D
Lab No: 9708760-27 Sample Desc : LIQUID,16 (Dup)					
Lead	mg/L	08/21/97	0.0050	0.070	D
Lab No: 9708760-28 Sample Desc : LIQUID,24 (Dup)					
Lead	mg/L	08/21/97	0.0050	0.0098	S/D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorada ES

Lab Proj. ID: 9708760

Sampled: 08/13/97
Received: 08/14/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708760-15 Sample Desc : LIQUID,15				
Lead	mg/L	08/21/97	0.0050	0.0088
Lab No: 9708760-16 Sample Desc : LIQUID,16				
Lead	mg/L	08/21/97	0.0050	0.068
Lab No: 9708760-17 Sample Desc : LIQUID,17				
Lead	mg/L	08/21/97	0.0050	0.018
Lab No: 9708760-18 Sample Desc : LIQUID,18				
Lead	mg/L	08/21/97	0.0050	0.019
Lab No: 9708760-19 Sample Desc : LIQUID,19				
Lead	mg/L	08/21/97	0.0050	0.0072
Lab No: 9708760-20 Sample Desc : LIQUID,20				
Lead	mg/L	08/21/97	0.0050	0.040
Lab No: 9708760-21 Sample Desc : LIQUID,21				
Lead	mg/L	08/21/97	0.0050	0.018

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorada ES
Lab Proj. ID: 9708760

Sampled: 08/13/97
Received: 08/14/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708760-08 Sample Desc : LIQUID,8				
Lead	mg/L	08/21/97	0.0050	0.0087
Lab No: 9708760-09 Sample Desc : LIQUID,9				
Lead	mg/L	08/21/97	0.0050	0.012
Lab No: 9708760-10 Sample Desc : LIQUID,10				
Lead	mg/L	08/21/97	0.0050	0.0055
Lab No: 9708760-11 Sample Desc : LIQUID,11				
Lead	mg/L	08/21/97	0.0050	0.015
Lab No: 9708760-12 Sample Desc : LIQUID,12				
Lead	mg/L	08/21/97	0.0050	N.D.
Lab No: 9708760-13 Sample Desc : LIQUID,13				
Lead	mg/L	08/21/97	0.0050	0.0051
Lab No: 9708760-14 Sample Desc : LIQUID,14				
Lead	mg/L	08/21/97	0.0050	0.0092

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: El Dorada ES

Lab Proj. ID: 9708760

Sampled: 08/13/97
Received: 08/14/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708760-01 Sample Desc : LIQUID,1				
Lead	mg/L	08/21/97	0.0050	0.041
Lab No: 9708760-02 Sample Desc : LIQUID,2				
Lead	mg/L	08/21/97	0.0050	0.0014
Lab No: 9708760-03 Sample Desc : LIQUID,3				
Lead	mg/L	08/21/97	0.0050	N.D.
Lab No: 9708760-04 Sample Desc : LIQUID,4				
Lead	mg/L	08/21/97	0.0050	0.0061
Lab No: 9708760-05 Sample Desc : LIQUID,5				
Lead	mg/L	08/21/97	0.0050	0.0063
Lab No: 9708760-06 Sample Desc : LIQUID,6				
Lead	mg/L	08/21/97	0.0050	0.011
Lab No: 9708760-07 Sample Desc : LIQUID,7				
Lead	mg/L	08/21/97	0.0050	0.0076

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
EDISON ES

Micro Log In **49288**
Total Samples 7
Date Sampled 10/3/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **25C** Micro 49288-06 **SINK DRINKING FOUNTAIN CLASSROOM - 021 THIRD DRAW**	**1.5**	1.0	
Client **42B** Micro 49288-07 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
EDISON ES

Micro Log In **49288**
Total Samples 7
Date Sampled 10/3/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **3A** Micro 49288-01 **MULTIPLE DRINKING FOUNTAIN** **BASEMENT PATIO** **FIRST DRAW**	< 1.0	1.0	
Client **3B** Micro 49288-02 **MULTIPLE DRINKING FOUNTAIN** **BASEMENT PATIO** **SECOND DRAW**	1.3	1.0	
Client **3C** Micro 49288-03 **MULTIPLE DRINKING FOUNTAIN** **BASEMENT PATIO** **THIRD DRAW**	1.5	1.0	
Client **25A** Micro 49288-04 **SINK DRINKING FOUNTAIN** **CLASSROOM - 021** **FIRST DRAW**	< 1.0	1.0	
Client **25B** Micro 49288-05 **SINK DRINKING FOUNTAIN** **CLASSROOM - 021** **SECOND DRAW**	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Edison Elementary
Lab Proj. ID: 9708D36

Sampled: 08/20/97
Received: 08/25/97
Analyzed: see below
Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D36-29 Sample Desc : **LIQUID,Edison 39**				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.043**

S

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Edison Elementary

Lab Proj. ID: 9708D36

Sampled: 08/20/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D36-22 Sample Desc : LIQUID,Edison 33				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0068**
Lab No: 9708D36-23 Sample Desc : LIQUID,Edison 34				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-24 Sample Desc : LIQUID,Edison 35				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0056**
Lab No: 9708D36-25 Sample Desc : LIQUID,Edison 36				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-26 Sample Desc : LIQUID,Edison 37				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-27 Sample Desc : LIQUID,Edison 38				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-28 Sample Desc : LIQUID,Edison Blank				
Lead	mg/L	08/28/97	0.0050	N.D.

B

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Edison Elementary

Lab Proj. ID: 9708D36

Sampled: 08/20/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D36-15 Sample Desc : LIQUID,Edison 25				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.014**
Lab No: 9708D36-16 Sample Desc : LIQUID,Edison 26				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-17 Sample Desc : LIQUID,Edison 27				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0079**
Lab No: 9708D36-18 Sample Desc : LIQUID,Edison 28				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-19 Sample Desc : LIQUID,Edison 29				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-20 Sample Desc : LIQUID,Edison 31				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-21 Sample Desc : LIQUID,Edison 32				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Edison Elementary
Lab Proj. ID: 9708D36

Sampled: 08/20/97
Received: 08/25/97
Analyzed: see below
Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D36-08 Sample Desc : LIQUID,Edison 6				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-09 Sample Desc : LIQUID,Edison 7				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-10 Sample Desc : LIQUID,Edison 17				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-11 Sample Desc : LIQUID,Edison 19				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-12 Sample Desc : LIQUID,Edison 21				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-13 Sample Desc : LIQUID,Edison 23				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-14 Sample Desc : LIQUID,Edison 24				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0054**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Edison Elementary

Lab Proj. ID: 9708D36

Sampled: 08/20/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D36-01 Sample Desc : LIQUID,Edison 1				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-02 Sample Desc : LIQUID,Edison 1 Duplicate				
Lead	mg/L	08/28/97	0.0050	0.0056 D
Lab No: 9708D36-03 Sample Desc : LIQUID,Edison 3				
Lead	mg/L	08/28/97	0.0050	0.030 ✓
Lab No: 9708D36-04 Sample Desc : LIQUID,Edison 3 Duplicate				
Lead	mg/L	08/28/97	0.0050	0.029 D
Lab No: 9708D36-05 Sample Desc : LIQUID,Edison 4				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D36-06 Sample Desc : LIQUID,Edison 4 Duplicate				
Lead	mg/L	08/28/97	0.0050	N.D. D
Lab No: 9708D36-07 Sample Desc : LIQUID,Edison 5				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Drew ES

Lab Proj. ID: 9708757

Sampled: 05/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708757-26 Sample Desc : LIQUID,18 (Dup)				
Lead	mg/L	08/19/97	0.0050	0.0053 D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Drew ES

Lab Proj. ID: 9708757

Sampled: 08/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708757-22 Sample Desc : LIQUID,22 (Blank)				
Lead	mg/L	08/21/97	0.0050	N.D. B
Lab No: 9708757-23 Sample Desc : LIQUID,23				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.013**
Lab No: 9708757-24 Sample Desc : LIQUID,3 (Dup)				
Lead	mg/L	08/19/97	0.0050	N.D. D
Lab No: 9708757-25 Sample Desc : LIQUID,12 (Dup)				
Lead	mg/L	08/19/97	0.0050	N.D. D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Drew ES

Lab Proj. ID: 9708757

Sampled: 08/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708757-15 Sample Desc : LIQUID,15				
Lead	mg/L	08/20/97	0.0050	N.D.
Lab No: 9708757-16 Sample Desc : LIQUID,16				
Lead	mg/L	08/20/97	0.0050	0.0063
Lab No: 9708757-17 Sample Desc : LIQUID,17				
Lead	mg/L	08/20/97	0.0050	N.D.
Lab No: 9708757-18 Sample Desc : LIQUID,18				
Lead	mg/L	08/21/97	0.0050	0.0050
Lab No: 9708757-19 Sample Desc : LIQUID,19				
Lead	mg/L	08/19/97	0.0050	0.014
Lab No: 9708757-20 Sample Desc : LIQUID,20				
Lead	mg/L	08/19/97	0.0050	0.0060
Lab No: 9708757-21 Sample Desc : LIQUID,21				
Lead	mg/L	08/19/97	0.0050	0.0050 S

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Drew ES

Lab Proj. ID: 9708757

Sampled: 08/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708757-08 Sample Desc : LIQUID,8				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-09 Sample Desc : LIQUID,9				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-10 Sample Desc : LIQUID,10				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-11 Sample Desc : LIQUID,11				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-12 Sample Desc : LIQUID,12				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-13 Sample Desc : LIQUID,13				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.0065**
Lab No: 9708757-14 Sample Desc : LIQUID,14				
Lead	mg/L	08/20/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Drew ES

Lab Proj. ID: 9708757

Sampled: 08/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708757-01 Sample Desc : **LIQUID,1**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-02 Sample Desc : **LIQUID,2**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-03 Sample Desc : **LIQUID,3**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-04 Sample Desc : **LIQUID,4**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-05 Sample Desc : **LIQUID,5**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708757-06 Sample Desc : **LIQUID,6**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0091**
Lab No: 9708757-07 Sample Desc : **LIQUID,7**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0073**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DOWNTOWN HS

Micro Log In 51850
Total Samples 3
Date Sampled 1/6/98
Date Received 1/6/98
Date Analyzed 1/7/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6A Micro 51850-01 DRINKING FOUNTAIN CORRIDOR C90, 1ST FLOOR NEXT TO OFFICE RESAMPLE	12.3	1.0	
Client 6B Micro 51850-02 DRINKING FOUNTAIN CORRIDOR C90, 1ST FLOOR NEXT TO OFFICE RESAMPLE	7.7	1.0	
Client 6C Micro 51850-03 DRINKING FOUNTAIN CORRIDOR C90, 1ST FLOOR NEXT TO OFFICE RESAMPLE	16.9	1.0	

Technical Supervisor: F. Ramezanzadeh 1/7/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DOWNTOWN HS

Micro Log In **49320**
Total Samples 4
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 1A Micro 49320-01 DRINKING FOUNTAIN 1ST FLOOR C-90 FOLLOW-UP	15.3	1.0	
Client: 1B Micro 49320-02 DRINKING FOUNTAIN 1ST FLOOR C-90 FOLLOW-UP	4.6	1.0	
Client: 1C Micro 49320-03 DRINKING FOUNTAIN 1ST FLOOR C-90 FOLLOW-UP	12.0	1.0	
Client: 31 Micro 49320-04 BLANK	< 1.0	1.0	

Technical Supervisor: _____ 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DOWNTOWN HS

Micro Log In **48116**
Total Samples 8
Date Sampled 8/30/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 6 Micro 48116-06 **DRINKING FOUNTAIN CORRIDOR C90, 1ST FLOOR FIRST DRAW**	**26.8**	1.0	
Client # 7 Micro 48116-07 **DRINKING FOUNTAIN CORRIDOR C90, 2ND FLOOR FIRST DRAW**	**27.7**	1.0	
Client # 8 Micro 48116-08 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DOWNTOWN HS

Micro Log In **48116**
Total Samples 8
Date Sampled 8/30/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 48116-01 DRINKING FOUNTAIN CORRIDOR C91, 1ST FLOOR FIRST DRAW	8.2	1.0	
Client # 2 Micro 48116-02 DRINKING FOUNTAIN CORRIDOR C91, 2ND FLOOR FIRST DRAW	4.4	1.0	
Client # 3 Micro 48116-03 DRINKING FOUNTAIN CORRIDOR C91 3RD FLOOR FIRST DRAW	8.5	1.0	
Client # 4 Micro 48116-04 SINK FAUCET, ROOM 310 THIRD FLOOR, SMALL KITCHEN FIRST DRAW	1.4	1.0	
Client # 5 Micro 48116-05 DRINKING FOUNTAIN CORRIDOR C91, FOURTH FLOOR FIRST DRAW	12.4	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JAMES DENMAN MS

Micro Log In **48577**
Total Samples 14
Date Sampled 9/17/97
Date Received 9/17/97
Date Analyzed 9/17/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **632-11** Micro 48577-11 **DRINKING FOUNTAIN** **C95 - 3RD FLOOR OUTSIDE RM 304** **FIRST DRAW**	**1.4**	1.0	
Client **632-12** Micro 48577-12 **MULTI DRINKING FOUNTAIN** **EXT. COURTYARD OUTSIDE RM 005** **FIRST DRAW**	**1.5**	1.0	
Client **632-13** Micro 48577-13 **DRINKING FOUNTAIN** **C95 - 4TH FLOOR** **FIRST DRAW**	**21.4**	1.0	
Client **632-14** Micro 48577-14 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 9/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JAMES DENMAN MS

Micro Log In **48577**
Total Samples **14**
Date Sampled **9/17/97**
Date Received **9/17/97**
Date Analyzed **9/17/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **632-6** Micro 48577-06 **DRINKING FOUNTAIN** **C95 - FIRST FLOOR OUTSIDE ROOM 114E** **FIRST DRAW**	**1.4**	1.0	
Client **632-7** Micro 48577-07 **DRINKING FOUNTAIN** **C91 - FIRST FLOOR AUDITORIUM WING** **FIRST DRAW**	**4.0**	1.0	
Client **632-8** Micro 48577-08 **DRINKING FOUNTAIN** **C95 - 2ND FLOOR OUTSIDE ROOM 204** **FIRST DRAW**	**1.3**	1.0	
Client **632-9** Micro 48577-09 **DRINKING FOUNTAIN** **C95 - 2ND FLOOR OUTSIDE RM 214** **FIRST DRAW**	**< 1.0**	1.0	
Client **632-10** Micro 48577-10 **DRINKING FOUNTAIN** **C95 - 3RD FLOOR OUTSIDE RM 314** **FIRST DRAW**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JAMES DENMAN MS

Micro Log In **48577**
Total Samples 14
Date Sampled 9/17/97
Date Received 9/17/97
Date Analyzed 9/17/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **632-1** Micro 48577-01 **DRINKING FOUNTAIN** **584 - 1ST FLOOR** **FIRST DRAW**	**1.7**	1.0	
Client **632-2** Micro 48577-02 **DRINKING FOUNTAIN** **ROOM 050 BASEMENT FLOOR** **FIRST DRAW**	**1.7**	1.0	
Client **632-3** Micro 48577-03 **DRINKING FOUNTAIN** **C99 - BASEMENT FLOOR** **FIRST DRAW**	**2.2**	1.0	
Client **632-4** Micro 48577-04 **DRINKING FOUNTAIN** **C99 - FIRST FLOOR** **FIRST DRAW**	**4.5**	1.0	
Client **632-5** Micro 48577-05 **DRINKING FOUNTAIN** **C95 - FIRST FLOOR OUTSIDE ROOM 105** **FIRST DRAW**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WILLIAM DE AVILA ES

Micro Log In **49189**
Total Samples 4
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **9A** Micro 49189-01 **MULTIPLE DRINKING FOUNTAIN BASEMENT LELVEL - EAST SIDE FIRST DRAW**	**4.3**	1.0	
Client **9B** Micro 49189-02 **MULTIPLE DRINKING FOUNTAIN BASEMENT LELVEL - EAST SIDE FIRST DRAW**	**2.8**	1.0	
Client **9C** Micro 49189-03 **MULTIPLE DRINKING FOUNTAIN BASEMENT LELVEL - EAST SIDE FIRST DRAW**	**4.1**	1.0	
Client **BLANK** Micro 49189-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WILLIAM DE AVILA ES

Micro Log In **47421**
Total Samples 14
Date Sampled 8/15/97
Date Received 8/15/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47421-11 SINK FAUCET FIRST FLOOR SINK IN LIBRARY OFFICE FIRST DRAW	4.8	1.0	
Client 12 Micro 47421-12 DRINKING FOUNTAIN 3RD FLOOR LEVEL BETWEEN RM. 310 AND 309 FIRST DRAW	10.1	1.0	
Client 13 Micro 47421-13 MULTIPLE DRINKING FOUNTAIN FIRST LEVEL PLAYGROUND - EAST SIDE FIRST DRAW	2.4	1.0	
Client 14 Micro 47421-14 DRINKING FOUNTAIN 3RD FLOOR LEVEL HALLWAY FIRST DRAW	11.4	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WILLIAM DE AVILA ES

Micro Log In **47421**
Total Samples **14**
Date Sampled **8/15/97**
Date Received **8/15/97**
Date Analyzed **8/20/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **6** Micro 47421-06 **MULTIPLE DRINKING FOUNTAIN FIRST FLOOR LEVEL PLAYGROUND (WEST) FIRST DRAW**	**3.4**	1.0	
Client **7** Micro 47421-07 **MULTIPLE DRINKING FOUNTAIN FIRST FLOOR LEVEL PLAYGROUND (WEST) FIRST DRAW**	**< 1.0**	1.0	
Client **8** Micro 47421-08 **MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL - NORTH SIDE FIRST DRAW**	**< 1.0**	1.0	
Client **9** Micro 47421-09 **MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL EAST SIDE FIRST DRAW**	**12.5**	1.0	
Client **10** Micro 47421-10 **DRINKING FOUNTAIN FIRST FLOOR LEVEL NEXT TO LADIES' BATHROOM FIRST DRAW**	**2.5**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WILLIAM DE AVILA ES

Micro Log In **47421**
Total Samples 14
Date Sampled 8/15/97
Date Received 8/15/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47421-01 **BLANK**	< 1.0	1.0	
Client 2 Micro 47421-02 **DRINKING FOUNTAIN FIRST FLOOR LIBRARY FIRST DRAW**	6.1	1.0	
Client 3 Micro 47421-03 **DRINKING FOUNTAIN SECOND FLOOR OUTSIDE RM. 209 FIRST DRAW**	5.2	1.0	
Client 4 Micro 47421-04 **DRINKING FOUNTAIN STREET LEVEL (WALLER ST) PLAYGROUND (EAST) FIRST DRAW**	< 1.0	1.0	
Client 5 Micro 47421-05 **DRINKING FOUNTAIN STREET LEVEL (WALLER ST) PLAYGROUND FIRST DRAW**	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GLORIA DAVIS
Return Visit

Micro Log In **48006**
Total Samples 4
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **641-7A** Micro 48006-01 DRINKING FOUNTAIN FIRST FLOOR CORRIDOR C91 ADJ . TO ROOM 114 FIRST DRAW	3.8	1.0	
Client **641-7B** Micro 48006-02 DRINKING FOUNTAIN FIRST FLOOR CORRIDOR C91 ADJ. TO ROOM 114 SECOND DRAW	3.9	1.0	
Client **BLANK** Micro 48006-03 BLANK	< 1.0	1.0	
Client **641-7C** Micro 48006-04 DRINKING FOUNTAIN FIRST FLOOR CORRIDOR ADJ. TO ROOM 114 FIRST DRAW	15.4	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

DAVIS MS (HUDSON)

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 1195 Hudson, Site #641
Lab Proj. ID: 9708B69

Sampled: 08/17/97
Received: 08/22/97
Analyzed: see below
Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B69-08 Sample Desc : LIQUID,641-7				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.052**
Lab No: 9708B69-09 Sample Desc : LIQUID,641-8				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B69-10 Sample Desc : LIQUID,641-9 (Blank)				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B69-11 Sample Desc : LIQUID,641-10				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B69-12 Sample Desc : LIQUID,641-11				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.018**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

Davis MS - Hudson SES

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: 1195 Hudson, Site #641
Lab Proj. ID: 9708B69

Sampled: 08/17/97
Received: 08/22/97
Analyzed: see below
Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B69-01 Sample Desc : LIQUID,641-1				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B69-02 Sample Desc : LIQUID,641-1 (DUP)				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B69-03 Sample Desc : LIQUID,641-2				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B69-04 Sample Desc : LIQUID,641-3				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B69-05 Sample Desc : LIQUID,641-4				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B69-06 Sample Desc : LIQUID,641-5				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B69-07 Sample Desc : LIQUID,641-6				
Lead	mg/L	08/26/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

DAVIS MS (EVANS)

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Site #1550 Evans St.

Lab Proj. ID: 9708B58

Sampled: 08/17/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B58-01 Sample Desc : LIQUID,1550-1				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B58-02 Sample Desc : LIQUID,1550-1 Dup				
Lead	mg/L	08/25/97	0.0050	N.D. D
Lab No: 9708B58-03 Sample Desc : LIQUID,1550-2				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B58-04 Sample Desc : LIQUID,1550-3				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B58-05 Sample Desc : LIQUID,1550-4 (Blank)				
Lead	mg/L	08/26/97	0.0050	N.D. B
Lab No: 9708B58-06 Sample Desc : LIQUID,1550-5				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.026** S

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SARAH B. COOPER
PROJECT NO. B-2243

Micro Log In 66557
Total Samples 7
Date Sampled 3/23/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client COOPER 3B 98 (A) Micro 66557-06 2ND DRAW, ROOM 3 SINK DRINKING FOUNTAIN	< 1	1	
Client COOPER BL Micro 66557-07 BLANK	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environment Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Healt Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with th approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SARAH B. COOPER
PROJECT NO. B-2243

Micro Log In 66557
Total Samples 7
Date Sampled 3/23/99
Date Received 3/25/99
Date Analyzed 3/30/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client COOPER 1A 7A Micro 66557-01 1ST DRAW EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client COOPER 1B 7B Micro 66557-02 2ND DRAW EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client COOPER 2A 8A Micro 66557-03 1ST DRAW, ROOM 4 SINK DRINKING FOUNTAIN	2	1	
Client COOPER 2B 8B Micro 66557-04 2ND DRAW, ROOM 4 SINK DRINKING FOUNTAIN	< 1	1	
Client COOPER 3A 9A Micro 66557-05 1ST DRAW, ROOM 3 SINK DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/30/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
COOPER CC

Micro Log In **47743**
Total Samples 8
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47743-06 SINK FAUCET 2ND FLOOR - MIDDLE CLASSROOM FIRST DRAW	2.8	1.0	
Client 7 Micro 47743-07 BLANK	< 1.0	1.0	
Client 8 Micro 47743-08 SPIKED	46.6	1.0	

Technical Supervisor: _____ 9/1/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
COOPER CC

Micro Log In **47743**
Total Samples 8
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47743-01 SINK FAUCET 1ST FLOOR - WEST CLASSROOM FIRST DRAW	< 1.0	1.0	
Client 2 Micro 47743-02 SINK FAUCET 1ST FLOOR - EAST CLASSROOM CLOSET FIRST DRAW	< 1.0	1.0	
Client 3 Micro 47743-03 SINK FAUCET 2ND FLOOR - EAST CLASSROOM FIRST DRAW	4.8	1.0	
Client 4 Micro 47743-04 SINK FAUCET 2ND FLOOR - WEST SIDE CLASSROOM FIRST DRAW	9.5	1.0	
Client 5 Micro 47743-05 SINK FAUCET 2ND FLOOR - WEST SIDE KITCHEN FIRST DRAW	1.4	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
COBB CC

Micro Log In **49290**
Total Samples 3
Date Sampled 10/2/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 8 Micro 49290-01 MULTIPLE DRINKING FOUNTAIN OUTSIDE FIRST DRAW	2.3	1.0	
Client 9 Micro 49290-02 MULTIPLE DRINKING FOUNTAIN OUTSIDE FIRST DRAW	< 1.0	1.0	
Client 10B Micro 49290-03 BLANK	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/12/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Cobb

Lab Proj. ID: 9708D00

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D00-06				
Sample Desc : LIQUID,Cobb 7				
Lead	mg/L	08/28/97	0.0050	0.011 S

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Cobb
Lab Proj. ID: 9708D00

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below
Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D00-01 Sample Desc : LIQUID,Cobb 1				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D00-02 Sample Desc : LIQUID,Cobb 1 Duplicate				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D00-03 Sample Desc : LIQUID,Cobb 2				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D00-04 Sample Desc : LIQUID,Cobb 3				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D00-05 Sample Desc : LIQUID,Cobb 4				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D00-06 Sample Desc : LIQUID,Cobb 5				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D00-07 Sample Desc : LIQUID,Cobb 6 Blank				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLEVELAND ES

Micro Log In **47844**
Total Samples 25
Date Sampled 8/22/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 97-W00753-5 Micro 47844-21 SPIKED SAMPLE	18.5	1.0	
Client 22 Micro 47844-22 DRINKING FOUNTAIN B01A	< 1.0	1.0	
Client 23 Micro 47844-23 SINK FAUCET B01A	3.4	1.0	
Client 24 Micro 47844-24 MULTIPLE DRINKING FOUNTAIN LEFT SIDE MULTIPLE DRINKING FOUNTAIN YARD	< 1.0	1.0	
Client 25 Micro 47844-25 MULTIPLE DRINKING FOUNTAIN RIGHT SIDE MULTIPLE DRINKING FOUNTAIN YARD	5.7	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLEVELAND ES

Micro Log In **47844**
Total Samples **25**
Date Sampled **8/22/97**
Date Received **8/26/97**
Date Analyzed **8/31/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **16** Micro 47844-16 **SINK FAUCET** **214A**	< **1.0**	1.0	
Client **17** Micro 47844-17 **SINK FAUCET** **215A**	< **1.0**	1.0	
Client **18** Micro 47844-18 **DRINKING FOUNTAIN** **SECOND FLOOR DRINKING FOUNTAIN** **C90 HALL**	< **1.0**	1.0	
Client **19** Micro 47844-19 **WATER FAUCET** **B03A**	< **1.0**	1.0	
Client **20** Micro 47844-20 **BLANK**	< **1.0**	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLEVELAND ES

Micro Log In **47844**
Total Samples 25
Date Sampled 8/22/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47844-11 SINK FAUCET 1ST FLOOR HALL R.R.	< 1.0	1.0	
Client 12 Micro 47844-12 210A	< 1.0	1.0	
Client 13 Micro 47844-13 WATER FAUCET FACULTY LUNCH RM.	< 1.0	1.0	
Client 14 Micro 47844-14 SINK FAUCET 211A	< 1.0	1.0	
Client 15 Micro 47844-15 SINK FAUCET 212A	< 1.0	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLEVELAND ES

Micro Log In 47844
Total Samples 25
Date Sampled 8/22/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47844-06 WATER FAUCET 108A	< 1.0	1.0	
Client 7 Micro 47844-07 DRINKING FOUNTAIN 1ST FL. C90 (HALL)	< 1.0	1.0	
Client 8 Micro 47844-08 WATER FAUCET OFFICE R. R.	< 1.0	1.0	
Client 9 Micro 47844-09 WATER FAUCET PRINCIPAL R. R.	< 1.0	1.0	
Client 10 Micro 47844-10 BLANK	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLEVELAND ES

Micro Log In **47844**
Total Samples 25
Date Sampled 8/22/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47844-01 SINK FAUCET BASEMENT GIRLS' RM.	< 1.0	1.0	
Client 2 Micro 47844-02 WATER FAUCET BASEMENT WF (LEFT)	< 1.0	1.0	
Client 3 Micro 47844-03 WATER FAUCET BASEMENT WF (RIGHT)	< 1.0	1.0	
Client 4 Micro 47844-04 SINK FAUCET BASEMENT BOYS' RM.	< 1.0	1.0	
Client 5 Micro 47844-05 WATER FAUCET 105A	< 1.0	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLAREDON ES
B-2243

Micro Log In **50766**
Total Samples 4
Date Sampled 11/12/97
Date Received 11/18/97
Date Analyzed 11/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **478-3A** Micro 50766-01 **DRINKING FOUNTAIN** **1ST FLOOR C92** **1ST DRAW**	**1.6**	1.0	
Client **478-3B** Micro 50766-02 **DRINKING FOUNTAIN** **1ST FLOOR C92** **2ND DRAW**	**1.5**	1.0	
Client **478-3C** Micro 50766-03 **DRINKING FOUNTAIN** **1ST FLOOR C92** **3RD DRAW**	**1.7**	1.0	
Client **478-BLANK** Micro 50766-04	**< 1.0**	1.0	

Technical Supervisor: 11/19/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLARENDON ES #478

Micro Log In **47608**
Total Samples 30
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 478-26 Micro 47608-26 MULTIPLE DRINKING FOUNTAIN 1ST FLOOR - OUTSIDE BLDG & T52 FIRST DRAW	2.6	1.0	
Client 478-27 Micro 47608-27 SINK DRINKING FOUNTAIN BUNGALOW CLASSROOM FIRST DRAW	4.2	1.0	
Client 478-28 Micro 47608-28 SINK DRINKING FOUNTAIN BUNGALOW CLASSROOM FIRST DRAW	9.7	1.0	
Client 478-29 Micro 47608-29 BLANK	< 1.0	1.0	
Client 478-30 Micro 47608-30 DRINKING FOUNTAIN ROOM 102 FIRST DRAW	20.5	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLARENDON ES #478

Micro Log In **47608**
Total Samples 30
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **478-21** Micro 47608-21 **SINK DRINKING FOUNTAIN** **2ND FLOOR - RM 209** **FIRST DRAW**	< 1.0	1.0	
Client **478-22** Micro 47608-22 **SINK DRINKING FOUNTAIN** **2ND FLOOR - RM 214** **FIRST DRAW**	< 1.0	1.0	
Client **478-23** Micro 47608-23 **SINK DRINKING FOUNTAIN** **2ND FLOOR - RM 206** **FIRST DRAW**	< 1.0	1.0	
Client **478-24** Micro 47608-24 **SINK DRINKING FOUNTAIN** **2ND FLOOR - RM 204** **FIRST DRAW**	< 1.0	1.0	
Client **478-25** Micro 47608-25 **DRINKING FOUNTAIN** **2ND FLOOR - C80** **FIRST DRAW**	1.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLARENDON ES #478

Micro Log In **47608**
Total Samples 30
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **478-16** Micro 47608-16 **DRINKING FOUNTAIN BASEMENT - RM 005 FIRST DRAW**	< **1.0**	1.0	
Client **478-17** Micro 47608-17 **MULTIPLE DRINKING FOUNTAIN BASEMENT - OUTSIDE NEXT TO S80 FIRST DRAW**	**1.6**	1.0	
Client **478-18** Micro 47608-18 **SINK DRINKING FOUNTAIN 2ND FLOOR - RM 203 FIRST DRAW**	**1.2**	1.0	
Client **478-19** Micro 47608-19 **SINK DRINKING FOUNTAIN 2ND FLOOR - RM 205 FIRST DRAW**	**2.1**	1.0	
Client **478-20** Micro 47608-20 **SINK DRINKING FOUNTAIN 2ND FLOOR - RM 207 FIRST DRAW**	< **1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLARENDON ES #478

Micro Log In **47608**
Total Samples 30
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 478-11 Micro 47608-11 SINK DRINKING FOUNTAIN 1ST FLOOR - RM 110 FIRST DRAW	< 1.0	1.0	
Client 478-12 Micro 47608-12 SINK DRINKING FOUNTAIN 1ST FLOOR - RM 116 FIRST DRAW	< 1.0	1.0	
Client 478-13 Micro 47608-13 SINK DRINKING FOUNTAIN BASEMENT - RM 001 FIRST DRAW	< 1.0	1.0	
Client 478-14 Micro 47608-14 SINK DRINKING FOUNTAIN BASEMENT - RM 003 FIRST DRAW	1.8	1.0	
Client 478-15 Micro 47608-15 SINK DRINKING FOUNTAIN BASEMENT - RM 005 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLARENDON ES #478

Micro Log In **47608**
Total Samples 30
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 478-6 Micro 47608-06 SINK DRINKING FOUNTAIN 1ST FLOOR - RM 103 FIRST DRAW	2.9	1.0	
Client 478-7 Micro 47608-07 SINK DRINKING FOUNTAIN 1ST FLOOR - RM 102 FIRST DRAW	1.1	1.0	
Client 478-8 Micro 47608-08 SINK DRINKING FOUNTAIN 1ST FLOOR - RM 105 FIRST DRAW	3.7	1.0	
Client 478-9 Micro 47608-09 SINK DRINKING FOUNTAIN 1ST FLOOR - RM 107 FIRST DRAW	4.7	1.0	
Client 478-10 Micro 47608-10 SINK DRINKING FOUNTAIN 1ST FLOOR - RM 109 FIRST DRAW	1.2	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLARENDON ES #478

Micro Log In **47608**
Total Samples 30
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 478-1 Micro 47608-01 SINK FAUCET 1ST FLOOR - RM 124 - KITCHEN FIRST DRAW	< 1.0	1.0	
Client 478-2 Micro 47608-02 SINK FAUCET 1ST FLOOR - RM 124 - KITCHEN FIRST DRAW	1.5	1.0	
Client 478-3 Micro 47608-03 DRINKING FOUNTAIN 1ST FLOOR - C92 FIRST DRAW	12.1	1.0	
Client 478-4 Micro 47608-04 SINK FAUCET 1ST FLOOR - RM 106 - NURSE OFFICE FIRST DRAW	2.6	1.0	
Client 478-5 Micro 47608-05 DRINKING FOUNTAIN 1ST FLOOR - C91 FIRST DRAW	1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Chinese Ed. Ctr.

Lab Proj. ID: 9710491

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710491-08 Sample Desc : **LIQUID,CEC 10-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710491-09 Sample Desc : **LIQUID,CEC 10-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.019**
Lab No: 9710491-10 Sample Desc : **LIQUID,CEC 10-C (duplicate)**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.017**
Lab No: 9710491-11 Sample Desc : **LIQUID,CEC Blank**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Chinese Ed. Ctr.

Lab Proj. ID: 9710491

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710491-01 Sample Desc : **LIQUID,CEC 3-A**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0060**
Lab No: 9710491-02 Sample Desc : **LIQUID,CEC 3-B**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0090**
Lab No: 9710491-03 Sample Desc : **LIQUID,CEC 3-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.018**
Lab No: 9710491-04 Sample Desc : **LIQUID,CEC 4-A**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.010**
Lab No: 9710491-05 Sample Desc : **LIQUID,CEC 4-B**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.016**
Lab No: 9710491-06 Sample Desc : **LIQUID,CEC 4-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.020**
Lab No: 9710491-07 Sample Desc : **LIQUID,CEC 10-A**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Chinese Ed. Center
Lab Proj. ID: 9708B86

Sampled: 08/21/97
Received: 08/22/97
Analyzed: see below
Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B86-08 Sample Desc : LIQUID,Chinese Ed. Center-7				
Lead	mg/L	08/27/97	0.0050	0.0052
Lab No: 9708B86-09 Sample Desc : LIQUID,Chinese Ed. Center-8				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708B86-10 Sample Desc : LIQUID,Chinese Ed. Center-9				
Lead	mg/L	08/28/97	0.0050	0.0079
Lab No: 9708B86-11 Sample Desc : LIQUID,Chinese Ed. Center-10				
Lead	mg/L	08/28/97	0.0050	0.013
Lab No: 9708B86-12 Sample Desc : LIQUID,BL-(Blank)				
Lead	mg/L	08/28/97	0.0050	N.D.

B

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Chinese Ed. Center

Lab Proj. ID: 9708B86

Sampled: 08/21/97
Received: 08/22/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B86-01 Sample Desc : LIQUID,Chinese Ed. Center-1				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B86-02 Sample Desc : LIQUID,Chinese Ed. Center-1 (DUP)				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0054**
Lab No: 9708B86-03 Sample Desc : LIQUID,Chinese Ed. Center-2				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B86-04 Sample Desc : LIQUID,Chinese Ed. Center-3				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.012**
Lab No: 9708B86-05 Sample Desc : LIQUID,Chinese Ed. Center-4				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.016**
Lab No: 9708B86-06 Sample Desc : LIQUID,Chinese Ed. Center-5				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0097**
Lab No: 9708B86-07 Sample Desc : LIQUID,Chinese Ed. Center-6				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0084**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CHINATOWN YOUTH CENTER

Micro Log In **49454**
Total Samples 4
Date Sampled 10/9/97
Date Received 10/10/97
Date Analyzed 10/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 49454-01 SINK FAUCET ROOM 112	5.9	1.0	
Client 2 Micro 49454-02 SINK FAUCET ROOM 111	1.8	1.0	
Client 3 Micro 49454-03 SINK FAUCET ROOM 109	2.8	1.0	
Client 4 Micro 49454-04 SINK FAUCET ROOM 207	1.6	1.0	

Technical Supervisor: F. Ramezanzadeh 10/12/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Client Proj. ID: Chin E.S.
Lab Proj. ID: 9710483

Sampled: 10/01/97
Received: 10/09/97
Analyzed: see below

Attention: Bruce Giannini

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710483-08				
Sample Desc : **LIQUID,Chin E.S. Blank**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Chin E.S.

Lab Proj. ID: 9710483

Sampled: 10/01/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710483-01 Sample Desc : **LIQUID,Chin E.S. 3-A**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.010**
Lab No: 9710483-02 Sample Desc : **LIQUID,Chin E.S. 3-B**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0060**
Lab No: 9710483-03 Sample Desc : **LIQUID,Chin E.S. 3-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.015**
Lab No: 9710483-04 Sample Desc : **LIQUID,Chin E.S. 5-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710483-05 Sample Desc : **LIQUID,Chin E.S. 5-B**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0060**
Lab No: 9710483-06 Sample Desc : **LIQUID,Chin E.S. 5-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710483-07 Sample Desc : **LIQUID,Chin E.S. 5-C (duplicate)**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOHN YEHALL CHIN ES

Micro Log In **47787**
Total Samples 6
Date Sampled 8/22/97
Date Received 8/26/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: CHIN 6 Micro: 47787-06 BLANK	< 1.0	1.0	

Technical Supervisor: F Ramezanzadeh 8/31/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOHN YEHALL CHIN ES

Micro Log In **47787**
Total Samples 6
Date Sampled 8/22/97
Date Received 8/26/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **CHIN 1** Micro 47787-01 **SINK FAUCET FIRST DRAW**	**7.2**	1.0	
Client **CHIN 2** Micro 47787-02 **SINK FAUCET FIRST DRAW**	**1.2**	1.0	
Client **CHIN 3** Micro 47787-03 **DRINKING FOUNTAIN FIRST DRAW**	**19.7**	1.0	
Client **CHIN 4** Micro 47787-04 **DRINKING FOUNTAIN FIRST DRAW**	**10.0**	1.0	
Client **CHIN 5** Micro 47787-05 **MULTIPLE DRINKING FOUNTAIN FIRST DRAW**	**17.5**	1.0	

Technical Supervisor: F. Ramezanzadeh 8/31/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CESAR CHAVEZ ES

Micro Log In **48025**
Total Samples **15**
Date Sampled **8/26/97**
Date Received **8/30/97**
Date Analyzed **8/30/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **11** Micro 48025-11 **SINK FAUCET** **LOUNGE KITCHEN** **FIRST DRAW**	**21.0**	1.0	
Client **12** Micro 48025-12 **MULTIPLE DRINKING FOUNTAIN (2)(RHS)** **2ND FLOOR HALL - SOUTH** **FIRST DRAW**	**4.5**	1.0	
Client **13** Micro 48025-13 **MULTIPLE DRINKING FOUNTAIN (2)(RHS)** **2ND FLOOR HALL - NORTH** **FIRST DRAW**	**1.3**	1.0	
Client **14** Micro 48025-14 **SINK FAUCET** **KITCHEN ROOM 35A** **FIRST DRAW**	**2.1**	1.0	
Client **15** Micro 48025-15 **FIELD BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CESAR CHAVEZ ES

Micro Log In **48025**
Total Samples 15
Date Sampled 8/26/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 48025-06 MULTIPLE DRINKING FOUNTAIN (3)(CENTER) CORRIDOR E OF ROOM 4 FIRST DRAW	< 1.0	1.0	
Client 7 Micro 48025-07 WATER-COOLED DRINKING FOUNTAIN CORRIDOR W OF ROOM 4 FIRST DRAW	3.8	1.0	
Client 8 Micro 48025-08 MULTIPLE DRINKING FOUNTAIN (3)(CENTER) CORRIDOR W OF ROOM 4 FIRST DRAW	1.0	1.0	
Client 9 Micro 48025-09 MULTIPLE DRINKING FOUNTAIN (2)(LHS) CORRIDOR W OF ROOM 4 FIRST DRAW	< 1.0	1.0	
Client 10 Micro 48025-10 MULTIPLE DRINKING FOUNTAIN (2)(LHS) 1ST FLOOR HALL SOUTH FIRST DRAW	2.0	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CESAR CHAVEZ ES

Micro Log In **48025**
Total Samples **15**
Date Sampled **8/26/97**
Date Received **8/30/97**
Date Analyzed **8/30/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48025-01 SINK FAUCET KITCHEN OFF ROOM 2 FIRST DRAW	3.5	1.0	
Client 2 Micro 48025-02 MULTIPLE DRINKING FOUNTAIN 1ST FLOOR HALL NORTH FIRST DRAW	1.2	1.0	
Client 3 Micro 48025-03 SINK DRINKING FOUNTAIN ROOM 30B (KIND. 2) FIRST DRAW	3.4	1.0	
Client 4 Micro 48025-04 SINK FAUCET KITCHEN ROOM 151A FIRST DRAW	5.5	1.0	
Client 5 Micro 48025-05 MULTIPLE DRINKING FOUNTAIN (2)(LHS) CORRIDOR E OF ROOM 4 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CENTRAL CITY
HOSPITALITY

Micro Log In **49455**
Total Samples 9
Date Sampled 10/7/97
Date Received 10/10/97
Date Analyzed 10/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 49455-06 SINK FAUCET MEN'S RESTROOM RIGHT	< 1.0	1.0	
Client 7 Micro 49455-07 SINK FAUCET MEN'S RESTROOM	3.1	1.0	
Client 8 Micro 49455-08 SINK FAUCET WOMEN'S RESTROOM	2.2	1.0	
Client 9 Micro 49455-09 BLANK	< 1.0	1.0	

Technical Supervisor: 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CENTRAL CITY
HOSPITALITY

Micro Log In **49455**
Total Samples 9
Date Sampled 10/7/97
Date Received 10/10/97
Date Analyzed 10/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 49455-01 **SINK FAUCET** **KITCHEN**	10.0	1.0	
Client 2 Micro 49455-02 **DRINKING FOUNTAIN** **HALL DRINKING FOUNTAIN**	< 1.0	1.0	
Client 3 Micro 49455-03 **SINK FAUCET** **WOMEN'S RESTROOM LEFT**	< 1.0	1.0	
Client 4 Micro 49455-04 **SINK FAUCET** **WOMEN RESTROOM RIGHT**	< 1.0	1.0	
Client 5 Micro 49455-05 **SINK FAUCET** **MEN'S RESTROOM LEFT**	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES 2243

Micro Log In **52161**
Total Samples 3
Date Sampled 1/17/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **CARVER 33A** Micro 52161-01 **SINK DRINKING FOUNTAIN COUNTER LEVEL SE WING**	**2.4**	1.0	
Client **CARVER 33B** Micro 52161-02 **SINK DRINKING FOUNTAIN COUNTER LEVEL SE WING**	**7.8**	1.0	
Client **CARVER 33C** Micro 52161-03 **SINK DRINKING FOUNTAIN COUNTER LEVEL SE WING**	**2.7**	1.0	

Technical Supervisor: F. Ramezanzadeh 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **28B** Micro 49292-61 **LOWER LEVEL S.E WING FIRST DRAW**	**2.2**	1.0	
Client **28C** Micro 49292-62 **LOWER LEVEL S.E WING FIRST DRAW**	**4.1**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **26C** Micro 49292-56 **LOWER LEVEL HALL FIRST DRAW**	**5.7**	1.0	
Client **27A** Micro 49292-57 **LOWER LEVEL S.E WING HALL FIRST DRAW**	**17.7**	1.0	
Client **27B** Micro 49292-58 **LOWER LEVEL S.E WING HALL FIRST DRAW**	**11.9**	1.0	
Client **27C** Micro 49292-59 **LOWER LEVEL S.E WING HALL FIRST DRAW**	**16.7**	1.0	
Client **28A** Micro 49292-60 **LOWER LEVEL S.E WING FIRST DRAW**	**3.3**	1.0	

Technical Supervisor: F. Ramezanzadeh, M.D. 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **37A** Micro 49292-51 SINK FAUCET LOWER LEVEL FACULITY DINING FIRST DRAW	7.2	1.0	
Client **37B** Micro 49292-52 SINK FAUCET LOWER LEVEL FACULITY DINING FIRST DRAW	19.4	1.0	
Client **37C** Micro 49292-53 SINK FAUCET LOWER LEVEL FACULITY DINING FIRST DRAW	49.6	1.0	
Client **26A** Micro 49292-54 LOWER LEVEL HALL FIRST DRAW	2.9	1.0	
Client **26B** Micro 49292-55 LOWER LEVEL HALL FIRST DRAW	4.3	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **35B** Micro 49292-46 **DRINKING FOUNTAIN LOWER LEVEL MULTI-PURPOSE ROOM FIRST DRAW**	**8.9**	1.0	
Client **35C** Micro 49292-47 **DRINKING FOUNTAIN LOWER LEVEL MULTI-PURPOSE ROOM FIRST DRAW**	**13.2**	1.0	
Client **36A** Micro 49292-48 **SINK DRINKING FOUNTAIN LOWER LEVEL MULTI-PURPOSE ROOM FIRST DRAW**	**3.0**	1.0	
Client **36B** Micro 49292-49 **SINK DRINKING FOUNTAIN LOWER LEVEL MULTI-PURPOSE ROOM FIRST DRAW**	**3.3**	1.0	
Client **36C** Micro 49292-50 **SINK DRINKING FOUNTAIN LOWER LEVEL MULTI-PURPOSE ROOM FIRST DRAW**	**4.1**	1.0	

Technical Supervisor: F Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 30C Micro: 49292-41 SINK DRINKING FOUNTAIN LOWER LEVEL S.E WING FIRST DRAW	11.5	1.0	
Client: 17A Micro: 49292-42 DRINKING FOUNTAIN UPPER LEVEL TEACHER LOUNGE FIRST DRAW	3.5	1.0	
Client: 17B Micro: 49292-43 DRINKING FOUNTAIN UPPER LEVEL TEACHER LOUNGE FIRST DRAW	2.8	1.0	
Client: 17C Micro: 49292-44 DRINKING FOUNTAIN UPPER LEVEL TEACHER LOUNGE FIRST DRAW	18.2	1.0	
Client: 35A Micro: 49292-45 DRINKING FOUNTAIN LOWER LEVEL MULTI-PURPOSE ROOM FIRST DRAW	20.1	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **29A** Micro 49292-36 **SINK DRINKING FOUNTAIN LOWER LEVEL S.E WING FIRST DRAW**	**3.1**	1.0	
Client **29B** Micro 49292-37 **SINK DRINKING FOUNTAIN LOWER LEVEL S.E WING FIRST DRAW**	**2.4**	1.0	
Client **29C** Micro 49292-38 **SINK DRINKING FOUNTAIN LOWER LEVEL S.E WING FIRST DRAW**	**3.6**	1.0	
Client **30A** Micro 49292-39 **SINK DRINKING FOUNTAIN LOWER LEVEL S.E WING FIRST DRAW**	**5.1**	1.0	
Client **30B** Micro 49292-40 **SINK DRINKING FOUNTAIN LOWER LEVEL S.E WING FIRST DRAW**	**3.7**	1.0	

Technical Supervisor: _____ 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11B Micro 49292-31 SINK DRINKING FOUNTAIN UPPER LEVEL S.W WING FIRST DRAW	3.0	1.0	
Client 11C Micro 49292-32 SINK DRINKING FOUNTAIN UPPER LEVEL S.W WING FIRST DRAW	6.0	1.0	
Client 12A Micro 49292-33 SINK DRINKING FOUNTAIN UPPER LEVEL S.W WING FIRST DRAW	6.5	1.0	
Client 12B Micro 49292-34 SINK DRINKING FOUNTAIN UPPER LEVEL S.W WING FIRST DRAW	5.6	1.0	
Client 12C Micro 49292-35 SINK DRINKING FOUNTAIN UPPER LEVEL S.W WING FIRST DRAW	10.9	1.0	

Technical Supervisor: 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In 49292
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6C Micro 49292-26 SINK DRINKING FOUNTAIN UPPER LEVEL S.E WING FIRST DRAW	4.6	1.0	
Client 7A Micro 49292-27 SINK DRINKING FOUNTAIN UPPER LEVEL S.E WING FIRST DRAW	3.9	1.0	
Client 7B Micro 49292-28 SINK DRINKING FOUNTAIN UPPER LEVEL S.E WING FIRST DRAW	9.5	1.0	
Client 7C Micro 49292-29 SINK DRINKING FOUNTAIN UPPER LEVEL S.E WING FIRST DRAW	3.5	1.0	
Client 11A Micro 49292-30 SINK DRINKING FOUNTAIN UPPER LEVEL S.W WING FIRST DRAW	5.3	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 5 A Micro 49292-21 SINK DRINKING FOUNTAIN UPPER LEVEL S.E WING FIRST DRAW	1.7	1.0	
Client 5 B Micro 49292-22 SINK DRINKING FOUNTAIN UPPER LEVEL S.E WING FIRST DRAW	2.4	1.0	
Client 5 C Micro 49292-23 SINK DRINKING FOUNTAIN UPPER LEVEL S.E WING FIRST DRAW	3.1	1.0	
Client 6 A Micro 49292-24 SINK DRINKING FOUNTAIN UPPER LEVEL S.E WING FIRST DRAW	2.5	1.0	
Client 6 B Micro 49292-25 SINK DRINKING FOUNTAIN UPPER LEVEL S.E WING FIRST DRAW	2.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **1B** Micro 49292-16 **DRINKING FOUNTAIN S.E WING UPPER FLOOR FIRST DRAW**	**10.7**	1.0	
Client **1C** Micro 49292-17 **DRINKING FOUNTAIN S.E WING UPPER FLOOR FIRST DRAW**	**10.5**	1.0	
Client **16A** Micro 49292-18 **SINK FAUCET TEACHER LOUNGE / UPPER FLOOR FIRST DRAW**	**4.9**	1.0	
Client **16B** Micro 49292-19 **SINK FAUCET TEACHER LOUNGE / UPPER FLOOR FIRST DRAW**	**2.4**	1.0	
Client **16C** Micro 49292-20 **SINK FAUCET TEACHER LOUNGE / UPPER FLOOR FIRST DRAW**	**6.5**	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **22C** Micro 49292-11 SINK DRINKING FOUNTAIN N.W WING UPPER FIRST DRAW	8.7	1.0	
Client **21A** Micro 49292-12 SINK DRINKING FOUNTAIN N.W WING UPPER FLOOR FIRST DRAW	4.4	1.0	
Client **21B** Micro 49292-13 SINK DRINKING FOUNTAIN N.W WING UPPER FLOOR FIRST DRAW	2.1	1.0	
Client **21C** Micro 49292-14 SINK DRINKING FOUNTAIN N.W WING UPPER FLOOR FIRST DRAW	6.0	1.0	
Client **1A** Micro 49292-15 DRINKING FOUNTAIN S.E WING UPPER FLOOR FIRST DRAW	10.5	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **38C** Micro 49292-06 **SINK FAUCET LOWER LEVEL KITCHEN FIRST DRAW**	**22.0**	1.0	
Client **CARVER S** Micro 49292-07 **SPIKED**	**10.9**	1.0	
Client **BLANK** Micro 49292-08 **BLANK**	**< 1.0**	1.0	
Client **22A** Micro 49292-09 **SINK DRINKING FOUNTAIN N.W WING UPPER FIRST DRAW**	**12.1**	1.0	
Client **22B** Micro 49292-10 **SINK DRINKING FOUNTAIN N.W WING UPPER FIRST DRAW**	**4.4**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARVER ES

Micro Log In **49292**
Total Samples 62
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **25A** Micro 49292-01 SINK DRINKING FOUNTAIN UPPER LEVEL N.W WING FIRST DRAW	12.8	1.0	
Client **25B** Micro 49292-02 SINK DRINKING FOUNTAIN UPPER LEVEL N.W WING FIRST DRAW	13.0	1.0	
Client **25C** Micro 49292-03 SINK DRINKING FOUNTAIN UPPER LEVEL N.W WING FIRST DRAW	6.6	1.0	
Client **38A** Micro 49292-04 SINK FAUCET LOWER LEVEL KITCHEN FIRST DRAW	4.0	1.0	
Client **38B** Micro 49292-05 SINK FAUCET LOWER LEVEL KITCHEN FIRST DRAW	4.3	1.0	

Technical Supervisor: F. Ramezanzadeh, M.S. 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
G. W. CARVER ES

Micro Log In **47728**
Total Samples 34
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 37 Micro 47728-31 SINK FAUCET LOWER LEVEL FACULTY DINING FIRST DRAW	13.6	1.0	
Client 38 Micro 47728-32 SINK FAUCET LOWER LEVEL KITCHEN FIRST DRAW	26.6	1.0	
Client B Micro 47728-33 BLANK	<1.0	1.0	
Client 39 Micro 47728-34 SPIKED	64.0	2.5	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
G. W. CARVER ES

Micro Log In **47728**
Total Samples 34
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 32 Micro 47728-26 SINK DRINKING FOUNTAIN LOWER LEVEL SE WING FIRST DRAW	4.5	1.0	
Client 33 Micro 47728-27 SINK DRINKING FOUNTAIN LOWER LEVEL SE WING FIRST DRAW	11.6	1.0	
Client 34 Micro 47728-28 SINK DRINKING FOUNTAIN LOWER LEVEL SE WING FIRST DRAW	10.3	1.0	
Client 35 Micro 47728-29 DRINKING FOUNTAIN LOWER LEVEL MULTI - PURPOSE FIRST DRAW	29.6	1.0	
Client 36 Micro 47728-30 SINK DRINKING FOUNTAIN LOWER LEVEL MULTI - PURPOSE FIRST DRAW	13.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry In accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
G. W. CARVER ES

Micro Log In **47728**
Total Samples 34
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **27** Micro 47728-21 **DRINKING FOUNTAIN LOWER FLOOR SE WING - HALL FIRST DRAW**	**122**	2.5	
Client **28** Micro 47728-22 **SINK DRINKING FOUNTAIN LOWER LEVEL SE WING FIRST DRAW**	**79.3**	2.0	
Client **29** Micro 47728-23 **SINK DRINKING FOUNTAIN LOWER LEVEL SE WING FIRST DRAW**	**28.7**	1.0	
Client **30** Micro 47728-24 **SINK DRINKING FOUNTAIN LOWER LEVEL SE WING FIRST DRAW**	**166**	6.7	
Client **31** Micro 47728-25 **SINK DRINKING FOUNTAIN LOWER LEVEL SE WING FIRST DRAW**	**10.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
G. W. CARVER ES

Micro Log In **47728**
Total Samples **34**
Date Sampled **8/19/97**
Date Received **8/25/97**
Date Analyzed **8/25/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **22** Micro 47728-16 SINK DRINKING FOUNTAIN UPPER FLOOR NW WING - LIBRARY FIRST DRAW	**162**	5.0	
Client **23** Micro 47728-17 SINK DRINKING FOUNTAIN UPPER FLOOR NW WING - LIBRARY FIRST DRAW	**5.8**	1.0	
Client **24** Micro 47728-18 SINK DRINKING FOUNTAIN UPPER FLOOR NW WING FIRST DRAW	**4.4**	1.0	
Client **25** Micro 47728-19 SINK DRINKING FOUNTAIN UPPER FLOOR NW WING FIRST DRAW	**28.1**	1.0	
Client **26** Micro 47728-20 DRINKING FOUNTAIN LOWER FLOOR HALL FIRST DRAW	**27.5**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
G. W. CARVER ES

Micro Log In **47728**
Total Samples 34
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47728-11 SINK FAUCET UPPER FLOOR TEACHERS' LOUNGE FIRST DRAW	25.7	1.0	
Client 17 Micro 47728-12 SINK FAUCET UPPER FLOOR TEACHERS' LOUNGE FIRST DRAW	13.7	1.0	
Client 18 Micro 47728-13 DRINKING FOUNTAIN UPPER FLOOR NW WING FIRST DRAW	5.4	1.0	
Client 20 Micro 47728-14 SINK DRINKING FOUNTAIN UPPER FLOOR NW WING FIRST DRAW	8.4	1.0	
Client 21 Micro 47728-15 SINK DRINKING FOUNTAIN UPPER FLOOR NW WING FIRST DRAW	25.9	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
G. W. CARVER ES

Micro Log In **47728**
Total Samples 34
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 7 Micro 47728-06 SINK DRINKING FOUNTAIN UPPER FLOOR SE WING FIRST DRAW	34.8	1.0	
Client 8 Micro 47728-07 SINK DRINKING FOUNTAIN UPPER FLOOR SE WING FIRST DRAW	2.9	1.0	
Client 9 Micro 47728-08 SINK FAUCET UPPER FLOOR COURTYARD FIRST DRAW	7.0	1.0	
Client 11 Micro 47728-09 SINK DRINKING FOUNTAIN UPPER FLOOR SW CLASSROOMS FIRST DRAW	87.2	2.2	
Client 12 Micro 47728-10 SINK DRINKING FOUNTAIN UPPER FLOOR SW CLASSROOMS FIRST DRAW	34.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
G. W. CARVER ES

Micro Log In **47728**
Total Samples 34
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47728-01 DRINKING FOUNTAIN UPPER FLOOR SE WING FIRST DRAW	25.2	1.0	
Client 3 Micro 47728-02 SINK DRINKING FOUNTAIN UPPER FLOOR SE WING FIRST DRAW	<1.0	1.0	
Client 4 Micro 47728-03 SINK DRINKING FOUNTAIN UPPER FLOOR SE WING FIRST DRAW	3.6	1.0	
Client 5 Micro 47728-04 SINK DRINKING FOUNTAIN UPPER FLOOR SE WING FIRST DRAW	16.2	1.0	
Client 6 Micro 47728-05 SINK DRINKING FOUNTAIN UPPER FLOOR SE WING FIRST DRAW	21.9	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARMICHAEL ES

Micro Log In **49291**
Total Samples 4
Date Sampled 10/2/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **7A** Micro 49291-01 **DRINKING FOUNTAIN C92 OUTSIDE FIRST DRAW**	**2.0**	1.0	
Client **7B** Micro 49291-02 **DRINKING FOUNTAIN C92 OUTSIDE SECOND DRAW**	**1.7**	1.0	
Client **7C** Micro 49291-03 **DRINKING FOUNTAIN C92 OUTSIDE 3RD DRAW**	**2.0**	1.0	
Client **11B** Micro 49291-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CARMICHAEL ES

Micro Log In **49291**
Total Samples 4
Date Sampled 10/2/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **7A** Micro 49291-01 **DRINKING FOUNTAIN C92 OUTSIDE FIRST DRAW**	**2.0**	1.0	
Client **7B** Micro 49291-02 **DRINKING FOUNTAIN C92 OUTSIDE SECOND DRAW**	**1.7**	1.0	
Client **7C** Micro 49291-03 **DRINKING FOUNTAIN C92 OUTSIDE 3RD DRAW**	**2.0**	1.0	
Client **11B** Micro 49291-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Carmichael

Lab Proj. ID: 9708C94

Sampled: 08/21/97
Received: 08/25/97
Analyzed: see below

Reported: 08/28/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708C94-08 Sample Desc : LIQUID,Carmichael 7				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.020**
Lab No: 9708C94-09 Sample Desc : LIQUID,Carmichael 8				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C94-10 Sample Desc : LIQUID,Carmichael 9				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C94-11 Sample Desc : LIQUID,Carmichael B				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Carmichael
Lab Proj. ID: 9708C94

Sampled: 08/21/97
Received: 08/25/97
Analyzed: see below
Reported: 08/28/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708C94-01 Sample Desc : LIQUID,Carmichael 1				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C94-02 Sample Desc : LIQUID,Carmichael 1 Duplicate				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C94-03 Sample Desc : LIQUID,Carmichael 2				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C94-04 Sample Desc : LIQUID,Carmichael 3				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0085**
Lab No: 9708C94-05 Sample Desc : LIQUID,Carmichael 4				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0077**
Lab No: 9708C94-06 Sample Desc : LIQUID,Carmichael 5				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C94-07 Sample Desc : LIQUID,Carmichael 6				
Lead	mg/L	08/28/97	0.0050	N.D.

D

alytes reported as N.D. were not present above the stated limit of detection.

EQUOIA ANALYTICAL - ELAP #1210

nella Flynn
roject Manager

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45443
Total Samples 16
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/18/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 58118A Micro 45443-16 MULTI DF ROOM 106 MULTI-PURPOSE ROOM 2ND DRAW			NOT ANALYZED

Technical Supervisor: 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45443
Total Samples 16
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/18/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 58116 Micro 45443-11 DRINKING FOUNTAIN ROOM 111 1ST DRAW	< 1.0	1	
Client 58116A Micro 45443-12 DRINKING FOUNTAIN ROOM 111 2ND DRAW			NOT ANALYZED
Client 58117 Micro 45443-13 MULTIPLE DF ROOM 105 MULTI - PURPOSE ROOM 1ST DRAW	< 1.0	1	
Client 58117A Micro 45443-14 MULTI DF ROOM 105 MULTI-PURPOSE ROOM 2ND DRAW			NOT ANALYZED
Client 58118 Micro 45443-15 MULTI DF ROOM 105 MULTI-PURPOSE ROOM 1ST DRAW	< 1.0	1	

Technical Supervisor: 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45443
Total Samples 16
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/18/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 58113A Micro 45443-06 DRINKING FOUNTAIN ROOM113 2ND DRAW			NOT ANALYZED
Client 58114 Micro 45443-07 DRINKING FOUNTAIN ROOM 116 1ST DRAW	1.2	1	
Client 58114A Micro 45443-08 DRINKING FOUNTAIN ROOM 116 2ND DRAW			NOT ANALYZED
Client 58115 Micro 45443-09 DRINKING FOUNTAIN ROOM112 1ST DRAW	3.7	1	
Client 58115A Micro 45443-10 DRINKING FOUNTAIN ROOM112 2ND DRAW			NOT ANALYZED

Technical Supervisor: 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45443
Total Samples 16
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/18/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 58111 Micro 45443-01 DRINKING FOUNTAIN ROOM 114 1ST DRAW	< 1.0	1	
Client 58111A Micro 45443-02 DRINKING FOUNTAIN ROOM 114 2ND DRAW			NOT ANALYZED
Client 58112 Micro 45443-03 DRINKING FOUNTAIN ROOM 115 1ST DRAW	1.5	1	
Client 58112A Micro 45443-04 DRINKING FOUNTAIN ROOM115 1ST DRAW			NOT ANALYZED
Client 58113 Micro 45443-05 DRINKING FOUNTAIN ROOM113 1ST DRAW	5.0	1	

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45444
Total Samples 26
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/18/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61452A Micro 45444-26 DRINKING FOUNTAIN KITCHEN 2ND FLOOR 2ND DRAW			NOT ANALYZED

Technical Supervisor: 6/23/97 Analyst: FR

Farid Rahezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45444
Total Samples 26
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61450 Micro 45444-21 DRINKING FOUNTAIN ROOM 202 1ST DRAW	< 1.0	1	
Client 61450A Micro 45444-22 DRINKING FOUNTAIN ROOM 202 2ND DRAW			NOT ANALYZED
Client 61451 Micro 45444-23 DRINKING FOUNTAIN ROOM 210 1ST DRAW	3.3	1	
Client 61451A Micro 45444-24 DRINKING FOUNTAIN ROOM 201 2ND DRAW			NOT ANALYZED
Client 61452 Micro 45444-25 DRINKING FOUNTAIN KITCHEN 2ND FLOOOR 1ST DRAW	< 1.0	1	

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (*Standard Methods for the Examination of Water and Wastewater*, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45444
Total Samples 26
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61498A Micro 45444-16 DRINKING FOUNTAIN ROOM 204 2ND DRAW			NOT ANALYZED
Client 61499 Micro 45444-17 DRINKING FOUNTAIN ROOM 205 1ST DRAW	< 1.0	1	
Client 61499A Micro 45444-18 DRINKING FOUNTAIN ROOM 205 2ND DRAW			NOT ANALYZED
Client 61490 Micro 45444-19 DRINKING FOUNTAIN ROOM 205 1ST DRAW	< 1.0	1	
Client 61490A Micro 45444-20 DRINKING FOUNTAIN ROOM 205 2ND DRAW			NOT ANALYZED

Technical Supervisor: 6/23/97 Analyst: FR

Farid Rahezamaceh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

FILE COPY

Page 3

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45444
Total Samples 26
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61496 Micro 45444-11 DRINKING FOUNTAIN ROM 212A MR. LU 1ST DRAW	1.6	1	
Client 61496A Micro 45444-12 DRINKING FOUNTAIN ROOM 212A MR. LU 2ND DRAW			NOT ANALYZED
Client 61497 Micro 45444-13 DRINKING FOUNTAIN ROOM 200 LIBRARY 1ST DRAW	< 1.0	1	
Client 61497A Micro 45444-14 DRINKING FOUNTAIN ROOM 200 LIBRARY 2ND DRAW			NOT ANALYZED
Client 61498 Micro 45444-15 DRINKING FOUNTAIN ROOM 204 1ST DRAW	< 1.0	1	

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45444
Total Samples 26
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61493A Micro 45444-06 DRINKING FOUNTAIN ROOM 213 2ND DRAW			NOT ANALYZED
Client 61494 Micro 45444-07 DRINKING FOUNTAIN ROOM 212 1ST DRAW	1.9	1	
Client 61494A Micro 45444-08 DRINKING FOUNTAIN ROOM 212 2ND DRAW			NOT ANALYZED
Client 61495 Micro 45444-09 DRINKING FOUNTAIN ROOM 211 1ST DRAW	< 1.0	1	
Client 61495A Micro 45444-10 DRINKING FOUNTAIN ROOM 211 2ND DRAW			NOT ANALYZED

Technical Supervisor: 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45444
Total Samples 26
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61491 Micro 45444-01 DRINKING FOUNTAIN ROOM 214 1ST DRAW	< 1.0	1	
Client 61491A Micro 45444-02 DRINKING FOUNTAIN ROOM 214 2ND DRAW			NOT ANALYZED
Client 61492 Micro 45444-03 DRINKING FOUNTAIN ROOM 215 1ST DRAW	< 1.0	1	
Client 61492A Micro 45444-04 DRINKING FOUNTAIN ROOM 215 2ND DRAW			NOT ANALYZED
Client 61493 Micro 45444-05 DRINKING FOUNTAIN ROOM 213 1ST DRAW	2.2	1	

Technical Supervisor: 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45445
Total Samples 42
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61597-21 Micro 45445-41 MULTI DF 105 1ST DRAW	< 1.0	1	
Client 61597-21A Micro 45445-42 MULTI DF 105 2ND DRAW			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1027. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45445
Total Samples 42
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61597-18A Micro 45445-36 DRINKING FOUNTAIN ROOM 115 2ND DRAW			NOT ANALYZED
Client 61597-19 Micro 45445-37 DRINKING FOUNTAIN ROOM 116 1ST DRAW	< 1.0	1	
Client 61597-19A Micro 45445-38 DRINKING FOUNTAIN ROOM 116 2ND DRAW			NOT ANALYZED
Client 61597-20 Micro 45445-39 DRINKING FOUNTAIN 106 CAFE 1ST DRAW	< 1.0	1	
Client 61597-20A Micro 45445-40 DRINKING FOUNTAIN 106 CAFE 2ND DRAW			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

FILE COPY

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45445
Total Samples 42
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61597-16 Micro 45445-31 DRINKING FOUNTAIN ROOM 113 1ST DRAW	8.6	1	
Client 61597-16A Micro 45445-32 DRINKING FOUNTAIN ROOM 113 2ND DRAW			NOT ANALYZED
Client 61597-17 Micro 45445-33 DRINKING FOUNTAIN ROOM 114 1ST DRAW	< 1.0	1	
Client 61597-17A Micro 45445-34 DRINKING FOUNTAIN ROOM 114 2ND DRAW			NOT ANALYZED
Client 61597-18 Micro 45445-35 DRINKING FOUNTAIN ROOM 115 1ST DRAW	2.1	1	

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

FILE COPY

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45445
Total Samples 42
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61597-13A Micro 45445-26 DRINKING FOUNTAIN KIT AREA 2ND FLOOR 2ND DRAW			NOT ANALYZED
Client 61597-14 Micro 45445-27 DRINKING FOUNTAIN ROOM 112 1ST DRAW	4.3	1	
Client 61597-14A Micro 45445-28 DRINKING FOUNTAIN ROOM 112 1ST DRAW			NOT ANALYZED
Client 61597-15 Micro 45445-29 DRINKING FOUNTAIN ROOM 111 1ST DRAW	< 1.0	1	
Client 61597-15A Micro 45445-30 DRINKING FOUNTAIN ROOM 111 2ND DRAW			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45445
Total Samples 42
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61597-11 Micro 45445-21 DRINKING FOUNTAIN ROOM 202 1ST DRAW	< 1.0	1	
Client 61597-11A Micro 45445-22 DRINKINF FOUNTAIN ROOM 202 2ND DRAW			NOT ANALYZED
Client 61597-12 Micro 45445-23 DRINKING FOUNTAIN ROOM 201 1ST DRAW	< 1.0	1	
Client 61597-12A Micro 45445-24 DRINKING FOUNTAIN ROOM 201 2ND DRAW			NOT ANALYZED
Client 61597-13 Micro 45445-25 DRINKING FOUNTAIN KIT AREA 2ND FLOOR 1ST DRAW	2.8	1	

Technical Supervisor: _____ 6/23/97 Analyst: FR
Farid Rameczadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1057. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 16th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

FILE NO.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45445
Total Samples 42
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61497-8A Micro 45445-16 DRINKING FOUNTAIN ROOM 204 2ND DRAW			NOT ANALYZED
Client 61497-9 Micro 45445-17 DRINKING FOUNTAIN ROOM 205 1ST DRAW	< 1.0	1	
Client 61497-9A Micro 45445-18 DRINKING FOUNTAIN ROOM 205 2ND DRAW			NOT ANALYZED
Client 61497-10 Micro 45445-19 DRINKING FOUNTAIN ROOM 203 1ST DRAW	< 1.0	1	
Client 61597-10A Micro 45445-20 DRINKING FOUNTAIN ROOM 203 2ND DRAW			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45445
Total Samples 42
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61497-6 Micro 45445-11 DRINKING FOUNTAIN ROOM 211 1ST DRAW	1.5	1	
Client 61497-6A Micro 45445-12 DRINKING FOUNTAIN ROOM 211 2ND DRAW			NOT ANALYZED
Client 61497-7 Micro 45445-13 DRINKING FOUNTAIN ROOM 200 1ST DRAW	2.2	1	
Client 61497-7A Micro 45445-14 DRINKING FOUNTAIN ROOM 200 1ST DRAW			NOT ANALYZED
Client 61497-8 Micro 45445-15 DRINKING FOUNTAIN ROOM 204 1ST DRAW	< 1.0	1	

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

FILE COPY

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45445
Total Samples 42
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61497-3A Micro 45445-06 DRINKING FOUNTAIN ROOM 212 2ND DRAW			NOT ANALYZED
Client 61497-4 Micro 45445-07 DRINKING FOUNTAIN ROOM 212 1ST DRAW	5.6	1	
Client 61497-4A Micro 45445-08 DRINKING FOUNTAIN ROOM 212 2ND DRAW			NOT ANALYZED
Client 61497-5 Micro 45445-09 DRINKING FOUNTAIN ROOM 212A 1ST DRAW	< 1.0	1	
Client 61497-5A Micro 45445-10 DRINKING FOUNTAIN ROOM 212A 2ND DRAW			NOT ANALYZED

Technical Supervisor: 6/23/97 Analyst: FR

Farid Rameznazdeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

FILE COPY

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CABRILLO ES
W.O. NO. WT97-357

Micro Log In 45445
Total Samples 42
Date Sampled 6/14/97
Date Received 6/16/97
Date Analyzed 6/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 61497-1 Micro 45445-01 DRINKING FOUNTAIN ROOM 214 1ST DRAW	< 1.0	1	
Client 61497-1A Micro 45445-02 DRINKING FOUNTAIN ROOM 214 2ND DRAW			NOT ANALYZED
Client 61497-2 Micro 45445-03 DRINKING FOUNTAIN ROOM 215 1ST DRAW	< 1.0	1	
Client 61497-2A Micro 45445-04 DRINKING FOUNTAIN ROOM 215 2ND DRAW			NOT ANALYZED
Client 61497-3 Micro 45445-05 DRINKING FOUNTAIN ROOM 213 1ST DRAW	1.8	1	

Technical Supervisor: F. Ramezanzadeh 6/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1057. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BURTON HS

Micro Log In **52058**
Total Samples 3
Date Sampled 1/14/98
Date Received 1/14/98
Date Analyzed 1/15/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **22A** Micro 52058-01 **SINK FAUCET ROOM 238 RESAMPLE**	< 1.0	1.0	
Client **22B** Micro 52058-02 **SINK FAUCET ROOM 238 RESAMPLE**	< 1.0	1.0	
Client **22C** Micro 52058-03 **SINK FAUCET ROOM 238 RESAMPLE**	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 1/15/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BURTON HS

Micro Log In **52166**
Total Samples 4
Date Sampled 1/17/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BURTON 22A** Micro 52166-01 SINK FAUCET 236	1.4	1.0	
Client **BURTON 22B** Micro 52166-02 SINK FAUCET 238	< 1.0	1.0	
Client **BURTON 22C** Micro 52166-03 SINK FAUCET 238	< 1.0	1.0	
Client **BURTON BLANK** Micro 52166-04 BLANK	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BURTON HS

Micro Log In **52058**
Total Samples 3
Date Sampled 1/14/98
Date Received 1/14/98
Date Analyzed 1/15/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 22A Micro 52058-01 SINK FAUCET ROOM 238 RESAMPLE	< 1.0	1.0	
Client 22B Micro 52058-02 SINK FAUCET ROOM 238 RESAMPLE	< 1.0	1.0	
Client 22C Micro 52058-03 SINK FAUCET ROOM 238 RESAMPLE	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 1/15/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
F & S BURTON HS

Micro Log In **49186**
Total Samples 13
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **30B** Micro 49186-11 **MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL, TENNIS COURT FIRST DRAW**	**103.3**	4.0	
Client **30C** Micro 49186-12 **MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL, TENNIS COURT FIRST DRAW**	**12.6**	1.0	
Client **BLANK** Micro 49186-13 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
F & S BURTON HS

Micro Log In **49186**
Total Samples 13
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **25C** Micro 49186-06 **SINK FAUCET SECOND FLOOR, ROOM 238 (#3) COOKING ROOM FIRST DRAW**	**10.4**	1.0	
Client **29A** Micro 49186-07 **SINK FAUCET SECOND FLOOR, ROOM 238 (#6) COOKING ROOM FIRST DRAW**	**< 1.0**	1.0	
Client **29B** Micro 49186-08 **SINK FAUCET SECOND FLOOR, ROOM 238 (#6) COOKING ROOM FIRST DRAW**	**< 1.0**	1.0	
Client **29C** Micro 49186-09 **SINK FAUCET SECOND FLOOR, ROOM 238 (#6) COOKING ROOM FIRST DRAW**	**1.7**	1.0	
Client **30A** Micro 49186-10 **MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL, TENNIS COURT FIRST DRAW**	**106.2**	4.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
F & S BURTON HS

Micro Log In **49186**
Total Samples 13
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **3A** Micro 49186-01 **DRINKING FOUNTAIN 2ND FLOOR, ROOM 204 FIRST DRAW**	**2.3**	1.0	
Client **3B** Micro 49186-02 **DRINKING FOUNTAIN 2ND FLOOR, ROOM 204 FIRST DRAW**	**1.4**	1.0	
Client **3C** Micro 49186-03 **DRINKING FOUNTAIN 2ND FLOOR, ROOM 204 FIRST DRAW**	**5.1**	1.0	
Client **25A** Micro 49186-04 **SINK FAUCET SECOND FLOOR, ROOM 238 (#3) COOKING ROOM FIRST DRAW**	**4.7**	1.0	
Client **25B** Micro 49186-05 **SINK FAUCET SECOND FLOOR, ROOM 238 (#3) COOKING ROOM FIRST DRAW**	**2.1**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMOUNT ES

Micro Log In **47846**
Total Samples 45
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **40** Micro 47846-41 **BLANK**	**<1.0**	1.0	
Client **41** Micro 47846-42 **DRINKING FOUNTAIN BLDG D LEFT OUTSIDE BELOW MID LEVEL "D"**	**<1.0**	1.0	
Client **42** Micro 47846-43 **DRINKING FOUNTAIN BLDG D RIGHT OUTSIDE BELOW MID LEVEL "D"**	**<1.0**	1.0	
Client **43** Micro 47846-44 **SINK FAUCET BLDG D RR SINK LEFT BELOW MID LEVEL "D"**	**2.0**	1.0	
Client **44** Micro 47846-45 **SINK FAUCET BLDG D RR SINK RIGHT BELOW MID LEVEL "D"**	**<1.0**	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMONT ES

Micro Log In **49248**
Total Samples 16
Date Sampled 10/6/97
Date Received 10/6/97
Date Analyzed 10/6/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **2A** Micro 49248-01 **SINK FAUCET** **BLDG. C, SINK NEAR ENTRANCE** **1ST**	**1.0**	1.0	
Client **2B** Micro 49248-02 **SINK FAUCET** **BLDG. C, SINK NEAR ENTRANCE** **2ND**	**< 1.0**	1.0	
Client **2C** Micro 49248-03 **SINK FAUCET** **BLDG. C, SINK NEAR ENTRANCE** **3RD**	**3.3**	1.0	
Client **4A** Micro 49248-04 **SINK FAUCET** **RIGHT SIDE RR, BLDG. C** **1ST**	**< 1.0**	1.0	
Client **4B** Micro 49248-05 **SINK FAUCET** **RIGHT SIDE RR, BLDG. C** **2ND**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMONT ES

Micro Log In **49248**
Total Samples 16
Date Sampled 10/6/97
Date Received 10/6/97
Date Analyzed 10/6/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **4C** Micro 49248-06 **SINK FAUCET** **RIGHT SIDE RR, BLDG. C** **3RD**	**3.2**	1.0	
Client **5A** Micro 49248-07 **SINK FAUCET** **LEFT SIDE RR, BLDG. C** **1ST**	**< 1.0**	1.0	
Client **5B** Micro 49248-08 **SINK FAUCET** **LEFT SIDE RR, BLDG. C** **2ND**	**< 1.0**	1.0	
Client **5C** Micro 49248-09 **SINK FAUCET** **LEFT SIDE RR, BLDG. C** **3RD**	**2.1**	1.0	
Client **14A** Micro 49248-10 **SINK FAUCET** **BLDG. D, RIGHT RR** **1ST**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMONT ES

Micro Log In **49248**
Total Samples **16**
Date Sampled **10/6/97**
Date Received **10/6/97**
Date Analyzed **10/6/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **14B** Micro 49248-11 SINK FAUCET BLDG. D, RIGHT RR 2ND	< 1.0	1.0	
Client **14C** Micro 49248-12 SINK FAUCET BLDG. D, RIGHT RR 3RD	< 1.0	1.0	
Client **15A** Micro 49248-13 BLDG. D, LEFT 1ST	< 1.0	1.0	
Client **15B** Micro 49248-14 BLDG. D, LEFT 2ND	< 1.0	1.0	
Client **15C** Micro 49248-15 BLDG. D, LEFT 3RD	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FAIRMONT ES

Micro Log In **49248**
Total Samples 16
Date Sampled 10/6/97
Date Received 10/6/97
Date Analyzed 10/6/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 45 Micro 49248-16 DRINKING FOUNTAIN DRINKING FOUNTAIN IN YARD	100.4	3.3	

Technical Supervisor: 10/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FILIPINO ED. CHILD CTR

Micro Log In **47739**
Total Samples 13
Date Sampled 8/16/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47739-01 DRINKING FOUNTAIN 1 FIRST DRAW	14.0	1.0	
Client 2 Micro 47739-02 DRINKING FOUNTAIN 2 FIRST DRAW	6.2	1.0	
Client 3 Micro 47739-03 DRINKING FOUNTAIN 3 FIRST DRAW	3.8	1.0	
Client 4 Micro 47739-04 DRINKING FOUNTAIN 4 FIRST DRAW	6.8	1.0	
Client 5 Micro 47739-05 DRINKING FOUNTAIN 5 FIRST DRAW	4.6	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FILIPINO ED. CHILD CTR

Micro Log In 47739
Total Samples 13
Date Sampled 8/16/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47739-06 DRINKING FOUNTAIN 6 FIRST DRAW	4.5	1.0	
Client 7 Micro 47739-07 DRINKING FOUNTAIN 7 FIRST DRAW	1.3	1.0	
Client 8 Micro 47739-08 SINK FAUCET KITCHEN FIRST DRAW	6.4	1.0	
Client 9 Micro 47739-09 DRINKING FOUNTAIN L FIRST DRAW	4.1	1.0	
Client 10 Micro 47739-10 SINK FAUCET STAFF KITCHEN FIRST DRAW	8.0	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FILIPINO ED. CHILD CTR

Micro Log In **47739**
Total Samples 13
Date Sampled 8/16/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: B Micro 47739-11 BLANK	< 1.0	1.0	
Client: 11 Micro 47739-12 DRINKING FOUNTAIN OUTSIDE FIRST DRAW	2.8	1.0	
Client: 12 Micro 47739-13 SPIKED	57.1	2.2	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FILIPINO

Micro Log In **49297**
Total Samples 4
Date Sampled 10/1/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **1A** Micro 49297-01 **SINK DRINKING FOUNTAIN ROOM 1 FIRST DRAW**	**3.9**	1.0	
Client **1B** Micro 49297-02 **SINK DRINKING FOUNTAIN ROOM 1 FIRST DRAW**	**5.0**	1.0	
Client **1C** Micro 49297-03 **SINK DRINKING FOUNTAIN ROOM 1 FIRST DRAW**	**4.5**	1.0	
Client **BLANK** Micro 49297-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/12/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALICE FONG YU

Micro Log In 66361
Total Samples 26
Date Sampled 3/18/99
Date Received 3/19/99
Date Analyzed 3/22/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: ALICE 1A Micro 66361-01 1ST DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	6	1	
Client: ALICE 1B Micro 66361-02 2ND DRAW, EXTERIOR COURTYARD MULTIPLE DRINKING FOUNTAIN	3	1	
Client: ALICE 2A Micro 66361-03 1ST DRAW, HALLWAY (3RD FLOOR) DRINKING FOUNTAIN	19	1	
Client: ALICE 2B Micro 66361-04 2ND DRAW, HALLWAY (3RD FLOOR) DRINKING FOUNTAIN	24	1	
Client: ALICE 3A Micro 66361-05 1ST DRAW, HALLWAY (3RD FLOOR) DRINKING FOUNTAIN	4	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/24/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALICE FONG YU

Micro Log In 66361
Total Samples 26
Date Sampled 3/18/99
Date Received 3/19/99
Date Analyzed 3/22/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: ALICE 3B Micro 66361-06 2ND DRAW, HALLWAY (3RD FLOOR) DRINKING FOUNTAIN	3	1	
Client: ALICE 4A Micro 66361-07 1ST DRAW, HALLWAY (2ND FLOOR) DRINKING FOUNTAIN	7	1	
Client: ALICE 4B Micro 66361-08 2ND DRAW, HALLWAY (2ND FLOOR) DRINKING FOUNTAIN	46	1	
Client: ALICE 5A Micro 66361-09 1ST DRAW, HALLWAY (2ND FLOOR) DRINKING FOUNTAIN	35	1	
Client: ALICE 5B Micro 66361-10 2ND DRAW, HALLWAY (2ND FLOOR) DRINKING FOUNTAIN	33	1	

Technical Supervisor: for Farid Ramazanzadeh, M.S. 3/24/99 Date Reported Analyst: AL

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALICE FONG YU

Micro Log In 66361
Total Samples 26
Date Sampled 3/18/99
Date Received 3/19/99
Date Analyzed 3/24/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: ALICE 6A Micro 66361-11 1ST DRAW, FACULTY LOUNGE SINK FAUCET	< 1	1	
Client: ALICE 6B Micro 66361-12 2ND DRAW, FACULTY LOUNGE SINK FAUCET	< 1	1	
Client: ALICE 7A Micro 66361-13 1ST DRAW, HALLWAY (1ST FLOOR) DRINKING FOUNTAIN	> 160	1	
Client: ALICE 7B Micro 66361-14 2ND DRAW, HALLWAY (1ST FLOOR) DRINKING FOUNTAIN	1	1	
Client: ALICE 8A Micro 66361-15 1ST DRAW, HALLWAY (1ST FLOOR) DRINKING FOUNTAIN	26	1	

Technical Supervisor: Hairfarid 3/24/99 Analyst: AL
for Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALICE FONG YU

Micro Log In 66361
Total Samples 26
Date Sampled 3/18/99
Date Received 3/19/99
Date Analyzed 3/24/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ALICE 8B Micro 66361-16 2ND DRAW, HALLWAY (1ST FLOOR) DRINKING FOUNTAIN	7	1	
Client ALICE 9A Micro 66361-17 1ST DRAW, CLASS 101 SINK DRINKING FOUNTAIN	< 1	1	
Client ALICE 9B Micro 66361-18 2ND DRAW, CLASS 101 SINK DRINKING FOUNTAIN	< 1	1	
Client ALICE 10A Micro 66361-19 1ST DRAW, CLASS 102 SINK DRINKING FOUNTAIN	< 1	1	
Client ALICE 10B Micro 66361-20 2ND DRAW, CLASS 102 SINK DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/24/99 Data Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALICE FONG YU

Micro Log In 66361
Total Samples 26
Date Sampled 3/18/99
Date Received 3/19/99
Date Analyzed 3/24/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: ALICE 11A Micro 66361-21 1ST DRAW, CLASS 103 SINK DRINKING FOUNTAIN	< 1	1	
Client: ALICE 11B Micro 66361-22 2ND DRAW, CLASS 103 SINK DRINKING FOUNTAIN	< 1	1	
Client: ALICE 12A Micro 66361-23 1ST DRAW, CLASS 104 SINK DRINKING FOUNTAIN	3	1	
Client: ALICE 12B Micro 66361-24 2ND DRAW, CLASS 104 SINK DRINKING FOUNTAIN	3	1	
Client: ALICE 13A Micro 66361-25 1ST DRAW, CLASS 105 SINK DRINKING FOUNTAIN	12	1	

Technical Supervisor: for Farid Rameza[illegible]zadeh, M.S. 3/24/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALICE FONG YU

Micro Log In 66361
Total Samples 26
Date Sampled 3/18/99
Date Received 3/19/99
Date Analyzed 3/24/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: ALICE 13B Micro 66361-26 2ND DRAW, CLASS 105 SINK DRINKING FOUNTAIN	1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/24/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ALICE FONG YU

Micro Log In 66361
Total Samples 26
Date Sampled 3/18/99
Date Received 3/19/99
Date Analyzed 3/24/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: ALICE 13B Micro 66361-26 2ND DRAW, CLASS 105 SINK DRINKING FOUNTAIN	1	1	
Client: ALICE BL1 Micro 66361-27 BLANK	< 1	1	
Client: ALICE BL2 Micro 66361-28 BLANK	< 1	1	

Technical Supervisor: Hamid Rameshzadeh for 3/25/99 Analyst: TT

Farid Rameshzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FLYNN ES

Micro Log In **47524**
Total Samples 12
Date Sampled 8/17/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **FLYNN 1** Micro 47524-01 **MULTIPLE DRINKING FOUNTAIN** **190 (HALL) / FIRST DRAW**	**1.8**	1.0	
Client **FLYNN 2** Micro 47524-02 **WATER-COOLED DRINKING FOUNTAIN** **190 (HALL) / FIRST DRAW**	**1.9**	1.0	
Client **FLYNN 3** Micro 47524-03 **SINK DRINKING FOUNTAIN** **108 B / FIRST DRAW**	**2.5**	1.0	
Client **FLYNN 4** Micro 47524-04 **SINK FAUCET** **108 B / FIRST DRAW**	**10.3**	1.0	
Client **FLYNN 5** Micro 47524-05 **SINK DRINKING FOUNTAIN** **202 / FIRST DRAW**	**2.6**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FLYNN ES

Micro Log In **47524**
Total Samples 12
Date Sampled 8/17/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **FLYNN 6** Micro 47524-06 **SINK FAUCET** **211 / FIRST DRAW**	**29.9**	1.0	
Client **FLYNN 7** Micro 47524-07 **MULTIPLE DRINKING FOUNTAIN** **230 (HALL) / FIRST DRAW**	**2.6**	1.0	
Client **FLYNN 8** Micro 47524-08 **WATER-COOLED DRINKING FOUNTAIN** **230 (HALL) / FIRST DRAW**	**1.7**	1.0	
Client **FLYNN 9** Micro 47524-09 **WATER-COOLED DRINKING FOUNTAIN** **350 (HALL) / FIRST DRAW**	**2.7**	1.0	
Client **FLYNN 10** Micro 47524-10 **MULTIPLE DRINKING FOUNTAIN** **350 (HALL) / FIRST DRAW**	**13.6**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FLYNN ES

Micro Log In **47524**
Total Samples 12
Date Sampled 8/17/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **FLYNN 11** Micro 47524-11 **MULTIPLE DRINKING FOUNTAIN 350 (HALL) / FIRST DRAW**	**22.0**	1.0	
Client **FLYNN 12** Micro 47524-12 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Leonard Flynn ES

Lab Proj. ID: 9710493

Sampled: 09/26/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710493-01 Sample Desc : **LIQUID,Flynn 10-A**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710493-02 Sample Desc : **LIQUID,Flynn 10-B**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710493-03 Sample Desc : **LIQUID,Flynn 10-C**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710493-04 Sample Desc : **LIQUID,Flynn 6-A**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710493-05 Sample Desc : **LIQUID,Flynn 6-B**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710493-06 Sample Desc : **LIQUID,Flynn 6-C**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.011**
Lab No: 9710493-07 Sample Desc : **LIQUID,Flynn 6-C (duplicate)**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.010**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Leonard Flynn ES

Lab Proj. ID: 9710493

Sampled: 09/26/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710493-08				
Sample Desc : **LIQUID,Flynn Blank**				
Lead	mg/L	10/13/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANCISCO MS

Micro Log In **47414**
Total Samples 15
Date Sampled 8/12/97
Date Received 8/15/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47414-01 DRINKING FOUNTAIN 2ND FLOOR MAIN BLDG FIRST DRAW	2.8	1.0	
Client 2 Micro 47414-02 DRINKING FOUNTAIN 2ND FLOOR MAIN BLDG (NO SAMPLE)			SAMPLE NOT RECEIVED
Client 3 Micro 47414-03 DRINKING FOUNTAIN 1ST FLOOR MAIN BLDG FIRST DRAW	9.2	1.0	
Client 4 Micro 47414-04 SINK FAUCET 1ST FLOOR MAIN BLDG RM. 115 FIRST DRAW	10.0	1.0	
Client 5 Micro 47414-05 DRINKING FOUNTAIN 1ST FLOOR MAIN BLDG FIRST DRAW	8.8	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANCISCO MS

Micro Log In 47414
Total Samples 15
Date Sampled 8/12/97
Date Received 8/15/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47414-06 DRINKING FOUNTAIN 2ND FLOOR SHOP WING FIRST DRAW	7.0	1.0	
Client 7 Micro 47414-07 DRINKING FOUNTAIN 2ND FLOOR SHOP WING FIRST DRAW	<1.0	1.0	
Client 8 Micro 47414-08 DRINKING FOUNTAIN 3RD FLOOR EAST WING (NO SAMPLE)			SAMPLE NOT RECEIVED
Client 9 Micro 47414-09 DRINKING FOUNTAIN 3RD FLOOR EAST WING FIRST DRAW	<1.0	1.0	
Client 10 Micro 47414-10 MULTIPLE DRINKING FOUNTAIN LOWER YARD FIRST DRAW	<1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANCISCO MS

Micro Log In **47414**
Total Samples 15
Date Sampled 8/12/97
Date Received 8/15/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47414-11 MULTIPLE DRINKING FOUNTAIN UPPER YARD FIRST DRAW	3.2	1.0	
Client 12 Micro 47414-12 DRINKING FOUNTAIN BASEMENT GYM ANNEX FIRST DRAW	2.4	1.0	
Client 13 Micro 47414-13 DRINKING FOUNTAIN BASEMENT GYM ANNEX RM. 400 FIRST DRAW	8.6	1.0	
Client 14 Micro 47414-14 DRINKING FOUNTAIN GYM ANNEX FIRST FLOOR FIRST DRAW	34.0	1.0	
Client 15 Micro 47414-15 BLANK	<1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BENJAMIN FRANKLIN JH

Micro Log In **47692**
Total Samples 17
Date Sampled 8/22/97
Date Received 8/22/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47692-01 **BLANK**	< 1.0	1.0	
Client 2 Micro 47692-02 **DRINKING FOUNTAIN** **BASEMENT FLOOR - FRONT OF ROOM 008** **FIRST DRAW**	< 1.0	1.0	
Client 3 Micro 47692-03 **DRINKING FOUNTAIN** **BASEMENT FLOOR - FRONT OF ROOM 014** **FIRST DRAW**	1.4	1.0	
Client 4 Micro 47692-04 **DRINKING FOUNTAIN** **FIRST FLOOR - FRONT OF ROOM 102** **FIRST DRAW**	1.2	1.0	
Client 5 Micro 47692-05 **DRINKING FOUNTAIN** **BASEMENT FLOOR - GIRLS' GYM - ROOM 030** **FIRST DRAW**	< 1.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BENJAMIN FRANKLIN JH

Micro Log In **47692**
Total Samples **17**
Date Sampled **8/22/97**
Date Received **8/22/97**
Date Analyzed **8/25/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47692-06 MULTIPLE DRINKING FOUNTAIN BASEMENT FLOOR - CAFETERIA - 040 FIRST DRAW	< 1.0	1.0	
Client 7 Micro 47692-07 SINK FAUCET BASEMENT LEVEL KITCHEN - ROOM 041 FIRST DRAW	4.4	1.0	
Client 8 Micro 47692-08 SINK FAUCET BASEMENT LEVEL KITCHEN - ROOM 041 FIRST DRAW	1.7	1.0	
Client 9 Micro 47692-09 SINK FAUCET BASEMENT LEVEL KITCHEN - ROOM 041 FIRST DRAW	2.5	1.0	
Client 10 Micro 47692-10 SINK FAUCET BASEMENT LEVEL KITCHEN - ROOM 041 FIRST DRAW	8.1	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BENJAMIN FRANKLIN JH

Micro Log In **47692**
Total Samples 17
Date Sampled 8/22/97
Date Received 8/22/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47692-11 DRINKING FOUNTAIN FIRST FLOOR - FRONT OF ROOM 113 FIRST DRAW	1.5	1.0	
Client 12 Micro 47692-12 SINK FAUCET FIRST FLOOR ROOM 119A TEACHERS' LOUNGE FIRST DRAW	3.0	1.0	
Client 13 Micro 47692-13 DRINKING FOUNTAIN SECOND FLOOR FRONT OF ROOM 206 FIRST DRAW	2.0	1.0	
Client 14 Micro 47692-14 DRINKING FOUNTAIN SECOND FLOOR FRONT OF ROOM 214A FIRST DRAW	6.7	1.0	
Client 15 Micro 47692-15 DRINKING FOUNTAIN SECOND FLOOR HALLWAY OUTSIDE ROOM 240 FIRST DRAW	6.0	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BENJAMIN FRANKLIN JH

Micro Log In **47692**
Total Samples 17
Date Sampled 8/22/97
Date Received 8/22/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47692-16 DRINKING FOUNTAIN FIRST FLOOR ANNEX BOY'S' GYM - ROOM 002 FIRST DRAW	3.8	1.0	
Client 17 Micro 47692-17 MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL - PLAYGROUND OUTSIDE RM. 016 FIRST DRAW	13.0	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BENJAMIN FRANKLIN JH

Micro Log In **49187**
Total Samples 4
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **17A** Micro 49187-01 **MULTIPLE DRINKING FOUNTAIN OUTSIDE ROOM 16, PLAYGROUND FIRST DRAW**	**1.1**	1.0	
Client **17B** Micro 49187-02 **MULTIPLE DRINKING FOUNTAIN OUTSIDE ROOM 16, PLAYGROUND FIRST DRAW**	**1.2**	1.0	
Client **17C** Micro 49187-03 **MULTIPLE DRINKING FOUNTAIN OUTSIDE ROOM 16, PLAYGROUND FIRST DRAW**	**< 1.0**	1.0	
Client **BLANK** Micro 49187-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S. F. U. S. D.
GALILEO HS

Micro Log In **48361**
Total Samples 11
Date Sampled 9/9/97
Date Received 9/10/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **GALILEO 1** Micro 48361-01 WATER FAUCET C96 FIRST DRAW	5.5	1.0	
Client **GALILEO 2** Micro 48361-02 WATER FAUCET C93 FIRST DRAW	3.4	1.0	
Client **GALILEO 3** Micro 48361-03 WATER FAUCET C93 FIRST DRAW	3.9	1.0	
Client **GALILEO 4** Micro 48361-04 WATER FAUCET C90 FIRST DRAW	1.0	1.0	
Client **GALILEO 5** Micro 48361-05 WATER FAUCET 760 FIRST DRAW	1.4	1.0	

Technical Supervisor: 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S. F. U. S. D.
GALILEO HS

Micro Log In **48361**
Total Samples 11
Date Sampled 9/9/97
Date Received 9/10/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **GALILEO 6** Micro 48361-06 **WATER FAUCET** **C93** **FIRST DRAW**	**1.1**	1.0	
Client **GALILEO 7** Micro 48361-07 **WATER FAUCET** **C91** **FIRST DRAW**	**1.7**	1.0	
Client **GALILEO 8** Micro 48361-08 **WATER FAUCET** **C92** **FIRST DRAW**	**1.2**	1.0	
Client **GALILEO 9** Micro 48361-09 **WATER FAUCET** **C94** **FIRST DRAW**	**1.1**	1.0	
Client **GALILEO 10** Micro 48361-10 **222A** **FIRST DRAW**	**4.4**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S. F. U. S. D.
GALILEO HS

Micro Log In **48361**
Total Samples 11
Date Sampled 9/9/97
Date Received 9/10/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: GALILEO 11 Micro: 48361-11 BLANK	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GARFIELD ES

Micro Log In **47730**
Total Samples 24
Date Sampled 8/17/97
Date Received 8/25/97
Date Analyzed 8/29/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 2 Micro 47730-01 DRINKING FOUNTAIN ROOM 403 FIRST DRAW	28.6	1.0	
Client 3 Micro 47730-02 DRINKING FOUNTAIN ROOM 405 FIRST DRAW	20.1	1.0	
Client 4 Micro 47730-03 DRINKING FOUNTAIN ROOM 408 FIRST DRAW	22.0	1.0	
Client 5 Micro 47730-04 DRINKING FOUNTAIN ROOM 409 FIRST DRAW	44.8	1.0	
Client 6 Micro 47730-05 DRINKING FOUNTAIN ROOM 411 FIRST DRAW	104	3.3	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GARFIELD ES

Micro Log In **47730**
Total Samples 24
Date Sampled 8/17/97
Date Received 8/25/97
Date Analyzed 8/29/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: B Micro 47730-06 BLANK	<1.0	1.0	
Client: 25 Micro 47730-07 SPIKED	56.7	2.0	
Client: 7 Micro 47730-08 DRINKING FOUNTAIN ROOM 315 FIRST DRAW	60.0	2.2	
Client: 8 Micro 47730-09 DRINKING FOUNTAIN ROOM 314 FIRST DRAW	1203	20.0	
Client: 9 Micro 47730-10 DRINKING FOUNTAIN ROOM 316 FIRST DRAW	25.5	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GARFIELD ES

Micro Log In **47730**
Total Samples 24
Date Sampled 8/17/97
Date Received 8/25/97
Date Analyzed 8/29/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **10** Micro 47730-11 **DRINKING FOUNTAIN ROOM 313 FIRST DRAW**	**26.5**	1.0	
Client **11** Micro 47730-12 **DRINKING FOUNTAIN ROOM 305 FIRST DRAW**	**82.7**	2.9	
Client **12** Micro 47730-13 **DRINKING FOUNTAIN ROOM 302 FIRST DRAW**	**20.2**	1.0	
Client **13** Micro 47730-14 **DRINKING FOUNTAIN ROOM 303 FIRST DRAW**	**75.5**	2.5	
Client **15** Micro 47730-15 **DRINKING FOUNTAIN ROOM 220 FIRST DRAW**	**24.6**	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GARFIELD ES

Micro Log In **47730**
Total Samples 24
Date Sampled 8/17/97
Date Received 8/25/97
Date Analyzed 8/29/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47730-16 DRINKING FOUNTAIN CLASSROOM 104 FIRST DRAW	84.6	2.9	
Client 17 Micro 47730-17 DRINKING FOUNTAIN CLASSROOM 105 FIRST DRAW	108	4.0	
Client 18 Micro 47730-18 SINK FAUCET KITCHEN ROOM 103 FIRST DRAW	9.7	1.0	
Client 19 Micro 47730-19 DRINKING FOUNTAIN 201 FIRST DRAW	68.0	2.5	
Client 20 Micro 47730-20 DRINKING FOUNTAIN 202 FIRST DRAW	34.1	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GARFIELD ES

Micro Log In **47730**
Total Samples 24
Date Sampled 8/17/97
Date Received 8/25/97
Date Analyzed 8/29/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 21 Micro 47730-21 DRINKING FOUNTAIN 206 FIRST DRAW	66.4	2.2	
Client 22 Micro 47730-22 DRINKING FOUNTAIN 205 FIRST DRAW	57.1	2.0	
Client 23 Micro 47730-23 DRINKING FOUNTAIN 203 FIRST DRAW	41.5	1.0	
Client 24 Micro 47730-24 DRINKING FOUNTAIN 222 FIRST DRAW	77.6	3.3	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
A.P. GIANNINI JH

Micro Log In **47642**
Total Samples 29
Date Sampled 8/21/97
Date Received 8/21/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47642-01 **BLANK**	< 1.0	1.0	
Client 2 Micro 47642-02 **DRINKING FOUNTAIN** **FIRST FLOOR OUTSIDE RM 116** **FIRST DRAW**	< 1.0	1.0	
Client 3 Micro 47642-03 **SINK FAUCET** **FIRST FLOOR COOKING AREA ROOM 108** **FIRST DRAW**	9.0	1.0	
Client 4 Micro 47642-04 **DRINKING FOUNTAIN** **FIRST FLOOR OUTSIDE ROOM 101** **FIRST DRAW**	3.4	1.0	
Client 5 Micro 47642-05 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 040** **FIRST DRAW**	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
A.P. GIANNINI JH

Micro Log In **47642**
Total Samples 29
Date Sampled 8/21/97
Date Received 8/21/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47642-06 DRINKING FOUNTAIN BASEMENT FLOOR ROOM 040 FIRST DRAW	35.8	1.0	
Client 7 Micro 47642-07 DRINKING FOUNTAIN BASEMENT FLOOR ROOM 041 FIRST DRAW	6.7	1.0	
Client 9 Micro 47642-08 DRINKING FOUNTAIN FIRST FLOOR GYM ROOM 141 FIRST DRAW	< 1.0	1.0	
Client 10 Micro 47642-09 DRINKING FOUNTAIN SECOND FLOOR OUTSIDE ROOM 201 FIRST DRAW	2.4	1.0	
Client 11 Micro 47642-10 DRINKING FOUNTAIN SECOND FLOOR OUTSIDE ROOM 220 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
A.P. GIANNINI JH

Micro Log In 47642
Total Samples 29
Date Sampled 8/21/97
Date Received 8/21/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 12 Micro 47642-11 DRINKING FOUNTAIN SECOND FLOOR OUTSIDE ROOM 216 FIRST DRAW	1.0	1.0	
Client 13 Micro 47642-12 DRINKING FOUNTAIN SECOND FLOOR CAFETERIA WALL ROOM 227 FIRST DRAW	< 1.0	1.0	
Client 14 Micro 47642-13 DRINKING FOUNTAIN SECOND FLOOR CAFETERIA WALL ROOM 227 FIRST DRAW	< 1.0	1.0	
Client 15 Micro 47642-14 SINK FAUCET SECOND FLOOR CAFETERIA KITCHEN BACK OF ROOM 227 FIRST DRAW	1.5	1.0	
Client 16 Micro 47642-15 SINK FAUCET SECOND FLOOR CAFETERIA KITCHEN BACK OF ROOM 227 FIRST DRAW	14.1	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
A.P. GIANNINI JH

Micro Log In 47642
Total Samples 29
Date Sampled 8/21/97
Date Received 8/21/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 17 Micro 47642-16 SINK FAUCET SECOND FLOOR CAFETERIA KITCHEN BACK OF ROOM 227 FIRST DRAW	< 1.0	1.0	
Client 18 Micro 47642-17 SINK FAUCET SECOND FLOOR CAFETERIA KITCHEN BACK OF ROOM 227 FIRST DRAW	< 1.0	1.0	
Client 19 Micro 47642-18 DRINKING FOUNTAIN SECOND FLOOR HALLWAY OUTSIDE AUDITORIUM FIRST DRAW	< 1.0	1.0	
Client 20 Micro 47642-19 DRINKING FOUNTAIN SECOND FLOOR HALLWAY OUTSIDE AUDITORIUM FIRST DRAW	< 1.0	1.0	
Client 21 Micro 47642-20 SINK FAUCET SECOND FLOOR ROOM 230 - COOKING AREA FIRST DRAW	2.3	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
A.P. GIANNINI JH

Micro Log In **47642**
Total Samples 29
Date Sampled 8/21/97
Date Received 8/21/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 22 Micro 47642-21 SINK FAUCET SECOND FLOOR ROOM 230 - COOKING AREA FIRST DRAW	3.1	1.0	
Client 23 Micro 47642-22 SINK FAUCET SECOND FLOOR ROOM 230 - COOKING AREA FIRST DRAW	15.1	1.0	
Client 24 Micro 47642-23 SINK FAUCET SECOND FLOOR ROOM 230 - COOKING AREA FIRST DRAW	2.0	1.0	
Client 25 Micro 47642-24 SINK FAUCET SECOND FLOOR ROOM 230 - COOKING AREA FIRST DRAW	4.6	1.0	
Client 26 Micro 47642-25 SINK FAUCET SECOND FLOOR ROOM 230 - COOKING AREA FIRST DRAW	7.6	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
A.P. GIANNINI JH

Micro Log In **47642**
Total Samples 29
Date Sampled 8/21/97
Date Received 8/21/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 27 Micro 47642-26 DRINKING FOUNTAIN THIRD FLOOR OUTSIDE ROOM 303 FIRST DRAW	27.8	1.0	
Client 28 Micro 47642-27 DRINKING FOUNTAIN THIRD FLOOR PLAY HALLWAY OUTSIDE ROOM 301 FIRST DRAW	< 1.0	1.0	
Client 29 Micro 47642-28 MULTIPLE DRINKING FOUNTAIN THIRD FLOOR PLAYGROUND OUTSIDE - WEST FIRST DRAW	2.9	1.0	
Client 30 Micro 47642-29 SINK FAUCET FIRST FLOOR ROOM 119 - WORK ROOM FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
A.P. GIANNINI JH

Micro Log In **48317**
Total Samples 3
Date Sampled 9/9/97
Date Received 9/9/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 31 Micro 48317-01 SINK FOUNTAIN SECOND FLOOR COOKING AREA ROOM 230 FIRST DRAW	2.1	1.0	
Client 32 Micro 48317-02 SINK FOUNTAIN SECOND FLOOR COOKING AREA ROOM 230 FIRST DRAW	2.1	1.0	
Client 33 Micro 48317-03 SINK FOUNTAIN SECOND FLOOR COOKING AREA ROOM 230 FIRST DRAW	1.6	1.0	

Technical Supervisor: F. Ramezanzadeh 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
A.P.G. GIANNINI

Micro Log In **50807**
Total Samples 6
Date Sampled 11/19/97
Date Received 11/19/97
Date Analyzed 11/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **16A** Micro 50807-01 **SINK FAUCET** **CAFETERIA KITCHEN BACK OF 227** **FIRST DRAW**	< **1.0**	1.0	
Client **16B** Micro 50807-02 **SINK FAUCET** **CAFETERIA KITCHEN BACK OF 227** **FIRST DRAW**	< **1.0**	1.0	
Client **16C** Micro 50807-03 **SINK FAUCET** **CAFETERIA KITCHEN BACK OF 227** **FIRST DRAW**	**1.1**	1.0	
Client **23A** Micro 50807-04 **SINK FAUCET** **ROOM 230 - COOKING AREA** **FIRST DRAW**	**2.6**	1.0	
Client **23B** Micro 50807-05 **SINK FAUCET** **ROOM 230 - COOKING AREA** **FIRST DRAW**	**1.1**	1.0	

Technical Supervisor: _____ 11/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
A.P.G. GIANNINI

Micro Log In **50807**
Total Samples 6
Date Sampled 11/19/97
Date Received 11/19/97
Date Analyzed 11/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 23C Micro: 50807-06 SINK FAUCET ROOM 230 - COOKING AREA FIRST DRAW	1.7	1.0	

Technical Supervisor: F. Ramezanzadeh 11/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GLEN PARK ES

Micro Log In **47413**
Total Samples 6
Date Sampled 8/12/97
Date Received 8/15/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47413-01 DRINKING FOUNTAIN OUTSIDE YARD EAST SIDE FIRST DRAW	11.5	1.0	
Client 2 Micro 47413-02 DRINKING FOUNTAIN OUTSIDE YARD WEST SIDE FIRST DRAW	6.3	1.0	
Client 3 Micro 47413-03 DRINKING FOUNTAIN CORRIDOR C-90 FIRST FLOOR FIRST DRAW	4.0	1.0	
Client 4 Micro 47413-04 DRINKING FOUNTAIN CORRIDOR C-90 SECOND FLOOR FIRST DRAW	7.8	1.0	
Client 5 Micro 47413-05 SINK FAUCET STAFF LUNCH ROOM - KITCHEN FIRST DRAW	8.3	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GLEN PARK ES

Micro Log In **47413**
Total Samples 6
Date Sampled 8/12/97
Date Received 8/15/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 6 Micro: 47413-06 BLANK	< 1.0	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GLEN PARK ES

Micro Log In 52536
Total Samples 3
Date Sampled 1/31/98
Date Received 2/2/98
Date Analyzed 2/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client GLEN PARK 1A Micro 52536-01 MULTIPLE DF YARD NE RESAMPLE	1.1	1.0	
Client GLEN PARK 1B Micro 52536-02 MULTIPLE DF YARD NE RESAMPLE	< 1.0	1.0	
Client GLEN PARK 1C Micro 52536-03 MULTIPLE DF YARD NE RESAMPLE	1.4	1.0	

Technical Supervisor: F. Ramezanzadeh 2/4/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD	Client Proj. ID: Golden Gate Annex	Sampled: 08/19/97
1551 Newcomb Ave., Rm. 103		Received: 08/22/97
San Francisco, CA 94124	Lab Proj. ID: 9708B64	Analyzed: see below
Attention: Bruce Giannini		Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B64-01 Sample Desc : LIQUID,Golden Gate Annex 1				
Lead	mg/L	08/26/97	0.0050	N.D. B
Lab No: 9708B64-02 Sample Desc : LIQUID,Golden Gate Annex 2				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B64-03 Sample Desc : LIQUID,Golden Gate Annex 2 Dup				
Lead	mg/L	08/26/97	0.0050	N.D. D
Lab No: 9708B64-04 Sample Desc : LIQUID,Golden Gate Annex 3				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B64-05 Sample Desc : LIQUID,Golden Gate Annex 4				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B64-06 Sample Desc : LIQUID,Golden Gate Annex 5				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B64-07 Sample Desc : LIQUID,Golden Gate Annex 6				
Lead	mg/L	08/26/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD	Client Proj. ID: Golden Gate Annex	Sampled: 08/19/97
1551 Newcomb Ave., Rm. 103		Received: 08/22/97
San Francisco, CA 94124	Lab Proj. ID: 9708B64	Analyzed: see below
Attention: Bruce Giannini		Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B64-08				
Sample Desc : LIQUID,Golden Gate Annex 7				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B64-09				
Sample Desc : LIQUID,Golden Gate Annex 8				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B64-10				
Sample Desc : LIQUID,Golden Gate Annex 9				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.028**

S

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Golden Gate Elementary
Lab Proj. ID: 9708B62

Sampled: 08/18/97
Received: 08/22/97
Analyzed: see below
Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B62-01 Sample Desc : LIQUID,Golden Gate 1				
Lead	mg/L	08/26/97	0.0050	N.D. B
Lab No: 9708B62-02 Sample Desc : LIQUID,Golden Gate 2				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B62-03 Sample Desc : LIQUID,Golden Gate 2 Duplicate				
Lead	mg/L	08/26/97	0.0050	N.D. D
Lab No: 9708B62-04 Sample Desc : LIQUID,Golden Gate 4				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-05 Sample Desc : LIQUID,Golden Gate 4 Duplicate				
Lead	mg/L	08/25/97	0.0050	N.D. D
Lab No: 9708B62-06 Sample Desc : LIQUID,Golden Gate 5				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-07 Sample Desc : LIQUID,Golden Gate 5 Duplicate				
Lead	mg/L	08/25/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Golden Gate Elementary

Lab Proj. ID: 9708B62

Sampled: 08/18/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B62-08 Sample Desc : **LIQUID,Golden Gate 6**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-09 Sample Desc : **LIQUID,Golden Gate 7**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-10 Sample Desc : **LIQUID,Golden Gate 8**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-11 Sample Desc : **LIQUID,Golden Gate 9**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-12 Sample Desc : **LIQUID,Golden Gate 10**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-13 Sample Desc : **LIQUID,Golden Gate 11**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B62-14 Sample Desc : **LIQUID,Golden Gate 12**				
Lead	mg/L	08/26/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Golden Gate Elementary

Lab Proj. ID: 9708B62

Sampled: 08/18/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B62-15 Sample Desc : LIQUID,Golden Gate 13				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0050**
Lab No: 9708B62-16 Sample Desc : LIQUID,Golden Gate 14				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B62-17 Sample Desc : LIQUID,Golden Gate 15				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B62-18 Sample Desc : LIQUID,Golden Gate 16				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B62-19 Sample Desc : LIQUID,Golden Gate 17				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0063**
Lab No: 9708B62-20 Sample Desc : LIQUID,Golden Gate 18				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B62-21 Sample Desc : LIQUID,Golden Gate 19				
Lead	mg/L	08/26/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Golden Gate Elementary
Lab Proj. ID: 9708B62

Sampled: 08/18/97
Received: 08/22/97
Analyzed: see below
Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B62-22 Sample Desc : LIQUID,Golden Gate 20				
Lead	mg/L	08/26/97	0.0050	0.020
Lab No: 9708B62-23 Sample Desc : LIQUID,Golden Gate 21				
Lead	mg/L	08/26/97	0.0050	0.0062
Lab No: 9708B62-24 Sample Desc : LIQUID,Golden Gate 22				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-25 Sample Desc : LIQUID,Golden Gate 23				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-26 Sample Desc : LIQUID,Golden Gate 24				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-27 Sample Desc : LIQUID,Golden Gate 25				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B62-28 Sample Desc : LIQUID,Golden Gate 26				
Lead	mg/L	08/25/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD	Client Proj. ID: Golden Gate Elementary	Sampled: 08/18/97
1551 Newcomb Ave., Rm. 103		Received: 08/22/97
San Francisco, CA 94124	Lab Proj. ID: 9708B62	Analyzed: see below
Attention: Bruce Giannini		Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B62-29				
Sample Desc : LIQUID,Golden Gate 27				
Lead	mg/L	08/25/97	0.0050	0.020
Lab No: 9708B62-30				
Sample Desc : LIQUID,Golden Gate 28				
Lead	mg/L	08/26/97	0.0050	0.017

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GOLDEN GATE ES

Micro Log In **48029**
Total Samples 4
Date Sampled 8/30/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 29 Micro 48029-01 **BLANK**	< 1.0	1.0	
Client ~~30~~ 27A Micro 48029-02 **MULTIPLE DRINKING FOUNTAIN MAIN LEVEL (1ST FLOOR) PLAYGROUND SOUTH SIDE FIRST DRAW**	1.9	1.0	
Client ~~31~~ 27B Micro 48029-03 **MULTIPLE DRINKING FOUNTAIN MAIN LEVEL (1ST FLOOR) PLAYGROUND SOUTH SIDE SECOND DRAW**	< 1.0	1.0	
Client ~~32~~ 27C Micro 48029-04 **MULTIPLE DRINKING FOUNTAIN MAIN LEVEL (1ST FLOOR) PLAYGROUND SOUTH SIDE THIRD DRAW**	1.9	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples **56**
Date Sampled **8/14/97**
Date Received **8/14/97**
Date Analyzed **8/17/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47364-01 BLANK	< 1.0	1.0	
Client 2 Micro 47364-02 SINK FAUCET FIRST FLOOR RM. 105A FIRST DRAW	18.6	1.0	
Client 3 Micro 47364-03 SINK FAUCET FIRST FLOOR KITCHEN RM. 105F FIRST DRAW	6.3	1.0	
Client 4 Micro 47364-04 SINK FAUCET FIRST FLOOR RM. 105 FIRST DRAW	9.8	1.0	
Client 5 Micro 47364-05 SINK DRINKING FOUNTAIN FIRST FLOOR RM. 105 FIRST DRAW	3.7	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47364-06 SINK FAUCET FIRST FLOOR RM. 106 FIRST DRAW	28.0	1.0	
Client 7 Micro 47364-07 SINK DRINKING FOUNTAIN FIRST FLOOR RM. 106 FIRST DRAW	9.5	1.0	
Client 8 Micro 47364-08 SINK FAUCET FIRST FLOOR RM. 107 FIRST DRAW	8.9	1.0	
Client 9 Micro 47364-09 SINK DRINKING FOUNTAIN RM. 107 FIRST DRAW	15.5	1.0	
Client 10 Micro 47364-10 SINK FAUCET FIRST FLOOR KITCHEN RM. 112 FIRST DRAW	14.7	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In 47364
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47364-11 SINK FAUCET FIRST FLOOR CAFETERIA RM. 113 FIRST DRAW	19.2	1.0	
Client 12 Micro 47364-12 SINK FAUCET FIRST FLOOR CAFETERIA RM. 113 FIRST DRAW	15.9	1.0	
Client 13 Micro 47364-13 SINK FAUCET FIRST FLOOR DISH WASHING RM. 113 FIRST DRAW	2.8	1.0	
Client 14 Micro 47364-14 DRINKING FOUNTAIN FIRST FLOOR COURT YARD FIRST DRAW	11.5	1.0	
Client 15 Micro 47364-15 SINK FAUCET FIRST FLOOR RM. 104 FIRST DRAW	2.9	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **16** Micro 47364-16 **SINK DRINKING FOUNTAIN FIRST FLOOR RM. 104 FIRST DRAW**	**2.6**	1.0	
Client **17** Micro 47364-17 **SINK FAUCET FIRST FLOOR RM. 103 FIRST DRAW**	**22.1**	1.0	
Client **18** Micro 47364-18 **SINK DRINKING FOUNTAIN RM. 103 FIRST DRAW**	**5.4**	1.0	
Client **19** Micro 47364-19 **SINK FAUCET FIRST FLOOR RM. 102 FIRST DRAW**	**51.5**	2.0	
Client **20** Micro 47364-20 **SINK DRINKING FOUNTAIN FIRST FLOOR RM. 102 FIRST DRAW**	**10.8**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 21 Micro 47364-21 DRINKING FOUNTAIN HALLWAY - OUTSIDE RM. 103 FIRST DRAW	12.9	1.0	
Client 22 Micro 47364-22 SINK FAUCET FIRST FLOOR RM. 101 FIRST DRAW	40.6	1.0	
Client 23 Micro 47364-23 SINK DRINKING FOUNTAIN FIRST FLOOR RM. 101 FIRST DRAW	4.6	1.0	
Client 24 Micro 47364-24 DRINKING FOUNTAIN FIRST FLOOR COURT YARD - OUTSIDE RM. 105 FIRST DRAW	7.0	1.0	
Client 25 Micro 47364-25 DRINKING FOUNTAIN SECOND FLOOR RM. 212 FIRST DRAW	10.1	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **26** Micro 47364-26 **MULTIPLE DRINKING FOUNTAIN SECOND FLOOR PLAYGROUND AREA FIRST DRAW**	**2.5**	1.0	
Client **28** Micro 47364-27 **SINK FAUCET SECOND FLOOR RM. 210 FIRST DRAW**	**5.2**	1.0	
Client **29** Micro 47364-28 **SINK DRINKING FOUNTAIN SECOND FLOOR RM. 210 FIRST DRAW**	**4.0**	1.0	
Client **30** Micro 47364-29 **SINK FAUCET SECOND FLOOR RM. 209 FIRST DRAW**	**28.4**	1.0	
Client **31** Micro 47364-30 **SINK DRINKING FOUNTAIN SECOND FLOOR RM. 209 FIRST DRAW**	**21.1**	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/17/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 32 Micro 47364-31 SINK FAUCET SECOND FLOOR RM. 208 FIRST DRAW	12.5	1.0	
Client 33 Micro 47364-32 SINK DRINKING FOUNTAIN SECOND FLOOR RM. 208 FIRST DRAW	4.6	1.0	
Client 34 Micro 47364-33 SINK FAUCET SECOND FLOOR RM. 207 FIRST DRAW	19.4	1.0	
Client 35 Micro 47364-34 SINK DRINKING FOUNTAIN SECOND FLOOR RM. 207 FIRST DRAW	569	20.0	
Client 36 Micro 47364-35 SINK FAUCET SECOND FLOOR RM. 205 FIRST DRAW	11.0	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/17/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **37** Micro 47364-36 **SINK DRINKING FOUNTAIN** **SECOND FLOOR RM. 205** **FIRST DRAW**	**33.5**	1.0	
Client **38** Micro 47364-37 **SINK FAUCET** **SECOND FLOOR RM. 204** **FIRST DRAW**	**19.8**	1.0	
Client **39** Micro 47364-38 **SINK DRINKING FOUNTAIN** **SECOND FLOOR RM. 204** **FIRST DRAW**	**3.6**	1.0	
Client **40** Micro 47364-39 **DRINKING FOUNTAIN** **SECOND FLOOR HALLWAY** **FIRST DRAW**	**7.7**	1.0	
Client **41** Micro 47364-40 **SINK FAUCET** **SECOND FLOOR RM. 203** **FIRST DRAW**	**49.6**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/18/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 42 Micro 47364-41 SINK DRINKING FOUNTAIN SECOND FLOOR RM. 203 FIRST DRAW	< 1.0	1.0	
Client 43 Micro 47364-42 SINK FAUCET SECOND FLOOR RM. 202 FIRST DRAW	5.0	1.0	
Client 44 Micro 47364-43 SINK DRINKING FOUNTAIN SECOND FLOOR RM. 202 FIRST DRAW	< 1.0	1.0	
Client 45 Micro 47364-44 SINK FAUCET SECOND FLOOR RM. 201 FIRST DRAW	5.1	1.0	
Client 46 Micro 47364-45 SINK DRINKING FOUNTAIN SECOND FLOOR RM. 201 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 47 Micro 47364-46 SINK FAUCET SECOND FLOOR RM. 215 FIRST DRAW	13.4	1.0	
Client 48 Micro 47364-47 SINK DRINKING FOUNTAIN SECOND FLOOR RM. 215 FIRST DRAW	3.6	1.0	
Client 49 Micro 47364-48 SINK FAUCET SECOND FLOOR RM. 214 FIRST DRAW	4.1	1.0	
Client 50 Micro 47364-49 SINK DRINKING FOUNTAIN SECOND FLOOR RM. 214 FIRST DRAW	1.1	1.0	
Client 51 Micro 47364-50 SINK FAUCET SECOND FLOOR RM. 213 FIRST DRAW	14.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 52 Micro 47364-51 SINK DRINKING FOUNTAIN SECOND FLOOR RM. 213 FIRST DRAW	9.2	1.0	
Client 53 Micro 47364-52 SINK FAUCET SECOND FLOOR RM. 212 FIRST DRAW	61.0	2.2	
Client 54 Micro 47364-53 SINK DRINKING FOUNTAIN SECOND FLOOR RM. 212 FIRST DRAW	6.0	1.0	
Client 55 Micro 47364-54 DRINKING FOUNTAIN SOUTHWEST YARD - LOWER FIRST DRAW	8.4	1.0	
Client 56 Micro 47364-55 DRINKING FOUNTAIN SOUTHWEST YARD FIRST DRAW	8.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES / CC

Micro Log In **47364**
Total Samples 56
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 57 Micro 47364-56 **DRINKING FOUNTAIN SOUTHWEST YARD - UPPER FIRST DRAW**	**14.0**	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 58 Micro 48008-01 SINK FAUCET FIRST FLOOR - ROOM 105A FIRST DRAW	9.5	1.0	
Client 59 Micro 48008-02 SINK FAUCET FIRST FLOOR - ROOM 105A SECOND DRAW	6.0	1.0	
Client 60 Micro 48008-03 SINK FAUCET FIRST FLOOR - ROOM 105A THIRD DRAW	8.9	1.0	
Client 61 Micro 48008-04 SINK FAUCET FIRST FLOOR - ROOM 106 FIRST DRAW	3.1	1.0	
Client 62 Micro 48008-05 SINK FAUCET FIRST FLOOR - ROOM 106 SECOND DRAW	2.3	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 63 Micro 48008-06 SINK FAUCET FIRST FLOOR - ROOM 106 THIRD DRAW	4.9	1.0	
Client 64 Micro 48008-07 SINK DRINKING FOUNTAIN FIRST FLOOR - RM 107 FIRST DRAW	2.4	1.0	
Client 65 Micro 48008-08 SINK DRINKING FOUNTAIN FIRST FLOOR - ROOM 107 SECOND DRAW	2.7	1.0	
Client 66 Micro 48008-09 SINK DRINKING FOUNTAIN FIRST FLOOR - ROOM 107 THIRD DRAW	5.3	1.0	
Client 67 Micro 48008-10 SINK FAUCET FIRST FLOOR - ROOM 112 (KITCHEN) FIRST DRAW	1.6	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 68 Micro 48008-11 SINK FAUCET FIRST FLOOR - ROOM 112 (KITCHEN) SECOND DRAW	1.6	1.0	
Client 69 Micro 48008-12 SINK FAUCET FIRST FLOOR - ROOM 112 (KITCHEN) THIRD DRAW	5.3	1.0	
Client 70 Micro 48008-13 SINK FAUCET FIRST FLOOR - ROOM 113 (CAFETERIA) FIRST DRAW	2.1	1.0	
Client 71 Micro 48008-14 SINK FAUCET FIRST FLOOR - ROOM 113 (CAFETERIA) SECOND DRAW	1.3	1.0	
Client 72 Micro 48008-15 SINK FAUCET FIRST FLOOR - ROOM 113 (CAFETERIA) THIRD DRAW	3.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 73 Micro 48008-16 SINK FAUCET FIRST FLOOR - ROOM 113 FIRST DRAW	1.4	1.0	
Client 74 Micro 48008-17 SINK FAUCET FIRST FLOOR - ROOM 113 SECOND DRAW	1.7	1.0	
Client 75 Micro 48008-18 SINK FAUCET FIRST FLOOR - ROOM 113 THIRD DRAW	1.8	1.0	
Client 76 Micro 48008-19 SINK FAUCET FIRST FLOOR - ROOM 103 FIRST FLOOR	1.6	1.0	
Client 77 Micro 48008-20 SINK FAUCET FIRST FLOOR - ROOM 103 SECOND DRAW	4.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 78 Micro 48008-21 SINK FAUCET FIRST FLOOR - ROOM 103 THIRD DRAW	13.5	1.0	
Client 79 Micro 48008-22 SINK FAUCET FIRST FLOOR - ROOM 102 FIRST DRAW	1.2	1.0	
Client 80 Micro 48008-23 SINK FAUCET FIRST FLOOR - ROOM 102 SECOND DRAW	3.8	1.0	
Client 81 Micro 48008-24 SINK FAUCET FIRST FLOOR - ROOM 102 THIRD DRAW	2.4	1.0	
Client 82 Micro 48008-25 SINK FAUCET FIRST FLOOR - ROOM 101 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 83 Micro 48008-26 SINK FAUCET FIRST FLOOR - ROOM 101 SECOND DRAW	< 1.0	1.0	
Client 84 Micro 48008-27 SINK FAUCET FIRST FLOOR - ROOM 101 THIRD DRAW	< 1.0	1.0	
Client 85 Micro 48008-28 SINK FAUCET SECOND FLOOR - ROOM 209 FIRST DRAW	1.5	1.0	
Client 86 Micro 48008-29 SINK FAUCET SECOND FLOOR - ROOM 209 SECOND DRAW	< 1.0	1.0	
Client 87 Micro 48008-30 SINK FAUCET SECOND FLOOR - ROOM 209 THIRD DRAW	3.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 88 Micro 48008-31 SINK DRINKING FOUNTAIN SECOND FLOOR - ROOM 209 FIRST DRAW	1.1	1.0	
Client 89 Micro 48008-32 SINK DRINKING FOUNTAIN SECOND FLOOR - ROOM 209 SECOND DRAW	< 1.0	1.0	
Client 90 Micro 48008-33 SINK DRINKING FOUNTAIN SECOND FLOOR - ROOM 209 THIRD DRAW	7.3	1.0	
Client 91 Micro 48008-34 SINK DRINKING FOUNTAIN SECOND FLOOR - ROOM 207 FIRST DRAW	2.7	1.0	
Client 92 Micro 48008-35 SINK DRINKING FOUNTAIN SECOND FLOOR - ROOM 207 SECOND DRAW	2.3	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 93 Micro 48008-36 SINK DRINKING FOUNTAIN SECOND FLOOR - ROOM 207 THIRD DRAW	2.5	1.0	
Client 94 Micro 48008-37 SINK DRINKING FOUNTAIN SECOND FLOOR - ROOM 205 FIRST DRAW	6.7	1.0	
Client 95 Micro 48008-38 SINK DRINKING FOUNTAIN SECOND FLOOR - ROOM 205 SECOND DRAW	9.4	1.0	
Client 96 Micro 48008-39 SINK DRINKING FOUNTAIN SECOND FLOOR - ROOM 205 THIRD DRAW	15.1	1.0	
Client 97 Micro 48008-40 SINK FAUCET SECOND FLOOR - ROOM 203 FIRST DRAW	1.5	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 98 Micro 48008-41 SINK FAUCET SECOND FLOOR - ROOM 203 SECOND DRAW	< 1.0	1.0	
Client 99 Micro 48008-42 SINK FAUCET SECOND FLOOR - ROOM 203 THIRD DRAW	1.4	1.0	
Client 100 Micro 48008-43 SINK FAUCET SECOND FLOOR - ROOM 212 FIRST DRAW	1.5	1.0	
Client 101 Micro 48008-44 SINK FAUCET SECOND FLOOR - ROOM 212 SECOND DRAW	25.8	1.0	
Client 102 Micro 48008-45 SINK FAUCET SECOND FLOOR - ROOM 212 THIRD DRAW	3.9	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN ES

Micro Log In **48008**
Total Samples 46
Date Sampled 8/29/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 103 Micro 48008-46 BLANK	< 1.0	1.0	

Technical Supervisor: 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN CC

Micro Log In **52170**
Total Samples 23
Date Sampled 1/18/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **GRATTAN 47A** Micro 52170-01 SINK DF 115	4.6	1.0	
Client **GRATTAN 47B** Micro 52170-02 SINK DF 115	3.2	1.0	
Client **GRATTAN 47C** Micro 52170-03 SINK DF 115	12.1	1.0	
Client **GRATTAN 51A** Micro 52170-04 SINK DF 113	6.9	1.0	
Client **GRATTAN 51B** Micro 52170-05 SINK DF 113	5.8	1.0	

Technical Supervisor: 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN CC

Micro Log In **52170**
Total Samples 23
Date Sampled 1/18/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **GRATTAN 51C** Micro 52170-06 SINK DF 113	**14.3**	1.0	
Client **GRATTAN 32A** Micro 52170-07 SINK DF 208	**3.1**	1.0	
Client **GRATTAN 32B** Micro 52170-08 SINK DF 208	**2.1**	1.0	
Client **GRATTAN 32C** Micro 52170-09 SINK DF 208	**6.9**	1.0	
Client **GRATTAN 34A** Micro 52170-10 SINK FAUCET 207	**9.2**	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN CC

Micro Log In **52170**
Total Samples 23
Date Sampled 1/18/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **GRATTAN 34B** Micro 52170-11 SINK FAUCET 207	17.9	1.0	
Client **GRATTAN 34C** Micro 52170-12 SINK FAUCET 207	12.6	1.0	
Client **GRATTAN 38A** Micro 52170-13 SINK DF 204	4.0	1.0	
Client **GRATTAN 38B** Micro 52170-14 SINK DF 204	5.4	1.0	
Client **GRATTAN 38C** Micro 52170-15 SINK DF 204	11.4	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN CC

Micro Log In **52170**
Total Samples 23
Date Sampled 1/18/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **GRATTAN 14A** Micro 52170-16 DRINKING FOUNTAIN COURTYARD	4.0	1.0	
Client **GRATTAN 14B** Micro 52170-17 DRINKING FOUNTAIN COURTYARD	6.1	1.0	
Client **GRATTAN 14C** Micro 52170-18 DRINKING FOUNTAIN COURTYARD	14.3	1.0	
Client **GRATTAN 57A** Micro 52170-19 OUTSIDE EAST	5.0	1.0	
Client **GRATTAN 57B** Micro 52170-20 OUTSIDE EAST	3.9	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GRATTAN CC

Micro Log In **52170**
Total Samples 23
Date Sampled 1/18/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: GRATTAN 57C Micro 52170-21 OUTSIDE EAST	2.8	1.0	
Client: GRATTAN BLANK 1 Micro 52170-22 BLANK 1	< 1.0	1.0	
Client: GRATTAN BLANK 2 Micro 52170-23 BLANK 2	< 1.0	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GUADALUPE ES

Micro Log In 47740
Total Samples 19
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47740-01 SINK FAUCET 1ST LEVEL KITCHEN FIRST DRAW	1.9	1.0	
Client 2 Micro 47740-02 DRINKING FOUNTAIN 1ST LEVEL HALL FIRST DRAW	5.6	1.0	
Client 3 Micro 47740-03 SINK FAUCET 1ST LEVEL CLASSROOM 100 FIRST DRAW	1.4	1.0	
Client 4 Micro 47740-04 SINK FAUCET 1ST LEVEL CLASSROOM 101 FIRST DRAW	2.2	1.0	
Client 5 Micro 47740-05 SINK FAUCET 1ST LEVEL CLASSROOM 102 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GUADALUPE ES

Micro Log In **47740**
Total Samples 19
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47740-06 SINK FAUCET 1ST LEVEL CLASSROOM 103 FIRST DRAW	6.5	1.0	
Client 7 Micro 47740-07 DRINKING FOUNTAIN 1ST LEVEL HALL FIRST DRAW	< 1.0	1.0	
Client 8 Micro 47740-08 SINK FAUCET 1ST LEVEL OFFICE FIRST DRAW	6.6	1.0	
Client 9 Micro 47740-09 DRINKING FOUNTAIN 2ND LEVEL HALL FIRST DRAW	< 1.0	1.0	
Client 10 Micro 47740-10 SINK FAUCET 2ND FLOOR TEACHERS' LOUNGE FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GUADALUPE ES

Micro Log In **47740**
Total Samples 19
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **11** Micro 47740-11 **SINK FAUCET** **2ND FLOOR CLASSROOM 9** **FIRST DRAW**	**2.3**	1.0	
Client **12** Micro 47740-12 **SINK FAUCET** **2ND FLOOR CLASSROOM 8** **FIRST DRAW**	**4.3**	1.0	
Client **13** Micro 47740-13 **SINK FAUCET** **2ND FLOOR CLASSROOM 6** **FIRST DRAW**	**< 1.0**	1.0	
Client **B** Micro 47740-14 **BLANK**	**< 1.0**	1.0	
Client **14** Micro 47740-15 **MULTIPLE DRINKING FOUNTAIN** **GROUND FLOOR NW FOUNTAIN** **FIRST DRAW**	**1.1**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GUADALUPE ES

Micro Log In **47740**
Total Samples 19
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 15 Micro 47740-16 MULTIPLE DRINKING FOUNTAIN SW FOUNTAIN FIRST DRAW	11.1	1.0	
Client 16 Micro 47740-17 SINK FAUCET BUNGALOW #2 FIRST DRAW	5.3	1.0	
Client 17 Micro 47740-18 SINK FAUCET BUNGALOW #1 FIRST DRAW	2.0	1.0	
Client 18 Micro 47740-19 SPIKED	54.3	2.2	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **48092**
Total Samples 37
Date Sampled 8/26/97
Date Received 9/2/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 1** Micro 48092-01 **SINK FAUCET** **ROOM 015** **FIRST DRAW**	**1.8**	1.0	
Client **BRET HARTE 2** Micro 48092-02 **SINK FAUCET** **ROOM 017A** **FIRST DRAW**	**18.7**	1.0	
Client **BRET HARTE 3** Micro 48092-03 **SINK FAUCET** **ROOM 107** **FIRST DRAW**	**10.9**	1.0	
Client **BRET HARTE 4** Micro 48092-04 **SINK FAUCET** **ROOM 109** **FIRST DRAW**	**4.2**	1.0	
Client **BRET HARTE 5** Micro 48092-05 **SINK FAUCET** **ROOM 111** **FIRST DRAW**	**8.4**	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **48092**
Total Samples 37
Date Sampled 8/26/97
Date Received 9/2/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 6** Micro 48092-06 SINK FAUCET ROOM 113 FIRST DRAW	3.9	1.0	
Client **BRET HARTE 7** Micro 48092-07 SINK FAUCET ROOM 115 FIRST DRAW	42.5	1.0	
Client **BRET HARTE 8** Micro 48092-08 SINK FAUCET ROOM 114 FIRST DRAW	9.6	1.0	
Client **BRET HARTE 9** Micro 48092-09 SINK FAUCET ROOM 112 FIRST DRAW	2.3	1.0	
Client **BRET HARTE 10** Micro 48092-10 DRINKING FOUNTAIN HALL " C90 " FIRST DRAW	2.5	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **48092**
Total Samples 37
Date Sampled 8/26/97
Date Received 9/2/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 11** Micro 48092-11 **DRINKING FOUNTAIN HALL " C91 " FIRST DRAW**	**4.9**	1.0	
Client **BRET HARTE 12** Micro 48092-12 **SINK FAUCET ROOM 101 FIRST DRAW**	**2.5**	1.0	
Client **BRET HARTE 13** Micro 48092-13 **DRINKING FOUNTAIN ROOM 204 FIRST DRAW**	**10.3**	1.0	
Client **BRET HARTE 14** Micro 48092-14 **SINK FAUCET ROOM 205 FIRST DRAW**	**3.6**	1.0	
Client **BRET HARTE 15** Micro 48092-15 **DRINKING FOUNTAIN ROOM 207 FIRST DRAW**	**9.8**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **48092**
Total Samples 37
Date Sampled 8/26/97
Date Received 9/2/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 16** Micro 48092-16 SINK FAUCET ROOM 206 FIRST DRAW	3.7	1.0	
Client **BRET HARTE 17** Micro 48092-17 DRINKING FOUNTAIN ROOM 209 FIRST DRAW	11.3	1.0	
Client **BRET HARTE 18** Micro 48092-18 SINK FAUCET ROOM 208 FIRST DRAW	4.7	1.0	
Client **BRET HARTE 19** Micro 48092-19 SINK FAUCET ROOM 210 FIRST DRAW	6.6	1.0	
Client **BRET HARTE 20** Micro 48092-20 SINK FAUCET ROOM 211 FIRST DRAW	5.5	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **48092**
Total Samples 37
Date Sampled 8/26/97
Date Received 9/2/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 21** Micro 48092-21 **MULTIPLE DRINKING FOUNTAIN ROOM 210 EXTERIOR FIRST DRAW**	**23.9**	1.0	
Client **BRET HARTE 22** Micro 48092-22 **SINK DRINKING FOUNTAIN ROOM 001A FIRST DRAW**	**3.2**	1.0	
Client **BRET HARTE 23** Micro 48092-23 **SINK DRINKING FOUNTAIN ROOM 002A FIRST DRAW**	**5.2**	1.0	
Client **BRET HARTE 24** Micro 48092-24 **SINK FAUCET ROOM 004A FIRST DRAW**	**5.9**	1.0	
Client **BRET HARTE 25** Micro 48092-25 **SINK DRINKING FOUNTAIN ROOM 003A FIRST DRAW**	**4.4**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **48092**
Total Samples 37
Date Sampled 8/26/97
Date Received 9/2/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 26** Micro 48092-26 **DRINKING FOUNTAIN HALL "C94" FIRST DRAW**	**12.7**	1.0	
Client **BRET HARTE 27** Micro 48092-27 **SINK FAUCET ROOM 005A FIRST DRAW**	**16.2**	1.0	
Client **BRET HARTE 28** Micro 48092-28 **SINK DRINKING FOUNTAIN ROOM 006A FIRST DRAW**	**7.8**	1.0	
Client **BRET HARTE 30** Micro 48092-29 **SINK DRINKING FOUNTAIN ROOM 008A FIRST DRAW**	**10.0**	1.0	
Client **BRET HARTE 31** Micro 48092-30 **MULTIPLE DRINKING FOUNTAIN PLAY AREA "C96" FIRST DRAW**	**25.6**	1.0	

Technical Supervisor: F Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **48092**
Total Samples 37
Date Sampled 8/26/97
Date Received 9/2/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 32** Micro 48092-31 **SINK FAUCET ROOM 001B FIRST DRAW**	**76.7**	2.9	
Client **BRET HARTE 33** Micro 48092-32 **SINK FAUCET ROOM 005B FIRST DRAW**	**104**	4.0	
Client **BRET HARTE 34** Micro 48092-33 **SINK FAUCET ROOM 002B FIRST DRAW**	**16.9**	1.0	
Client **BRET HARTE 35** Micro 48092-34 **SINK FAUCET ROOM 003B FIRST DRAW**	**34.9**	1.0	
Client **BRET HARTE 36** Micro 48092-35 **SINK FAUCET ROOM 004B FIRST DRAW**	**110**	4.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **48092**
Total Samples 37
Date Sampled 8/26/97
Date Received 9/2/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: **BRET HARTE BL** Micro 48092-36 **BLANK**	< 1.0	1.0	
Client: **BRET HARTE 29** Micro 48092-37 **ROOM 007A** **(SAMPLE NOT LISTED ON CHAIN-OF-CUSTODY FORM; DESCRIPTION ENTERED FROM BOTTLE LABEL)**	13.6	1.0	

Technical Supervisor: F Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **47522**
Total Samples 12
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 1** Micro 47522-01 **SINK FAUCET ROOM 115**			SAMPLE NOT RECEIVED
Client **BRET HARTE 2** Micro 47522-02 **DRINKING FOUNTAIN HALLWAY**	**5.8**	1.0	
Client **BRET HARTE 3** Micro 47522-03 **DRINKING FOUNTAIN HALL**	**7.9**	1.0	
Client **BRET HARTE 4** Micro 47522-04 **SINK FAUCET ROOM 101 "LUNCH"**	**2.7**	1.0	
Client **BRET HARTE 5** Micro 47522-05 **SINK FAUCET ROOM 205**	**2.5**	1.0	

Technical Supervisor: 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **47522**
Total Samples 12
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: **BRET HARTE 6** Micro 47522-06 **DRINKING FOUNTAIN ROOM 207**	**10.9**	1.0	
Client: **BRET HARTE 7** Micro 47522-07 **MULTIPLE DRINKING FOUNTAIN ROOM 210 EXTERIOR**	**31.0**	1.0	
Client: **BRET HARTE 8** Micro 47522-08 **MULTIPLE DRINKING FOUNTAIN PLAY AREA**	**29.9**	1.0	
Client: **BRET HARTE 9** Micro 47522-09 **SINK FAUCET ROOM 001**	**143**	5.0	
Client: **BRET HARTE 10** Micro 47522-10 **SINK FAUCET ROOM 002**	**15.2**	1.0	

Technical Supervisor: F Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE

Micro Log In **47522**
Total Samples 12
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 11** Micro 47522-11 **SINK FAUCET ROOM 003**	**56.4**	2.0	
Client **BRET HARTE BL** Micro 47522-12 **BLANK**	**<1.0**	1.0	

Technical Supervisor: _____ 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hart ES

Lab Proj. ID: 9710472

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710472-01 Sample Desc : **LIQUID,Harte 2-A**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-02 Sample Desc : **LIQUID,Harte 2-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-03 Sample Desc : **LIQUID,Harte 2-C**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-04 Sample Desc : **LIQUID,Harte 7-A**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-05 Sample Desc : **LIQUID,Harte 7-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-06 Sample Desc : **LIQUID,Harte 7-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.015**
Lab No: 9710472-07 Sample Desc : **LIQUID,Harte 7-D**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.095**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hart ES

Lab Proj. ID: 9710472

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710472-08 Sample Desc : **LIQUID,Harte 26-A**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-09 Sample Desc : **LIQUID,Harte 26-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-10 Sample Desc : **LIQUID,Harte 26-B (duplicate)**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-11 Sample Desc : **LIQUID,Harte 26-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0050**
Lab No: 9710472-12 Sample Desc : **LIQUID,Harte 27-A**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-13 Sample Desc : **LIQUID,Harte 27-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-14 Sample Desc : **LIQUID,Harte 27-C**				
Lead	mg/L	10/10/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hart ES

Lab Proj. ID: 9710472

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710472-15 Sample Desc : **LIQUID,Harte 31-A**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0060**
Lab No: 9710472-16 Sample Desc : **LIQUID,Harte 31-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-17 Sample Desc : **LIQUID,Harte 31-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.031**
Lab No: 9710472-18 Sample Desc : **LIQUID,Harte 32-A**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0070**
Lab No: 9710472-19 Sample Desc : **LIQUID,Harte 32-B**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0051**
Lab No: 9710472-20 Sample Desc : **LIQUID,Harte 32-B (duplicate)**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0051**
Lab No: 9710472-21 Sample Desc : **LIQUID,Harte 32-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.013**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hart ES

Lab Proj. ID: 9710472

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710472-22 Sample Desc : **LIQUID,Harte 34-A**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-23 Sample Desc : **LIQUID,Harte 34-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-24 Sample Desc : **LIQUID,Harte 34-C**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-25 Sample Desc : **LIQUID,Harte 35-A**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-26 Sample Desc : **LIQUID,Harte 35-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-27 Sample Desc : **LIQUID,Harte 35-C**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-28 Sample Desc : **LIQUID,Harte 36-A**				
Lead	mg/L	10/10/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hart ES

Lab Proj. ID: 9710472

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710472-29 Sample Desc : **LIQUID,Harte 36-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-30 Sample Desc : **LIQUID,Harte 36-B (duplicate)**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710472-31 Sample Desc : **LIQUID,Harte 36-C**				
Lead	mg/L	10/10/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hart ES

Lab Proj. ID: 9710472

Sampled: 10/10/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710472-32				
Sample Desc : **LIQUID,Harte Blank**				
Lead	mg/L	10/10/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
BRET HARTE ES

Micro Log In **52165**
Total Samples 4
Date Sampled 1/17/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **BRET HARTE 21A** Micro 52165-01 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND OUTSIDE 210**	**5.0**	1.0	
Client **BRET HARTE 21B** Micro 52165-02 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND OUTSIDE 210**	**10.1**	1.0	
Client **BRET HARTE 21C** Micro 52165-03 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND OUTSIDE 210**	**21.8**	1.0	
Client **BRET HARTE BLANK** Micro 52165-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HILLCREST ES

Micro Log In 47783
Total Samples 10
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client HILLCREST #1 Micro 47783-01 DRINKING FOUNTAIN HALLWAY C90 FIRST DRAW	10.6	1.0	
Client HILLCREST #2 Micro 47783-02 SINK FAUCET TEACHERS LOUNGE FIRST DRAW	2.6	1.0	
Client HILLCREST #3 Micro 47783-03 DRINKING FOUNTAIN HALLWAY C94 FIRST DRAW	7.0	1.0	
Client HILLCREST #4 Micro 47783-04 MULTIPLE DRINKING FOUNTAIN EXT. YARD FIRST DRAW	4.4	1.0	
Client HILLCREST #5 Micro 47783-05 DRINKING FOUNTAIN HALLWAY C92 FIRST DRAW	9.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HILLCREST ES

Micro Log In **47783**
Total Samples **10**
Date Sampled **8/23/97**
Date Received **8/25/97**
Date Analyzed **8/25/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **HILLCREST #6** Micro 47783-06 **MULTIPLE DRINKING FOUNTAIN EXT. YARD FIRST DRAW**	**58.5**	2.2	
Client **HILLCREST #7** Micro 47783-07 **DRINKING FOUNTAIN 2ND FL HALLWAY FIRST DRAW**	**18.6**	1.0	
Client **HILLCREST #8** Micro 47783-08 **DRINKING FOUNTAIN 2ND FL HALLWAY FIRST DRAW**	**9.3**	1.0	
Client **HILLCREST #9** Micro 47783-09 **MULTIPLE DRINKING FOUNTAIN EXT. YARD FIRST DRAW**	**33.3**	1.0	
Client **HILLCREST #10** Micro 47783-10 **BLANK**	**1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hillcrest ES

Lab Proj. ID: 9710494

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710494-01 Sample Desc : **LIQUID,Hillcrest 6-A**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710494-02 Sample Desc : **LIQUID,Hillcrest 6-B**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710494-03 Sample Desc : **LIQUID,Hillcrest 6-C**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710494-04 Sample Desc : **LIQUID,Hillcrest 7-A**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710494-05 Sample Desc : **LIQUID,Hillcrest 7-B**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710494-06 Sample Desc : **LIQUID,Hillcrest 7-C**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.0060**
Lab No: 9710494-07 Sample Desc : **LIQUID,Hillcrest 7-C (duplicate)**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.0060**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
104 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hillcrest ES
Lab Proj. ID: 9710494

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below
Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710494-08				
Sample Desc : LIQUID,Hillcrest Blank				
Lead	mg/L	10/13/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hilltop
Lab Proj. ID: 9708D10

Sampled: 08/25/97
Received: 08/25/97
Analyzed: see below
Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D10-01 Sample Desc : **LIQUID,Hilltop 1**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D10-02 Sample Desc : **LIQUID,Hilltop 1 Duplicate**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D10-03 Sample Desc : **LIQUID,Hilltop 2**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D10-04 Sample Desc : **LIQUID,Hilltop 3 Blank**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D10-05 Sample Desc : **LIQUID,Hilltop 4**				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0078**
Lab No: 9708D10-06 Sample Desc : **LIQUID,Hilltop 5**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D10-07 Sample Desc : **LIQUID,Hilltop 6**				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hilltop
Lab Proj. ID: 9708D10

Sampled: 08/25/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D10-08 Sample Desc : LIQUID,Hilltop 7				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D10-09 Sample Desc : LIQUID,Hilltop 8				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D10-10 Sample Desc : LIQUID,Hilltop 9				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D10-11 Sample Desc : LIQUID,Hilltop 10				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D10-12 Sample Desc : LIQUID,Hilltop 11				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.044** S

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HERBERT HOOVER MS

Micro Log In **48051**
Total Samples 21
Date Sampled 8/27/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **H. HOOVER 1** Micro 48051-01 **DRINKING FOUNTAIN** **C9B** **FIRST DRAW**	**2.9**	1.0	
Client **H. HOOVER 2** Micro 48051-02 **DRINKING FOUNTAIN** **C9B** **FIRST DRAW**	**7.1**	1.0	
Client **H. HOOVER 3** Micro 48051-03 **DRINKING FOUNTAIN** **C9C** **FIRST DRAW**	**3.0**	1.0	
Client **H. HOOVER 4** Micro 48051-04 **DRINKING FOUNTAIN** **C9C** **FIRST DRAW**	**2.4**	1.0	
Client **H. HOOVER 5** Micro 48051-05 **DRINKING FOUNTAIN** **C9C** **FIRST DRAW**	**5.7**	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HERBERT HOOVER MS

Micro Log In **48051**
Total Samples 21
Date Sampled 8/27/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **H. HOOVER 6** Micro 48051-06 DRINKING FOUNTAIN C9B FIRST DRAW	3.2	1.0	
Client **H. HOOVER 7** Micro 48051-07 DRINKING FOUNTAIN C9B FIRST DRAW	2.4	1.0	
Client **H. HOOVER 8** Micro 48051-08 DRINKING FOUNTAIN C9G FIRST DRAW	1.7	1.0	
Client **H. HOOVER 9** Micro 48051-09 DRINKING FOUNTAIN C93 FIRST DRAW	2.1	1.0	
Client **H. HOOVER 10** Micro 48051-10 DRINKING FOUNTAIN C93 FIRST DRAW	1.3	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HERBERT HOOVER MS

Micro Log In **48051**
Total Samples 21
Date Sampled 8/27/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **H. HOOVER 12** Micro 48051-11 **DRINKING FOUNTAIN** **C9B** **FIRST DRAW**	**1.5**	1.0	
Client **H. HOOVER 13** Micro 48051-12 **DRINKING FOUNTAIN** **C9B** **FIRST DRAW**	**3.7**	1.0	
Client **H. HOOVER 14** Micro 48051-13 **DRINKING FOUNTAIN** **B18** **FIRST DRAW**	**1.9**	1.0	
Client **H. HOOVER 15** Micro 48051-14 **SINK FAUCET** **B18** **FIRST DRAW**	**6.5**	1.0	
Client **H. HOOVER 16** Micro 48051-15 **SINK FAUCET** **B18** **FIRST DRAW**	**3.4**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HERBERT HOOVER MS

Micro Log In **48051**
Total Samples 21
Date Sampled 8/27/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **H. HOOVER 17** Micro 48051-16 **SINK FAUCET** **B16** **FIRST DRAW**	**3.0**	1.0	
Client **H. HOOVER 18** Micro 48051-17 **SINK FAUCET** **B18** **FIRST DRAW**	**11.4**	1.0	
Client **H. HOOVER 19** Micro 48051-18 **SINK FAUCET** **B18** **FIRST DRAW**	**1.9**	1.0	
Client **H. HOOVER 11** Micro 48051-19 **WATER FAUCET** **308** **FIRST DRAW**	**2.6**	1.0	
Client **H. HOOVER 20** Micro 48051-20 **SINK FAUCET** **B18** **FIRST DRAW**	**1.8**	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HERBERT HOOVER MS

Micro Log In **48051**
Total Samples 21
Date Sampled 8/27/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: H. HOOVER 21 Micro 48051-21 BLANK	< 1.0	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hutch Community Center

Lab Proj. ID: 9710H20

Sampled: 10/30/97
Received: 10/30/97
Analyzed: see below

Reported: 11/06/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710H20-01 Sample Desc : LIQUID,1				
Lead	mg/L	11/03/97	0.0050	N.D.
Lab No: 9710H20-02 Sample Desc : LIQUID,2				
Lead	mg/L	11/03/97	0.0050	N.D.
Lab No: 9710H20-03 Sample Desc : LIQUID,3				
Lead	mg/L	11/03/97	0.0050	N.D.
Lab No: 9710H20-04 Sample Desc : LIQUID,4				
Lead	mg/L	11/03/97	0.0050	N.D.
Lab No: 9710H20-05 Sample Desc : LIQUID,5				
Lead	**mg/L**	**11/03/97**	**0.0050**	**0.058**
Lab No: 9710H20-06 Sample Desc : LIQUID,6				
Lead	mg/L	11/03/97	0.0050	N.D.
Lab No: 9710H20-07 Sample Desc : LIQUID,7				
Lead	mg/L	11/03/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hutch Community Center
Lab Proj. ID: 9710H20

Sampled: 10/30/97
Received: 10/30/97
Analyzed: see below
Reported: 11/06/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710H20-08 Sample Desc : **LIQUID,8**				
Lead	mg/L	11/03/97	0.0050	N.D.
Lab No: 9710H20-09 Sample Desc : **LIQUID,9**				
Lead	mg/L	11/03/97	0.0050	N.D.
Lab No: 9710H20-10 Sample Desc : **LIQUID,9 (duplicate)**				
Lead	mg/L	11/03/97	0.0050	N.D.
Lab No: 9710H20-11 Sample Desc : **LIQUID,10**				
Lead	mg/L	11/03/97	0.0050	N.D.
Lab No: 9710H20-12 Sample Desc : **LIQUID,11 (blank)**				
Lead	mg/L	11/03/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Hutch Community

Lab Proj. ID: 9712754

Sampled: 12/11/97
Received: 12/12/97
Analyzed: see below

Reported: 12/18/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9712754-01 Sample Desc : LIQUID, ~~5-1~~ 5A				
Lead	mg/L	12/17/97	0.0050	0.018
Lab No: 9712754-02 Sample Desc : LIQUID, ~~3-2~~ 5B				
Lead	mg/L	12/17/97	0.0050	0.014
Lab No: 9712754-03 Sample Desc : LIQUID, ~~3-3~~ 5C				
Lead	mg/L	12/17/97	0.0050	0.082
Lab No: 9712754-04 Sample Desc : LIQUID, ~~3-8~~ Dup 5C				
Lead	mg/L	12/17/97	0.0050	0.084
Lab No: 9712754-05 Sample Desc : LIQUID, Blank				
Lead	mg/L	12/17/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
INTN'L STUDIES ACADEMY

Micro Log In **47412**
Total Samples 6
Date Sampled 8/13/97
Date Received 8/15/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47412-01 DRINKING FOUNTAIN CORRIDOR C-90 FIRST FLOOR FIRST DRAW	6.0	1.0	
Client 2 Micro 47412-02 DRINKING FOUNTAIN CORRIDOR C-90 SECOND FLOOR FIRST DRAW	< 1.0	1.0	
Client 3 Micro 47412-03 SINK FAUCET KITCHEN AREA 035, BASEMENT FIRST DRAW	2.7	1.0	
Client 4 Micro 47412-04 DRINKING FOUNTAIN BY ENTRANCE TO THE GYM FIRST DRAW	3.7	1.0	
Client 5 Micro 47412-05 DRINKING FOUNTAIN CORRIDOR C-90 FIRST DRAW	10.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
INTN'L STUDIES ACADEMY

Micro Log In **47412**
Total Samples 6
Date Sampled 8/13/97
Date Received 8/15/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47412-06 BLANK	< 1.0	1.0	

Technical Supervisor: 8/21/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JEFFERSON NURSERY (CC)

Micro Log In **47786**
Total Samples 9
Date Sampled 8/22/97
Date Received 8/26/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **JEFFERSON CC 1** Micro 47786-01 **SINK FAUCET** **BATHROOM 1** **FIRST DRAW**	**3.3**	1.0	
Client **JEFFERSON CC 2** Micro 47786-02 **SINK FAUCET** **BATHROOM 1** **FIRST DRAW**	**2.8**	1.0	
Client **JEFFERSON CC 3** Micro 47786-03 **SINK FAUCET** **BATHROOM 1** **FIRST DRAW**	**4.1**	1.0	
Client **JEFFERSON CC 4** Micro 47786-04 **SINK FAUCET** **KITCHEN** **FIRST DRAW**	**33.2**	1.0	
Client **JEFFERSON CC 5** Micro 47786-05 **SINK FAUCET** **BATHROOM 2** **FIRST DRAW**	**1.6**	1.0	

Technical Supervisor: F. Ramezanzadeh 8/31/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JEFFERSON NURSERY (CC)

Micro Log In **47786**
Total Samples 9
Date Sampled 8/22/97
Date Received 8/26/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: JEFFERSON CC 6 Micro 47786-06 SINK FAUCET BATHROOM 3 FIRST DRAW	1.3	1.0	
Client: JEFFERSON CC 7 Micro 47786-07 WATER FAUCET OUTSIDE FOUNT. 1 FIRST DRAW	1.2	1.0	
Client: JEFFERSON CC 8 Micro 47786-08 WATER FAUCET OUTSIDE FOUNT. 2 FIRST DRAW	31.4	1.0	
Client: JEFFERSON CC 9 Micro 47786-09 SINK FAUCET BUNGALOW FIRST DRAW	3.3	1.0	

Technical Supervisor: F. Ramezanzadeh 8/31/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Jefferson CC
Lab Proj. ID: 9710481

Sampled: 10/01/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710481-01 Sample Desc : **LIQUID,Jefferson CC 4-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710481-02 Sample Desc : **LIQUID,Jefferson CC 4-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710481-03 Sample Desc : **LIQUID,Jefferson CC 4-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710481-04 Sample Desc : **LIQUID,Jefferson CC 4-C duplicate**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0050**
Lab No: 9710481-05 Sample Desc : **LIQUID,Jefferson CC Blank**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JEFFERSON ES

Micro Log In 47525
Total Samples 30
Date Sampled 8/18/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client JEFFERSON C.C. 1 Micro 47525-01 SINK DRINKING FOUNTAIN ROOM 106	2.7	1.0	
Client JEFFERSON C.C. 2 Micro 47525-02 SINK DRINKING FOUNTAIN ROOM 106	1.6	1.0	
Client JEFFERSON C.C. 3 Micro 47525-03 DRINKING FOUNTAIN HALL - 1ST FLOOR	2.4	1.0	
Client JEFFERSON E.S. 4 Micro 47525-04 SINK DRINKING FOUNTAIN ROOM 104	4.9	1.0	
Client JEFFERSON E.S. 5 Micro 47525-05 SINK DRINKING FOUNTAIN ROOM 102	2.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JEFFERSON ES

Micro Log In 47525
Total Samples 30
Date Sampled 8/18/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client JEFFERSON E.S. 6 Micro 47525-06 SINK FAUCET TEACHERS LOUNGE	1.6	1.0	
Client JEFFERSON E.S. 7 Micro 47525-07 DRINKING FOUNTAIN CAFETERIA	1.2	1.0	
Client JEFFERSON E.S. 8 Micro 47525-08 SINK FAUCET ROOM 8	< 1.0	1.0	
Client JEFFERSON E.S. 9 Micro 47525-09 SINK DRINKING FOUNTAIN ROOM 101	7.1	1.0	
Client JEFFERSON E.S. 10 Micro 47525-10 SINK DRINKING FOUNTAIN ROOM 103	1.9	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JEFFERSON ES

Micro Log In 47525
Total Samples 30
Date Sampled 8/18/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client JEFFERSON E.S. 11 Micro 47525-11 SINK DRINKING FOUNTAIN ROOM 105	9.6	1.0	
Client JEFFERSON E.S. 12 Micro 47525-12 SINK DRINKING FOUNTAIN ROOM 209	3.2	1.0	
Client JEFFERSON E.S. 13 Micro 47525-13 DRINKING FOUNTAIN HALL - 2ND FLOOR	3.0	1.0	
Client JEFFERSON 28 Micro 47525-14 DRINKING FOUNTAIN HALL - 3RD FLOOR	21.2	1.0	
Client JEFFERSON BL Micro 47525-15 BLANK	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JEFFERSON ES

Micro Log In **47525**
Total Samples 30
Date Sampled 8/19/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **JEFFERSON E.S . 14** Micro 47525-16 **SINK DRINKING FOUNTAIN ROOM 212**	**2.2**	1.0	
Client **JEFFERSON E.S. 15** Micro 47525-17 **SINK DRINKING FOUNTAIN ROOM 213**	**3.7**	1.0	
Client **JEFFERSON E.S. 16** Micro 47525-18 **SINK DRINKING FOUNTAIN ROOM 211**	**4.1**	1.0	
Client **JEFFERSON E.S. 17** Micro 47525-19 **SINK DRINKING FOUNTAIN ROOM 210**	**16.2**	1.0	
Client **JEFFERSON E.S. 18** Micro 47525-20 **SINK DRINKING FOUNTAIN ROOM 208**	**7.3**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JEFFERSON ES

Micro Log In **47525**
Total Samples **30**
Date Sampled **8/19/97**
Date Received **8/19/97**
Date Analyzed **8/24/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **JEFFERSON E.S. 19** Micro 47525-21 SINK DRINKING FOUNTAIN ROOM 206	3.2	1.0	
Client **JEFFERSON E.S. 20** Micro 47525-22 SINK DRINKING FOUNTAIN ROOM 204	2.5	1.0	
Client **JEFFERSON E.S. 21** Micro 47525-23 SINK DRINKING FOUNTAIN ROOM 202	40.6	1.0	
Client **JEFFERSON E.S. 22** Micro 47525-24 SINK DRINKING FOUNTAIN ROOM 201	8.4	1.0	
Client **JEFFERSON E.S. 23** Micro 47525-25 SINK DRINKING FOUNTAIN ROOM 203	9.9	1.0	

Technical Supervisor: F Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JEFFERSON ES

Micro Log In **47525**
Total Samples 30
Date Sampled 8/19/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **JEFFERSON E.S. 24** Micro 47525-26 **SINK DRINKING FOUNTAIN ROOM 205**	**4.7**	1.0	
Client **JEFFERSON E.S. 25** Micro 47525-27 **SINK DRINKING FOUNTAIN ROOM 207**	**14.8**	1.0	
Client **JEFFERSON E.S. 26** Micro 47525-28 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND**	**3.8**	1.0	
Client **JEFFERSON E.S. 27** Micro 47525-29 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND**	**21.2**	1.0	
Client **JEFFERSON E.S. BL** Micro 47525-30 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Jefferson ES

Lab Proj. ID: 9710478

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710478-01 Sample Desc : **LIQUID,Jefferson E.S. 17-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710478-02 Sample Desc : **LIQUID,Jefferson E.S. 17-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710478-03 Sample Desc : **LIQUID,Jefferson E.S. 17-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710478-04 Sample Desc : **LIQUID,Jefferson E.S. 21-A**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0060**
Lab No: 9710478-05 Sample Desc : **LIQUID,Jefferson E.S. 21-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710478-06 Sample Desc : **LIQUID,Jefferson E.S. 21-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.026**
Lab No: 9710478-07 Sample Desc : **LIQUID,Jefferson E.S. 25-A**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Jefferson ES

Lab Proj. ID: 9710478

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710478-08 Sample Desc : **LIQUID,Jefferson E.S. 25-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710478-09 Sample Desc : **LIQUID,Jefferson E.S. 25-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0080**
Lab No: 9710478-10 Sample Desc : **LIQUID,Jefferson E.S. 25-C (dup)**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0070**
Lab No: 9710478-11 Sample Desc : **LIQUID,Jefferson E.S. Blank**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
KATE KENNEDY CC

Micro Log In **47422**
Total Samples **11**
Date Sampled **8/15/97**
Date Received **8/15/97**
Date Analyzed **8/21/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47422-01 BLANK	< 1.0	1.0	
Client 2 Micro 47422-02 DRINKING FOUNTAIN FIRST FLOOR HALLWAY - NEXT TO CAFETERIA FIRST DRAW	< 1.0	1.0	
Client 3 Micro 47422-03 MULTIPLE DRINKING FOUNTAIN PLAYGROUND LEVEL OUTSIDE OF CAFETERIA SOUTH / WEST FIRST DRAW	1.8	1.0	
Client 4 Micro 47422-04 MULTIPLE DRINKING FOUNTAIN PLAYGROUND LEVEL NORTH / WEST SIDE OF KITCHEN FIRST DRAW	22.6	1.0	
Client 5 Micro 47422-05 DRINKING FOUNTAIN SECOND FLOOR BETWEEN MAIN OFFICE & LIBRARY FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
KATE KENNEDY CC

Micro Log In 47422
Total Samples 11
Date Sampled 8/15/97
Date Received 8/15/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47422-06 DRINKING FOUNTAIN SECOND FLOOR NEXT TO ROOM 9 - (HALLWAY) FIRST DRAW	1.6	1.0	
Client 7 Micro 47422-07 DRINKING FOUNTAIN THIRD FLOOR HALLWAY - NEXT TO ROOM 15 FIRST DRAW	1.1	1.0	
Client 8 Micro 47422-08 DRINKING FOUNTAIN THIRD FLOOR HALLWAY - NEXT TO ROOM13 FIRST DRAW	2.4	1.0	
Client 9 Micro 47422-09 SINK FAUCET KITCHEN SINK (LEFT) FIRST DRAW	< 1.0	1.0	
Client 10 Micro 47422-10 SINK FAUCET KITCHEN SINK (CENTER) FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
KATE KENNEDY CC

Micro Log In **47422**
Total Samples **11**
Date Sampled **8/15/97**
Date Received **8/15/97**
Date Analyzed **8/21/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47422-11 SINK FAUCET DISH WASHER (COUNTER) FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
KATE KENNEDY CC

Micro Log In **48028**
Total Samples 4
Date Sampled 8/30/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 12 Micro 48028-01 **BLANK**	< 1.0	1.0	
Client ~~13~~ 4A Micro 48028-02 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND LEVEL WEST SIDE OF KITCHEN FIRST DRAW**	1.1	1.0	
Client ~~14~~ 4B Micro 48028-03 **MUTILPLE DRINKING FOUNTAIN PLAYGROUND LEVEL WEST SIDE OF KITCHEN SECOND DRAW**	< 1.0	1.0	
Client ~~15~~ 4C Micro 48028-04 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND LEVEL WEST SIDE OF KITCHEN THIRD DRAW**	1.2	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANCIS SCOTT KEY ES

Micro Log In **47742**
Total Samples 8
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47742-06 MULTIPLE DRINKING FOUNTAIN OUTSIDE BASKETBALL COURT FIRST DRAW	< 1.0	1.0	
Client 7 Micro 47742-07 MULTIPLE DRINKING FOUNTAIN OUTSIDE BASKETBALL COURT BLANK	< 1.0	1.0	
Client 8 Micro 47742-08 SPIKED	57.4	2.2	

Technical Supervisor: 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANCIS SCOTT KEY ES

Micro Log In **49296**
Total Samples 4
Date Sampled 10/2/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **3A** Micro 49296-01 **DRINKING FOUNTAIN** **1ST FLOOR HALL / SOUTH END** **FIRST DRAW**	< 1.0	1.0	
Client **3B** Micro 49296-02 **DRINKING FOUNTAIN** **1ST FLOOR HALL / SOUTH END** **FIRST DRAW**	1.4	1.0	
Client **3C** Micro 49296-03 **DRINKING FOUNTAIN** **1ST FLOOR HALL / SOUTH END** **FIRST DRAW**	1.4	1.0	
Client **BLANK** Micro 49296-04 **BLANK**	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
STARR KING ES

Micro Log In **47523**
Total Samples 14
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **STARR KING 1** Micro 47523-01 **SINK FAUCET** **KITCHEN ROOM 017**	**10.5**	1.0	
Client **STARR KING 2** Micro 47523-02 **MULTIPLE DRINKING FOUNTAIN** **EXTERIOR NEAR T-600**	**3.2**	1.0	
Client **STARR KING 3** Micro 47523-03 **SINK FAUCET** **ROOM 009**	**3.8**	1.0	
Client **STARR KING 4** Micro 47523-04 **SINK FAUCET** **ROOM 005**	**3.1**	1.0	
Client **STARR KING 5** Micro 47523-05 **DRINKING FOUNTAIN** **ROOM 003**	**2.7**	1.0	

Technical Supervisor: 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
STARR KING ES

Micro Log In 47523
Total Samples 14
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **STARR KING 6** Micro 47523-06 **DRINKING FOUNTAIN ROOM 001**	**58.5**	2.0	
Client **STARR KING 7** Micro 47523-07 **DRINKING FOUNTAIN ROOM 113**	**15.8**	1.0	
Client **STARR KING 8** Micro 47523-08 **DRINKING FOUNTAIN ROOM 114**	**11.4**	1.0	
Client **STARR KING 9** Micro 47523-09 **DRINKING FOUNTAIN HALL - SOUTH**	**8.7**	1.0	
Client **STARR KING 10** Micro 47523-10 **DRINKING FOUNTAIN HALL NEAR ROOM 201**	**2.9**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
STARR KING ES

Micro Log In **47523**
Total Samples 14
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **STARR KING 11** Micro 47523-11 **DRINKING FOUNTAIN HALL NEAR LOUNGE**	**30.6**	1.0	
Client **STARR KING 12** Micro 47523-12 **DRINKING FOUNTAIN HALL NEAR BOYS' RESTROOM**	**10.0**	1.0	
Client **STARR KING 13** Micro 47523-13 **DRINKING FOUNTAIN HALL NEAR GIRLS' RESTROOM**	**20.9**	1.0	
Client **STARR KING BL** Micro 47523-14 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/5/97 Analyst: FR
Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: King ES

Lab Proj. ID: 9710480

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710480-01 Sample Desc : **LIQUID,King ES 6-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710480-02 Sample Desc : **LIQUID,King ES 6-B**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: King ES

Lab Proj. ID: 9710480

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710480-03 Sample Desc : LIQUID,King ES 6-C				
Lead	mg/L	10/11/97	0.0050	0.0050

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: King ES

Lab Proj. ID: 9710480

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710480-04 Sample Desc : **LIQUID,King ES 7-A**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0090**
Lab No: 9710480-05 Sample Desc : **LIQUID,King ES 7-B**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.010**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: King ES

Lab Proj. ID: 9710480

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710480-06				
Sample Desc : LIQUID,King ES 7-C				
Lead	mg/L	10/11/97	0.0050	0.011

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: King ES
Lab Proj. ID: 9710480

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below
Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710480-07 Sample Desc : **LIQUID,King ES 11-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710480-08 Sample Desc : **LIQUID,King ES 11-B**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: King ES

Lab Proj. ID: 9710480

Sampled: 10/04/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710480-09 Sample Desc : **LIQUID,King ES 11-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.011**
Lab No: 9710480-10 Sample Desc : **LIQUID,King ES 11-C (duplicate)**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.010**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: King ES

Lab Proj. ID: 9710480

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710480-11				
Sample Desc : **LIQUID,King ES Blank**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANCIS SCOTT KEY ES

Micro Log In **47742**
Total Samples 8
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47742-01 DRINKING FOUNTAIN FIRST FLOOR KITCHEN BY STAIRS FIRST DRAW	9.7	1.0	
Client 2 Micro 47742-02 SINK FAUCET FIRST FLOOR KITCHEN FIRST DRAW	2.9	1.0	
Client 3 Micro 47742-03 DRINKING FOUNTAIN FIRST FLOOR HALL, SOUTH END FIRST DRAW	14.2	1.0	
Client 4 Micro 47742-04 DRINKING FAUCET 2ND FLOOR HALL, SOUTH END FIRST DRAW	< 1.0	1.0	
Client 5 Micro 47742-05 SINK FAUCET 1ST FLOOR ADMIN. LOUNGE FIRST DRAW	2.9	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
M.L. KING MS

Micro Log In **47641**
Total Samples 10
Date Sampled 8/21/97
Date Received 8/21/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47641-01 **BLANK**	< 1.0	1.0	
Client 3 Micro 47641-02 **SINK FAUCET FIRST FLOOR - FACULTY ROOM ROOM 103 FIRST DRAW**	< 1.0	1.0	
Client 4 Micro 47641-03 **DRINKING FOUNTAIN FIRST FLOOR UNDER STAIRWAY NEXT TO ROOM 126**	1.2	1.0	
Client 7 Micro 47641-04 **SINK FAUCET FIRST FLOOR INSIDE CAFETERIA KITCHEN FIRST DRAW**	3.7	1.0	
Client 8 Micro 47641-05 **DRINKING FOUNTAIN LOWER LEVEL GIRLS' GYM BATHROOM FIRST DRAW**	5.3	1.0	

Technical Supervisor: 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
M.L. KING MS

Micro Log In **47641**
Total Samples 10
Date Sampled 8/21/97
Date Received 8/21/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 9 Micro 47641-06 DRINKING FOUNTAIN UPPER LEVEL GYM - BASKETBALL COURT FIRST DRAW	7.5	1.0	
Client 10 Micro 47641-07 DRINKING FOUNTAIN LOWER LEVEL GIRLS' BATHROOM GYM FIRST DRAW	3.1	1.0	
Client 11 Micro 47641-08 DRINKING FOUNTAIN LOWER LEVEL BOYS' ROOM GYM FIRST DRAW	4.2	1.0	
Client 12 Micro 47641-09 DRINKING FOUNTAIN LOWER LEVEL BOYS' ROOM GYM - BATHROOM FIRST DRAW	2.2	1.0	
Client 14 Micro 47641-10 DRINKING FOUNTAIN UPPER LEVEL BASKETBALL COURT FIRST DRAW	4.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAFAYETTE ES

Micro Log In **47937**
Total Samples 13
Date Sampled 8/21/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47937-01 DRINKING FOUNTAIN 1ST FLOOR CORRIDOR (190) FIRST DRAW	2.1	1.0	
Client 2 Micro 47937-02 DRINKING FOUNTAIN 1ST FLOOR CORRIDOR (190) FIRST DRAW	2.3	1.0	
Client 3 Micro 47937-03 DRINKING FOUNTAIN 1ST FLOOR CORRIDOR (190) FIRST DRAW	16.0	1.0	
Client 4 Micro 47937-04 DRINKING FOUNTAIN 2ND FLOOR CORRIDOR (290) FIRST DRAW	7.3	1.0	
Client 5 Micro 47937-05 DRINKING FOUNTAIN 2ND FLOOR CORRIDOR (290) FIRST DRAW	9.2	1.0	

Technical Supervisor: F. Ramezanzadeh 9/4/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAFAYETTE ES

Micro Log In **47937**
Total Samples 13
Date Sampled 8/21/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47937-06 DRINKING FOUNTAIN 2ND FLOOR CORRIDOR (290) FIRST DRAW	2.4	1.0	
Client 7 Micro 47937-07 DRINKING FOUNTAIN 1ST FLOOR RM (026B) FIRST DRAW	17.1	1.0	
Client 8 Micro 47937-08 DRINKING FOUNTAIN 1ST FLOOR CORRIDOR (193) FIRST DRAW	5.4	1.0	
Client 9 Micro 47937-09 MULTIPLE DRINKING FOUNTAIN YARD FIRST DRAW	2.8	1.0	
Client 10 Micro 47937-10 MULTIPLE DRINKING FOUNTAIN YARD FIRST DRAW	4.3	1.0	

Technical Supervisor: F. Ramezanzadeh 9/4/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAFAYETTE ES

Micro Log In **47937**
Total Samples 13
Date Sampled 8/21/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **11** Micro 47937-11 **SINK FAUCET** **FACULTY LOUNGE RM (039A)** **FIRST DRAW**	< 1.0	1.0	
Client **12** Micro 47937-12 **SINK FAUCET** **KITCHEN RM (037)** **FIRST DRAW**	< 1.0	1.0	
Client **13** Micro 47937-13 **BLANK**	< 1.0	1.0	

Technical Supervisor: 9/4/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAFAYETTE ES

Micro Log In **49317**
Total Samples 6
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~1A~~ 3A Micro 49317-01 DRINKING FOUNTAIN 1ST FLOOR CORRIDOR (190) RE-SAMPLE	6.5	1.0	
Client ~~1B~~ 3B Micro 49317-02 DRINKING FOUNTAIN 1ST FLOOR CORRIDOR (190) RE-SAMPLE	4.5	1.0	
Client ~~1C~~ 3C Micro 49317-03 DRINKING FOUNTAIN 1ST FLOOR CORRIDOR (190) RE-SAMPLE	3.4	1.0	
Client 2A 7A Micro 49317-04 DRINKING FOUNTAIN 1ST FLOOR ROOM (026B) RE-SAMPLE	2.0	1.0	
Client 2B 7B Micro 49317-05 DRINKING FOUNTAIN 1ST FLOOR ROOM (026B) RE-SAMPLE	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAFAYETTE ES

Micro Log In **49317**
Total Samples 6
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 2C 7C Micro 49317-06 **DRINKING FOUNTAIN 1ST FLOOR ROOM (026B) RE-SAMPLE**	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Lake Shore Elem.

Lab Proj. ID: 9708B83

Sampled: 08/16/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B83-01 Sample Desc : LIQUID,Lakeshore-1 (Blank)				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B83-02 Sample Desc : LIQUID,Lakeshore-2				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B83-03 Sample Desc : LIQUID,Lakeshore-2 (DUP)				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B83-04 Sample Desc : LIQUID,Lakeshore-3				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B83-05 Sample Desc : LIQUID,Lakeshore-4				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B83-06 Sample Desc : LIQUID,Lakeshore-5				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B83-07 Sample Desc : LIQUID,Lakeshore-6				
Lead	mg/L	08/27/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Lake Shore Elem.
Lab Proj. ID: 9708B83

Sampled: 08/16/97
Received: 08/22/97
Analyzed: see below
Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B83-08 Sample Desc : LIQUID,Lakeshore-7				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-09 Sample Desc : LIQUID,Lakeshore-8				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-10 Sample Desc : LIQUID,Lakeshore-9				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-11 Sample Desc : LIQUID,Lakeshore-11				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-12 Sample Desc : LIQUID,Lakeshore-12				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-13 Sample Desc : LIQUID,Lakeshore-12 (DUP)				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-14 Sample Desc : LIQUID,Lakeshore-13				
Lead	mg/L	08/27/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Lake Shore Elem.

Lab Proj. ID: 9708B83

Sampled: 08/16/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B83-15 Sample Desc : LIQUID,Lakeshore-14				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-16 Sample Desc : LIQUID,Lakeshore-15				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-17 Sample Desc : LIQUID,Lakeshore-16				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-18 Sample Desc : LIQUID,Lakeshore-17				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B83-19 Sample Desc : LIQUID,Lakeshore-18				
Lead	mg/L	08/27/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LARKIN STREET
(HOMELESS)
YOUTH CENTER

Micro Log In **49456**
Total Samples 9
Date Sampled 10/9/97
Date Received 10/10/97
Date Analyzed 10/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 49456-01 **SINK FAUCET** **DROP IN KITCHEN SINK**	< 1.0	1.0	
Client 2 Micro 49456-02 **SINK FAUCET** **DROP IN RESTROOM**	< 1.0	1.0	
Client 3 Micro 49456-03 **SINK FAUCET** **ART ROOOM SINK**	< 1.0	1.0	
Client 4 Micro 49456-04 **SINK FAUCET** **STAFF RESTROOM**	< 1.0	1.0	
Client 5 Micro 49456-05 **SINK FAUCET** **MEDICAL CLINIC RESTROOM**	1.4	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LARKIN STREET
(HOMELESS)
YOUTH CENTER

Micro Log In **49456**
Total Samples 9
Date Sampled 10/9/97
Date Received 10/10/97
Date Analyzed 10/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 49456-06 SINK FAUCET AFTER CARE RESTROOM	2.0	1.0	
Client 7 Micro 49456-07 SINK FAUCET AFTER CARE KITCHEN	1.1	1.0	
Client 8 Micro 49456-08 BLANK	< 1.0	1.0	
Client 9 Micro 49456-09 SINK FAUCET MEETING ROOM RESTROOM	97.4	3.3	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Las Americas C.C.

Lab Proj. ID: 9709175

Sampled: 09/05/97
Received: 09/05/97
Analyzed: see below

Reported: 09/11/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709175-01 Sample Desc : **LIQUID,1**				
Lead	**mg/L**	**09/11/97**	**0.0050**	**0.0053**
Lab No: 9709175-02 Sample Desc : **LIQUID,2**				
Lead	mg/L	09/11/97	0.0050	N.D.
Lab No: 9709175-03 Sample Desc : **LIQUID,3**				
Lead	mg/L	09/11/97	0.0050	N.D.
Lab No: 9709175-04 Sample Desc : **LIQUID,4**				
Lead	**mg/L**	**09/11/97**	**0.0050**	**0.011**
Lab No: 9709175-05 Sample Desc : **LIQUID,4 duplicate**				
Lead	**mg/L**	**09/11/97**	**0.0050**	**0.011**
Lab No: 9709175-06 Sample Desc : **LIQUID,5**				
Lead	mg/L	09/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In 60461
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client LAWTON 1 Micro 60461-01 drinking fountain hallway east of auditorium	1	1	
Client LAWTON 2 Micro 60461-02 drinking fountain cross from rm. 32 hall	1	1	
Client LAWTON 3 Micro 60461-03 drinking fountain cross from 232 I hall	3	1	
Client LAWTON 4 Micro 60461-04 sink faucet, class room 228	7	1	
Client LAWTON 5 Micro 60461-05 sink faucet, class room 224	5	1	

Technical Supervisor: F. Ramazanzadeh 9/29/98 Analyst: FR

Farid Ramazanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1097. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER • STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In 60461
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: LAWTON 6 Micro 60461-06 sink faucet, class room 227	19	1	
Client: LAWTON 7 Micro 60461-07 drinking fountain, hall by 140 I	2	1	
Client: LAWTON 8 Micro 60461-08 drinking fountain, hall by 140 r	3	1	
Client: LAWTON 9 Micro 60461-09 drinking fountain, hall by 135	< 1	1	
Client: LAWTON 10 Micro 60461-10 sink faucet, 230	8	1	

Technical Supervisor: F. Ramezanzadeh 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In 60461
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client LAWTON 11 Micro 60461-11 sink faucet, 239	< 1	1	
Client LAWTON 12 Micro 60461-12 sink faucet, 222	7	1	
Client LAWTON 13 Micro 60461-13 sink faucet, 233	3	1	
Client LAWTON 14 Micro 60461-14 sink faucet, 134	5	1	
Client LAWTON 15 Micro 60461-15 sink faucet, 133	6	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In 60461
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client LAWTON 16 Micro 60461-16 sink faucet, 135	6	1	
Client LAWTON 17 Micro 60461-17 sink faucet, 122	6	1	
Client LAWTON 18 Micro 60461-18 sink faucet, 136	7	1	
Client LAWTON 19 Micro 60461-19 sink faucet, 131	10	1	
Client LAWTON 20 Micro 60461-20 sink faucet, 138	4	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In 60461
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client LAWTON 21 Micro 60461-21 sink drinking fountain 139	3	1	
Client LAWTON 22 Micro 60461-22 sink faucet, 139	4	1	
Client LAWTON 23 Micro 60461-23 sink drinking fountain, 140	3	1	
Client LAWTON 24 Micro 60461-24 sink faucet, 140	5	1	
Client LAWTON 25 Micro 60461-25 sink drinking fountain, 141	2	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In 60461
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client LAWTON 26 Micro 60461-26 sink faucet, 141	2	1	
Client LAWTON 27 Micro 60461-27 drinking fountain, hall by 031 r	2	1	
Client LAWTON 28 Micro 60461-28 drinking fountain, hall by 031 l	2	1	
Client LAWTON 29 Micro 60461-29 multiple drinking fountain hall across from cafeteria r	3	1	
Client LAWTON 30 Micro 60461-30 multiple drinking fountain hall across from cafeteria south l	1	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In **60461**
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **LAWTON 31** Micro 60461-31 multiple drinking fountain cafeteria south	2	1	
Client **LAWTON 32** Micro 60461-32 multiple drinking fountain cafeteria north	4	1	
Client **LAWTON 33** Micro 60461-33 sink drinking fountain, 031	41	1	
Client **LAWTON 34** Micro 60461-34 sink faucet, 031	4	1	
Client **LAWTON 35** Micro 60461-35 sink drinking fountain, 032	2	1	

Technical Supervisor: F. Ramezanzadeh 9/29/98 Analyst: FR

Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In 60461
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client LAWTON 36 Micro 60461-36 sink faucet, 032	3	1	
Client LAWTON 37 Micro 60461-37 sink drinking fountain, 033	4	1	
Client LAWTON 38 Micro 60461-38 sink faucet, 023	8	1	
Client LAWTON 39 Micro 60461-39 sink faucet, 027	1	1	
Client LAWTON 40 Micro 60461-40 sink faucet, rm. 25	1	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In 60461
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client LAWTON 41 Micro 60461-41 sink faucet, kitchen I	2	1	
Client LAWTON 42 Micro 60461-42 sink faucet, kitchen r (porcelin)	< 1	1	
Client LAWTON 43 Micro 60461-43 sink drinking fountain, 1f2	3	1	
Client LAWTON 44 Micro 60461-44 sink faucet, 1f2	3	1	
Client LAWTON 45 Micro 60461-45 sink drinking fountain, 034	3	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES

Micro Log In 60461
Total Samples 47
Date Sampled 9/22/98
Date Received 9/22/98
Date Analyzed 9/24/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client LAWTON 46 Micro 60461-46 multiple drinking fountain playground a	< 1	1	
Client LAWTON 47 Micro 60461-47 multiple drinking fountain playground nw	< 1	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LAWTON ES B 2243

Micro Log In **60869**
Total Samples 2
Date Sampled 9/22/98
Date Received 10/5/98
Date Analyzed 10/6/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **LAWTON 6A** Micro 60869-01 **SINK FAUCET, 237**	9	1	
Client **LAWTON 33A** Micro 60869-02 **sink drinking fountain, 031**	3	1	

Technical Supervisor: F. Ramezanzadeh 10/7/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JAMES LICK MS

Micro Log In **47942**
Total Samples 17
Date Sampled 8/23/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 47942-01 MULTIPLE DRINKING FOUNTAIN OUTSIDE YARD NORTH SIDE INITIAL DRAW	12.2	1.0	
Client # 2 Micro 47942-02 MULTIPLE DRINKING FOUNTAIN OUTSIDE YARD NORTHWEST INITIAL DRAW	< 1.0	1.0	
Client # 3 Micro 47942-03 MULTIPLE DRINKING FOUNTAIN OUTSIDE WEST SIDE INITIAL DRAW	< 1.0	1.0	
Client # 4 Micro 47942-04 DRINKING FOUNTAIN ROOM 001 BASEMENT INITIAL DRAW	1.6	1.0	
Client # 5 Micro 47942-05 DRINKING FOUNTAIN CORRIDOR C90 - BASEMENT INITIAL DRAW	1.6	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JAMES LICK MS

Micro Log In **47942**
Total Samples 17
Date Sampled 8/23/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 6 Micro 47942-06 DRINKING FOUNTAIN CORRIDOR C90S, FIRST FLOOR INITIAL DRAW	< 1.0	1.0	
Client # 7 Micro 47942-07 DRINKING FOUNTAIN CORRIDOR C90N, FIRST FLOOR INITIAL DRAW	< 1.0	1.0	
Client # 8 Micro 47942-08 DRINKING FOUNTAIN CORRIDOR C91, FIRST FLOOR INITIAL DRAW	1.0	1.0	
Client # 9 Micro 47942-09 DRINKING FOUNTAIN CAFETERIA 130, 1ST FLOOR INITIAL DRAW	< 1.0	1.0	
Client # 10 Micro 47942-10 DRINKING FOUNTAIN BOYS' LOCKER ROOM 143, 1ST FLOOR INITIAL DRAW	16.7	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JAMES LICK MS

Micro Log In **47942**
Total Samples 17
Date Sampled 8/23/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 11 Micro 47942-11 DRINKING FOUNTAIN CORRIDOR C90 2ND FLOOR INITIAL DRAW	3.5	1.0	
Client # 12 Micro 47942-12 DRINKING FOUNTAIN CORRIDOR C90 EAST SIDE 2ND FLOOR INITIAL DRAW	1.7	1.0	
Client # 13 Micro 47942-13 SINK FAUCET TEACHERS' LUNCH ROOM 223 2ND FLOOR INITIAL DRAW	11.5	1.0	
Client # 14 Micro 47942-14 DRINKING FOUNTAIN CORRIDOR C90, THIRD FLOOR INITIAL DRAW	2.5	1.0	
Client # 15 Micro 47942-15 DRINKING FOUNTAIN CORRIDOR C90, 3RD FLOOR INITIAL DRAW	2.3	1.0	

Technical Supervisor: 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JAMES LICK MS

Micro Log In **47942**
Total Samples **17**
Date Sampled **8/23/97**
Date Received **8/29/97**
Date Analyzed **9/2/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 16 Micro 47942-16 DRINKING FOUNTAIN ROOM 152, FIRST FLOOR INITIAL DRAW	10.6	1.0	
Client # 17 Micro 47942-17 BLANK	< 1.0	1.0	

Technical Supervisor: 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
J. LICKS MS

Micro Log In **49319**
Total Samples 9
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **1A** Micro 49319-01 **MULTIPLE DRINKING FOUNTAIN EXT YARD FOLLOW- UP**	**4.0**	1.0	
Client **1B** Micro 49319-02 **MULTIPLE DRINKING FOUNTAIN EXT YARD FOLLOW- UP**	**3.2**	1.0	
Client **10A** Micro 49319-03 **DRINKING FOUNTAIN R-130 GIRL'S LOCKER ROOM FOLLOW- UP**	**3.8**	1.0	
Client **10B** Micro 49319-04 **DRINKING FOUNTAIN R-130 GIRL'S LOCKER ROOM FOLLOW- UP**	**3.3**	1.0	
Client **13A** Micro 49319-05 **SINK FAUCET R-223 TEACHER LUNCH ROOM FOLLOW- UP**	**1.2**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
J. LICKS MS

Micro Log In **49319**
Total Samples 9
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **13B** Micro 49319-06 **SINK FAUCET** **R-223 TEACHER LUNCH ROOM** **FOLLOW- UP**	**1.6**	1.0	
Client **1C** Micro 49319-07 **MULTIPLE DRINKING FOUNTAIN** **EXT YARD** **FOLLOW- UP**	**3.5**	1.0	
Client **10C** Micro 49319-08 **DRINKING FOUNTAIN** **R-130 GIRL'S LOCKER ROOM** **FOLLOW- UP**	**3.9**	1.0	
Client **30** Micro 49319-09 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Client Proj. ID: Lilienthal/3630 Divisadero
Lab Proj. ID: 9708A93

Attention: Bruce Giannini

Sampled: 08/20/97
Received: 08/21/97
Analyzed: see below
Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708A93-01 Sample Desc : **LIQUID,Lilienthal 1**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-02 Sample Desc : **LIQUID,Lilienthal 1 duplicate**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-03 Sample Desc : **LIQUID,Lilienthal 2**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-04 Sample Desc : **LIQUID,Lilienthal 2 duplicate**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-05 Sample Desc : **LIQUID,Lilienthal 3**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-06 Sample Desc : **LIQUID,Lilienthal 4**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-07 Sample Desc : **LIQUID,Lilienthal 5**				
Lead	mg/L	08/22/97	0.0050	N.D.

D

D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Lilienthal/3630 Divisadero

Lab Proj. ID: 9708A93

Sampled: 08/20/97
Received: 08/21/97
Analyzed: see below

Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708A93-08 Sample Desc : LIQUID,Lilienthal 6				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-09 Sample Desc : LIQUID,Lilienthal 7				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-10 Sample Desc : LIQUID,Lilienthal 8				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-11 Sample Desc : LIQUID,Lilienthal 9				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-12 Sample Desc : LIQUID,Lilienthal 10				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-13 Sample Desc : LIQUID,Lilienthal 11				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-14 Sample Desc : LIQUID,Lilienthal 12				
Lead	mg/L	08/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Lilienthal/3630 Divisadero

Lab Proj. ID: 9708A93

Sampled: 08/20/97
Received: 08/21/97
Analyzed: see below

Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708A93-15 Sample Desc : **LIQUID,Lilienthal 13**				
Lead	**mg/L**	**08/22/97**	**0.0050**	**0.0064**
Lab No: 9708A93-16 Sample Desc : **LIQUID,Lilienthal 14**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-17 Sample Desc : **LIQUID,Lilienthal 15**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-18 Sample Desc : **LIQUID,Lilienthal 16**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-19 Sample Desc : **LIQUID,Lilienthal 17**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A93-20 Sample Desc : **LIQUID,Lilienthal 18**				
Lead	**mg/L**	**08/22/97**	**0.0050**	**0.0066**
Lab No: 9708A93-21 Sample Desc : **LIQUID,Lilienthal 19**				
Lead	mg/L	08/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Lilienthal/3630 Divisadero

Lab Proj. ID: 9708A93

Sampled: 08/20/97
Received: 08/21/97
Analyzed: see below

Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results	
Lab No: 9708A93-22 Sample Desc : LIQUID,Lilienthal 20					
Lead	mg/L	08/22/97	0.0050	N.D.	
Lab No: 9708A93-23 Sample Desc : LIQUID,Lilienthal 21					
Lead	mg/L	08/22/97	0.0050	N.D.	
Lab No: 9708A93-24 Sample Desc : LIQUID,Lilienthal 22					
Lead	mg/L	08/22/97	0.0050	N.D.	
Lab No: 9708A93-25 Sample Desc : LIQUID,Lilienthal 23					
Lead	mg/L	08/22/97	0.0050	N.D.	
Lab No: 9708A93-26 Sample Desc : LIQUID,Lilienthal 24					
Lead	mg/L	08/22/97	0.0050	N.D.	B
Lab No: 9708A93-27 Sample Desc : LIQUID,Lilienthal 25					
Lead	**mg/L**	**08/22/97**	**0.0050**	**0.032**	S
Lab No: 9708A93-28 Sample Desc : LIQUID,Lilienthal 14 Duplicate					
Lead	mg/L	08/22/97	0.0050	N.D.	D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Lilienthal/3630 Divisadero

Lab Proj. ID: 9708A93

Sampled: 08/20/97
Received: 08/21/97
Analyzed: see below

Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708A93-29				
Sample Desc : LIQUID,Lilienthal 23 Duplicate				
Lead	mg/L	08/22/97	0.0050	N.D.

D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLAIRE LILIEN THAL ES ANNEX

Micro Log In 59833
Total Samples 10
Date Sampled 9/1/98
Date Received 9/2/98
Date Analyzed 9/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 59833-01 LILIEN THAL ESA SINK FAUCET, KITCHEN	1	1	
Client 6 A Micro 59833-02 LILIEN THAL ESA SINK FAUCET, KITCHEN			NOT ANALYZED
Client 6 B Micro 59833-03 LILIEN THAL ESA SINK FAUCET, KITCHEN			NOT ANALYZED
Client 4 Micro 59833-04 LILIEN THAL ESA SINK DF, CLASSROOM 13	< 1	1	
Client 4 A Micro 59833-05 LILIEN THAL ESA SINK DF, ROOM 13			NOT ANALYZED

Technical Supervisor: 9/3/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
CLAIRE LILIEN THAL ES ANNEX

Micro Log In 59833
Total Samples 10
Date Sampled 9/1/98
Date Received 9/2/98
Date Analyzed 9/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 4B Micro 59833-06 LILIEN THAL ESA SINK DF, ROOM 13			NOT ANALYZED
Client: 5 Micro 59833-07 LILIEN THAL ESA SINK DF, ROOM 12	< 1	1	
Client: 5A Micro 59833-08 LILIEN THAL ESA SINK DF, ROOM 12			NOT ANALYZED
Client: 5B Micro 59833-09 LILIEN THAL ESA SINK DF, ROOM 12			NOT ANALYZED
Client: BLANK Micro 59833-10 LILIEN THAL ESA BLANK	< 1	1	

Technical Supervisor: F.R. 9/3/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 60355-01 SINK FAUCET KITCHEN	2	1	
Client 1A Micro 60355-02 SINK FAUCET KITCHEN			NOT ANALYZED
Client 1B Micro 60355-03 SINK FAUCET KITCHEN			NOT ANALYZED
Client 2 Micro 60355-04 SINK FAUCET KITCHEN	1	1	
Client 2A Micro 60355-05 SINK FAUCET KITCHEN			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 9/29/98 Analyst: FR

Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 2B Micro 60355-06 SINK FAUCET KITCHEN			NOT ANALYZED
Client 3 Micro 60355-07 DRINKING FOUNTAIN TOP FLOOR - NORTH	1	1	
Client 3A Micro 60355-08 DRINKING FOUNTAIN TOP FLOOR - NORTH			NOT ANALYZED
Client 3B Micro 60355-09 DRINKING FOUNTAIN TOP FLOOR - NORTH			NOT ANALYZED
Client 4 Micro 60355-10 DRINKING FOUNTAIN TOP FLOOR HALL - SOUTH	2	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 4A Micro 60355-11 DRINKING FOUNTAIN TOP FLOOR HALL - SOUTH			NOT ANALYZED
Client 4B Micro 60355-12 DRINKING FOUNTAIN TOP FLOOR HALL - SOUTH			NOT ANALYZED
Client 5 Micro 60355-13 DRINKING FOUNTAIN 2ND FLOOR HALL - SOUTH	2	1	
Client 5A Micro 60355-14 DRINKING FOUNTAIN 2ND FLOOR HALL - SOUTH			NOT ANALYZED
Client 5B Micro 60355-15 DRINKING FOUNTAIN 2ND FLOOR HALL - SOUTH			NOT ANALYZED

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 60355-16 DRINKING FOUNTAIN 2ND FLOOR HALL - NORTH	1	1	
Client 6A Micro 60355-17 DRINKING FOUNTAIN 2ND FLOOR HALL - NORTH			NOT ANALYZED
Client 6B Micro 60355-18 DRINKING FOUNTAIN 2ND FLOOR HALL - NORTH			NOT ANALYZED
Client 7 Micro 60355-19 DRINKING FOUNTAIN N.E. 1ST FLOOR	1	1	
Client 7A Micro 60355-20 DRINKING FOUNTAIN N.E. 1ST FLOOR			NOT ANALYZED

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 7 B Micro 60355-21 DRINKING FOUNTAIN N.E. 1ST FLOOR			NOT ANALYZED
Client 8 Micro 60355-22 DRINKING FOUNTAIN N.N.E. 1ST FLOOR	< 1	1	
Client 8 A Micro 60355-23 DRINKING FOUNTAIN N.N.E. 1ST FLOOR			NOT ANALYZED
Client 8 B Micro 60355-24 DRINKING FOUNTAIN N.N.E. 1ST FLOOR			NOT ANALYZED
Client 9 Micro 60355-25 DRINKING FOUNTAIN NORTH 1ST FLOOR	2	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 9A Micro 60355-26 DRINKING FOUNTAIN NORTH 1ST FLOOR			NOT ANALYZED
Client 9B Micro 60355-27 DRINKING FOUNTAIN NORTH 1ST FLOOR			NOT ANALYZED
Client 10 Micro 60355-28 DRINKING FOUNTAIN 1ST FLOOR MAIN HALL - N	< 1	1	
Client 10A Micro 60355-29 DRINKING FOUNTAIN 1ST FLOOR MAIN HALL - N			NOT ANALYZED
Client 10B Micro 60355-30 DRINKING FOUNTAIN 1ST FLOOR MAIN HALL - N			NOT ANALYZED

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 11 Micro 60355-31 DRINKING FOUNTAIN 1ST FLOOR - SOUTH	2	1	
Client: 11A Micro 60355-32 DRINKING FOUNTAIN 1ST FLOOR - SOUTH			NOT ANALYZED
Client: 11B Micro 60355-33 DRINKING FOUNTAIN 1ST FLOOR - SOUTH			NOT ANALYZED
Client: BLANK Micro 60355-34 BLANK	< 1	1	
Client: 12 Micro 60355-35 DRINKING FOUNTAIN 2ND - N.W.	2	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 12A Micro 60355-36 DRINKING FOUNTAIN 2ND - N.N.			NOT ANALYZED
Client 12B Micro 60355-37 DRINKING FOUNTAIN 2ND - N.N.			NOT ANALYZED
Client 13 Micro 60355-38 DRINKING FOUNTAIN 2ND - N.N.E.	5	1	
Client 13A Micro 60355-39 DRINKING FOUNTAIN 2ND - N.N.E.			NOT ANALYZED
Client 13B Micro 60355-40 DRINKING FOUNTAIN 2ND - N.N.E.			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 9/29/98 Analyst: FR

Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 14 Micro 60355-41 SINK FAUCET ROOM 102	2	1	
Client 14A Micro 60355-42 SINK FAUCET ROOM 102			NOT ANALYZED
Client 14B Micro 60355-43 SINK FAUCET ROOM 102			NOT ANALYZED
Client 15 Micro 60355-44 SINK FAUCET ROOM 104	< 1	1	
Client 15A Micro 60355-45 SINK FAUCET ROOM 104			NOT ANALYZED

Technical Supervisor: F. Ramazanzadeh 9/29/98 Analyst: FR
Farid Ramazanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 15B Micro 60355-46 SINK FAUCET ROOM 104			NOT ANALYZED
Client 16 Micro 60355-47 SINK FAUCET ROOM 106	< 1	1	
Client 16A Micro 60355-48 SINK FAUCET ROOM 106			NOT ANALYZED
Client 16B Micro 60355-49 SINK FAUCET ROOM 106			NOT ANALYZED
Client 17 Micro 60355-50 SINK FAUCET ROOM 125	3	1	

Technical Supervisor: F. R. 9/29/98 Analyst: FR

Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 17A Micro 60355-51 SINK FAUCET ROOM 126			NOT ANALYZED
Client 18 Micro 60355-52 SINK FAUCET ROOM 126	3	1	
Client 18A Micro 60355-53 SINK FAUCET ROOM 126			NOT ANALYZED
Client 19 Micro 60355-54 SINK FAUCET ROOM 126	1	1	
Client 19A Micro 60355-55 SINK FAUCET ROOM 126			NOT ANALYZED

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1097. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 20 Micro 60355-56 SINK FAUCET ROOM 125	< 1	1	
Client 20A Micro 60355-57 SINK FAUCET ROOM 126			NOT ANALYZED
Client 21 Micro 60355-58 SINK FAUCET ROOM 126	1	1	
Client 21A Micro 60355-59 SINK FAUCET ROOM 126			NOT ANALYZED
Client 22 Micro 60355-60 SINK FAUCET ROOM 126	< 1	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 22A Micro 60355-61 SINK FAUCET ROOM 126			NOT ANALYZED
Client 23 Micro 60355-62 SINK FAUCET ROOM 126 - NORTH SINK DRINKING FOUNTAIN	3	1	
Client 23A Micro 60355-63 SINK FAUCET ROOM 126 - NORTH SINK DRINKING FOUNTAIN			NOT ANALYZED
Client 24 Micro 60355-64 DRINKING FOUNTAIN BASEMENT HALL	2	1	
Client 24A Micro 60355-65 DRINKING FOUNTAIN BASEMENT HALL			NOT ANALYZED

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 24B Micro 60355-66 DRINKING FOUNTAIN BASEMENT HALL			NOT ANALYZED
Client 25 Micro 60355-67 DRINKING FOUNTAIN BLDG. B, BASEMENT - E	4	1	
Client 25A Micro 60355-68 DRINKING FOUNTAIN BLDG. B, BASEMENT - E			NOT ANALYZED
Client 25B Micro 60355-69 DRINKING FOUNTAIN BLDG. B, BASEMENT - E			NOT ANALYZED
Client 26 Micro 60355-70 DRINKING FOUNTAIN BLDG. B - BASEMENT	2	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 26A Micro 60355-71 DRINKING FOUNTAIN BLDG. B - BASEMENT			NOT ANALYZED
Client 26B Micro 60355-72 DRINKING FOUNTAIN BLDG. B - BASEMENT			NOT ANALYZED
Client 27 Micro 60355-73 DRINKING FOUNTAIN WRESTLING ROOM	3	1	
Client 27A Micro 60355-74 DRINKING FOUNTAIN WRESTLING ROOM			NOT ANALYZED
Client 27B Micro 60355-75 DRINKING FOUNTAIN WRESTLING ROOM			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 28 Micro 60355-76 SINK FAUCET ROOM 226	3	1	
Client 28A Micro 60355-77 SINK FAUCET ROOM 226			NOT ANALYZED
Client 28B Micro 60355-78 SINK FAUCET ROOM 226			NOT ANALYZED
Client 29 Micro 60355-79 SINK FAUCET ROOM 128A	2	1	
Client 29A Micro 60355-80 SINK FAUCET ROOM 128A			NOT ANALYZED

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LINCOLN HS

Micro Log In 60355
Total Samples 81
Date Sampled 9/18/98
Date Received 9/18/98
Date Analyzed 9/23/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 29B Micro 60355-81 SINK FAUCET ROOM 128A			NOT ANALYZED

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Log Cabin Ranch

Lab Proj. ID: 9711282

Sampled: 11/07/97
Received: 11/07/97
Analyzed: see below

Reported: 11/10/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9711282-01 Sample Desc : LIQUID,1				
Lead	mg/L	11/10/97	0.0050	N.D.
Lab No: 9711282-02 Sample Desc : LIQUID,2				
Lead	mg/L	11/10/97	0.0050	N.D.
Lab No: 9711282-03 Sample Desc : LIQUID,3				
Lead	mg/L	11/10/97	0.0050	N.D.
Lab No: 9711282-04 Sample Desc : LIQUID,4				
Lead	mg/L	11/10/97	0.0050	N.D.
Lab No: 9711282-05 Sample Desc : LIQUID,5				
Lead	mg/L	11/10/97	0.0050	N.D.
Lab No: 9711282-06 Sample Desc : LIQUID,6				
Lead	mg/L	11/10/97	0.0050	N.D.
Lab No: 9711282-07 Sample Desc : LIQUID,7				
Lead	mg/L	11/10/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Log Cabin Ranch

Lab Proj. ID: 9711282

Sampled: 11/07/97
Received: 11/07/97
Analyzed: see below

Reported: 11/10/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9711282-08 Sample Desc : LIQUID,8				
Lead	mg/L	11/10/97	0.0050	0.024
Lab No: 9711282-09 Sample Desc : LIQUID,8-Duplicate				
Lead	mg/L	11/10/97	0.0050	0.025
Lab No: 9711282-10 Sample Desc : LIQUID,9-Blank				
Lead	mg/L	11/10/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LONGFELLOW ES

Micro Log In **47741**
Total Samples 12
Date Sampled 8/22/97
Date Received 8/25/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47741-01 SINK FAUCET 1ST LEVEL KITCHEN FIRST DRAW	1.5	1.0	
Client 2 Micro 47741-02 DRINKING FOUNTAIN 1ST LEVEL HALL FIRST DRAW	< 1.0	1.0	
Client 3 Micro 47741-03 DRINKING FOUNTAIN IST LEVEL HALL FIRST DRAW	1.9	1.0	
Client 4 Micro 47741-04 DRINKING FOUNTAIN 2ND LEVEL HALL FIRST DRAW	< 1.0	1.0	
Client 5 Micro 47741-05 DRINKING FOUNTAIN 2ND LEVEL HALL FIRST DRAW	1.2	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LONGFELLOW ES

Micro Log In **47741**
Total Samples **12**
Date Sampled **8/22/97**
Date Received **8/25/97**
Date Analyzed **9/1/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47741-06 DRINKING FOUNTAIN BASEMENT LEVEL HALL FIRST DRAW	1.6	1.0	
Client 7 Micro 47741-07 MULTIPLE DRINKING FOUNTAIN PLAY YARD FIRST DRAW	3.5	1.0	
Client 8 Micro 47741-08 MULTIPLE DRINKING FOUNTAIN PLAY YARD FIRST DRAW	< 1.0	1.0	
Client 9 Micro 47741-9 DRINKING FOUNTAIN 1ST LEVEL CLASSROOM #11 FIRST DRAW	2.1	1.0	
Client 10 Micro 47741-10 DRINKING FOUNTAIN 1ST LEVEL CLASSROOM #109	1.2	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LONGFELLOW ES

Micro Log In **47741**
Total Samples 12
Date Sampled 8/22/97
Date Received 8/25/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **B** Micro 47741-11 **BLANK**	< **1.0**	1.0	
Client **11** Micro 47741-12 **SPIKED**	**57.6**	2.2	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LOWELL HIGH SCHOOL

Micro Log In **48769**
Total Samples **16**
Date Sampled **9/22/97**
Date Received **9/23/97**
Date Analyzed **9/23/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **697-1** Micro 48769-01 DRINKING FOUNTAIN CORRIDOR C90B ADJACENT TO ROOM 129 FIRST DRAW	**5.0**	1.0	
Client **697-2** Micro 48769-02 DRINKING FOUNTAIN CORRIDOR C92 ADJACENT TO ROOM 112A FIRST DRAW	**< 1.0**	1.0	
Client **697-3** Micro 48769-03 DRINKING FOUNTAIN CORRIDOR C90C ADJACENT TO ROOM 142 FIRST DRAW	**12.9**	1.0	
Client **697-4** Micro 48769-04 DRINKING FOUNTAIN CORRIDOR C90A ADJACENT TO ROOM 251 FIRST DRAW	**1.4**	1.0	
Client **697-5** Micro 48769-05 DRINKING FOUNTAIN CORRIDOR C90E ADJACENT TO ROOM 771 FIRST DRAW	**3.1**	1.0	

Technical Supervisor: F Ramezanzadeh 9/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LOWELL HIGH SCHOOL

Micro Log In **48769**
Total Samples 16
Date Sampled 9/22/97
Date Received 9/23/97
Date Analyzed 9/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **697-6** Micro 48769-06 **DRINKING FOUNTAIN CORRIDOR C90 ADJACENT TO ROOM T69 FIRST DRAW**	**1.6**	1.0	
Client **697-7** Micro 48769-07 **DRINKING FOUNTAIN CORRIDOR C91 ADJACENT TO ROOM J213 FIRST DRAW**	**< 1.0**	1.0	
Client **697-8** Micro 48769-08 **DRINKING FOUNTAIN CORRIDOR C90 ADJACENT TO ROOM T72 FIRST DRAW**	**1.4**	1.0	
Client **697-9** Micro 48769-09 **DRINKING FOUNTAIN CORRIDOR C90 ADJACENT TO ROOM 339 FIRST DRAW**	**2.4**	1.0	
Client **697-10** Micro 48769-10 **DRINKING FOUNTAIN CORRIDOR C90 ADJACENT TO ROOM 763 FIRST DRAW**	**< 1.0**	1.0	

Technical Supervisor: 9/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LOWELL HIGH SCHOOL

Micro Log In **48769**
Total Samples 16
Date Sampled 9/22/97
Date Received 9/23/97
Date Analyzed 9/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **697-11** Micro 48769-11 DRINKING FOUNTAIN ROOM 055 CAFETERIA ADJACENT TO ROOM 046 FIRST DRAW	3.9	1.0	
Client **697-12** Micro 48769-12 DRINKING FOUNTAIN CORRIDOR C90A ADJACENT TO ROOM 045 FIRST DRAW	2.6	1.0	
Client **697-13** Micro 48769-13 DRINKING FOUNTAIN CORRIDOR C90A ADJACENT TO ROOM 041 FIRST DRAW	< 1.0	1.0	
Client **697-14** Micro 48769-14 DRINKING FOUNTAIN ROOM 033 GIRLS LOCKER ROOM DRINKING FOUNTAIN FIRST DRAW	4.1	1.0	
Client **697-15** Micro 48769-15 SPIKE #97-W00774-12 SPIKED	21.7	1.0	

Technical Supervisor: 9/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
LOWELL HIGH SCHOOL

Micro Log In **48769**
Total Samples 16
Date Sampled 9/22/97
Date Received 9/23/97
Date Analyzed 9/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 697-16 Micro: 48769-16 **BLANK**	< 1.0	1.0	

Technical Supervisor: _____ 9/23/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1057. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Mahler CC

Lab Proj. ID: 9708C09

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/28/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708C09-01 Sample Desc : LIQUID,Mahler 1				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C09-02 Sample Desc : LIQUID,Mahler 1 Duplicate				
Lead	mg/L	08/28/97	0.0050	N.D. D
Lab No: 9708C09-03 Sample Desc : LIQUID,Mahler 2				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C09-04 Sample Desc : LIQUID,Mahler 3				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708C09-05 Sample Desc : LIQUID,Mahler Blank				
Lead	mg/L	08/28/97	0.0050	N.D. B

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MALCOLM X ACADEMY

Micro Log In **47607**
Total Samples 9
Date Sampled 8/16/97
Date Received 8/21/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **830-1** Micro 47607-01 DRINKING FOUNTAIN C-90 - BASEMENT OUTSIDE 005 FIRST DRAW	**1.7**	1.0	
Client **830-2** Micro 47607-02 SINK FAUCET ROOM 004 - KITCHEN SINK (SOUTH) FIRST DRAW	**7.0**	1.0	
Client **830-3** Micro 47607-03 SINK FAUCET ROOM 004 - KITCHEN SINK (NORTH) FIRST DRAW	**13.7**	1.0	
Client **830-4** Micro 47607-04 DRINKING FOUNTAIN C-90 - BASEMENT OUTSIDE ROOM 014 FIRST DRAW	**2.8**	1.0	
Client **830-5** Micro 47607-05 DRINKING FOUNTAIN C-90 - FIRST FLOOR OUTSIDE ROOM 109 FIRST DRAW	**1.5**	1.0	

Technical Supervisor: F. Ramezanzadeh 8/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MALCOLM X ACADEMY

Micro Log In **47607**
Total Samples 9
Date Sampled 8/16/97
Date Received 8/21/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **830-6** Micro 47607-06 **DRINKING FOUNTAIN C-90 - FIRST FLOOR OUTSIDE ROOM 103 FIRST DRAW**	< 1.0	1.0	
Client **830-7** Micro 47607-07 **MULTIPLE DRINKING FOUNTAIN OUTSIDE IN PLAYGROUND @ ONE DRINKING FOUNTAIN / ONE FOUNTAIN NON-OPERATIONAL FIRST DRAW**	1.6	1.0	
Client **830-8** Micro 47607-08 **MULTIPLE DRINKING FOUNTAIN C-92 - OUTSIDE 204 @ ONE DRINKING FOUNTAIN (3 TAPS) FIRST DRAW**	8.5	1.0	
Client **830-9** Micro 47607-09 **BLANK**	< 1.0	1.0	

Technical Supervisor: 8/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MALCOLM X
B.-2243

Micro Log In **50765**
Total Samples 4
Date Sampled 11/12/97
Date Received 11/18/97
Date Analyzed 11/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **830-3A** Micro 50765-01 **SINK FAUCET - ROOM 004 KITCHENSINK FAUCET 1ST DRAW**	**2.1**	1.0	
Client **830-3B** Micro 50765-02 **SINK FAUCET - ROOM 004 KITCHENSINK FAUCET 2ND DRAW**	**1.8**	1.0	
Client **830-3C** Micro 50765-03 **SINK FAUCET - ROOM 004 KITCHENSINK FAUCET 3RD DRAW**	**3.8**	1.0	
Client **830-BLANK** Micro 50765-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 11/19/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HORACE MANN

Micro Log In **48520**
Total Samples 13
Date Sampled 9/15/97
Date Received 9/15/97
Date Analyzed 9/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 618-1 Micro 48520-01 DRINKING FOUNTAIN DRINKING FOUNTAIN AT MAIN ENTRANCE OF FACILITY FIRST DRAW	1.2	1.0	
Client 618-2 Micro 48520-02 DRINKING FOUNTAIN DRINKING FOUNTAIN ADJACENT TO ROOM 102 IN CORRIDOR C90 FIRST DRAW	1.1	1.0	
Client 618-3 Micro 48520-03 DRINKING FOUNTAIN DRINKING FOUNTAIN ADJACENT TO ROOM 114 IN CORRIDOR C90 FIRST DRAW	1.3	1.0	
Client 618-4 Micro 48520-04 DRINKING FOUNTAIN DRINKING FOUNTAIN LOCATED IN CORRIDOR C92 2ND FOUNTAIN FROM LEFT FIRST DRAW	< 1.0	1.0	
Client 618-5 Micro 48520-05 DRINKING FOUNTAIN DRINKING FOUNTAIN LOCATED ADJACENT TO ROOM 152 IN CORRIDOR C95 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HORACE MANN

Micro Log In **48520**
Total Samples 13
Date Sampled 9/15/97
Date Received 9/15/97
Date Analyzed 9/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **618-6** Micro 48520-06 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN LOCATED ADJACENT TO ROOM 152 IN CORRIDOR C92** **FIRST DRAW**	< **1.0**	1.0	
Client **618-7** Micro 48520-07 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN LOCATED IN CORRIDOR** **C95 ADJACENT TO ROOM 251** **FIRST DRAW**	< **1.0**	1.0	
Client **618-8** Micro 48520-08 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN IN C95 ADJACENT TO ROOM 251** **FIRST DRAW**	< **1.0**	1.0	
Client **618-9** Micro 48520-09 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN IN CORRIDOR C90 ADJACENT TO ROOM 202** **FIRST DRAW**	< **1.0**	1.0	
Client **618-10** Micro 48520-10 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN LOCATED IN CORRIDOR** **C90 ADJACENT TO ROOM 202** **FIRST DRAW**	< **1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
HORACE MANN

Micro Log In **48520**
Total Samples 13
Date Sampled 9/15/97
Date Received 9/15/97
Date Analyzed 9/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **618-11** Micro 48520-11 **DRINKING FOUNTAIN DRINKING FOUNTAIN LOCATED IN CORRIDOR C90 ADJACENT TO ROOM 302 FIRST DRAW**	< 1.0	1.0	
Client **618-12** Micro 48520-12 **SAMPLE #97-W00-794-2 SPIKED**	20.9	1.0	
Client **618-13** Micro 48520-13 **BLANK**	< 1.0	1.0	

Technical Supervisor: _____ 9/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MARINA JH

Micro Log In **47744**
Total Samples 20
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47744-01 **BLANK**	< 1.0	1.0	
Client 2 Micro 47744-02 **DRINKING FOUNTAIN FIRST FLOOR OUTSIDE ROOM 104 FIRST DRAW**	2.4	1.0	
Client 3 Micro 47744-03 **SINK FAUCET FIRST FLOOR - ROOM104 - COOKING ROOM FIRST DRAW**	1.8	1.0	
Client 4 Micro 47744-04 **SINK FAUCET FIRST FLOOR - ROOM104 - COOKING ROOM FIRST DRAW**	1.9	1.0	
Client 5 Micro 47744-05 **SINK FAUCET FIRST FLOOR - ROOM104 - COOKING ROOM FIRST DRAW**	4.4	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MARINA JH

Micro Log In 47744
Total Samples 20
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47744-06 SINK FAUCET FIRST FLOOR - ROOM104 - COOKING ROOM FIRST DRAW	1.5	1.0	
Client 7 Micro 47744-07 SINK FAUCET FIRST FLOOR - ROOM104 - COOKING ROOM FIRST DRAW	2.4	1.0	
Client 8 Micro 47744-08 SINK FAUCET FIRST FLOOR - ROOM104 - COOKING ROOM FIRST DRAW	< 1.0	1.0	
Client 9 Micro 47744-09 DRINKING FOUNTAIN FIRST FLOOR OUTSIDE ROOM 150 FIRST DRAW	6.5	1.0	
Client 10 Micro 47744-10 DRINKING FOUNTAIN FIRST FLOOR OUTSIDE OF BUILDING OUTSIDE RM.150 FIRST DRAW	2.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNSET ES

Micro Log In 50653
Total Samples 12
Date Sampled 11/12/97
Date Received 11/14/97
Date Analyzed 11/14/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 7C Micro 53653-06 DRINKING FOUNTAIN ROOM 005 - EAST WALL BLANK	9.4	1.0	
Client 10A Micro 53653-07 DRINKING FOUNTAIN ROOM 001 - WEST HALL BLANK	13.4	1.0	
Client 10B Micro 53653-08 DRINKING FOUNTAIN ROOM 001 - WEST HALL BLANK	14.0	1.0	
Client 10C Micro 53653-09 DRINKING FOUNTAIN ROOM 001 - WEST HALL BLANK	8.6	1.0	
Client 11A Micro 53653-10 MUTIPLE DRINKING FOUNTAIN OUTSIDE BY SAND BOX NEXT BLANK	3.6	1.0	

Technical Supervisor: F. Ramezanzadeh 11/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNSET ES

Micro Log In **50653**
Total Samples 12
Date Sampled 11/12/97
Date Received 11/14/97
Date Analyzed 11/14/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **11B** Micro 53653-11 **MUTIPLE DRINKING FOUNTAIN OUTSIDE BY SAND BOX NEXT BLANK**	**2.4**	1.0	
Client **11C** Micro 53653-12 **MUTIPLE DRINKING FOUNTAIN OUTSIDE BY SAND BOX NEXT BLANK**	**12.2**	1.0	

Technical Supervisor: _____ 11/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNSHINE HS

Micro Log In **48024**
Total Samples 7
Date Sampled 8/26/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48024-01 **SINK FAUCET** **KITCHEN - 1ST FLOOR NORTH** **FIRST DRAW**	**6.6**	1.0	
Client 2 Micro 48024-02 **SINK FAUCET** **KITCHEN - ROOM 4** **FIRST DRAW**	**3.3**	1.0	
Client 3 Micro 48024-03 **FIELD BLANK**	**< 1.0**	1.0	
Client 4 Micro 48024-04 **SINK FAUCET** **ROOM 15 "POOL"** **FIRST DRAW**	**1.7**	1.0	
Client 5 Micro 48024-05 **SINK FAUCET** **KITCHEN OF SEWING ROOM** **N.W CORNER - 1ST FLOOR** **FIRST DRAW**	**5.0**	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNSHINE HS

Micro Log In **48024**
Total Samples 7
Date Sampled 8/26/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 48024-06 DRINKING FOUNTAIN 2ND FLOOR HALL S.W CORNER FIRST DRAW	3.1	1.0	
Client 7 Micro 48024-07 WATER-COOLED DRINKING FOUNTAIN 2ND FLOOR HALL N.E CORNER FIRST DRAW	1.6	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MARINA JH

Micro Log In **47744**
Total Samples 20
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47744-11 DRINKING FOUNTAIN THIRD FLOOR OUTSIDE ROOM 306 FIRST DRAW	2.7	1.0	
Client 13 Micro 47744-12 DRINKING FOUNTAIN SECOND FLOOR OUTSIDE ROOM 213 FIRST DRAW	3.0	1.0	
Client 14 Micro 47744-13 DRINKING FOUNTAIN SECOND FLOOR OUTSIDE ROOM 208 FIRST DRAW	2.9	1.0	
Client 15 Micro 47744-14 DRINKING FOUNTAIN SECOND FLOOR OUTSIDE ROOM 217 FIRST DRAW	10.3	1.0	
Client 16 Micro 47744-15 DRINKING FOUNTAIN SECOND FLOOR INSIDE ROOM 03B FIRST DRAW	8.6	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MARINA JH

Micro Log In 47744
Total Samples 20
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 17 Micro 47744-16 DRINKING FOUNTAIN FIRST FLOOR ROOM 036 FIRST DRAW	12.7	1.0	
Client 18 Micro 47744-17 MULTIPLE DRINKING FOUNTAIN FIRST FLOOR OUTSIDE OF BLDG. ROOM 980 FIRST DRAW	2.0	1.0	
Client 19 Micro 47744-18 DRINKING FOUNTAIN FIRST FLOOR OUTSIDE ROOM 117 FIRST DRAW	1.5	1.0	
Client 20 Micro 47744-19 DRINKING FOUNTAIN FIRST FLOOR INSIDE ROOM 01B FIRST DRAW	1.8	1.0	
Client 21 Micro 47744-20 DRINKING FOUNTAIN FIRST FLOOR OUTSIDE OF ROOM 002 FIRST DRAW	16.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MARINA JH

Micro Log In **49188**
Total Samples 4
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **17A** Micro 49188-01 **DRINKING FOUNTAIN FIRST FLOOR, ROOM 03G FIRST DRAW**	< **1.0**	1.0	
Client **17B** Micro 49188-01 **DRINKING FOUNTAIN FIRST FLOOR, ROOM 03G FIRST DRAW**	< **1.0**	1.0	
Client **17C** Micro 49188-01 **DRINKING FOUNTAIN FIRST FLOOR, ROOM 03G FIRST DRAW**	< **1.0**	1.0	
Client **BLANK** Micro 49188-01 **BLANK**	< **1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Marshall Elementary

Lab Proj. ID: 9708D25

Sampled: 08/23/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D25-01 Sample Desc : LIQUID,Marshall 1				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0052**
Lab No: 9708D25-02 Sample Desc : LIQUID,Marshall 1 Duplicate				
Lead	mg/L	08/28/97	0.0050	N.D. D
Lab No: 9708D25-03 Sample Desc : LIQUID,Marshall 2				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-04 Sample Desc : LIQUID,Marshall 2 Duplicate				
Lead	mg/L	08/28/97	0.0050	N.D. D
Lab No: 9708D25-05 Sample Desc : LIQUID,Marshall 3				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-06 Sample Desc : LIQUID,Marshall 4				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0072**
Lab No: 9708D25-07 Sample Desc : LIQUID,Marshall 5				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Marshall Elementary

Lab Proj. ID: 9708D25

Sampled: 08/23/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D25-08 Sample Desc : **LIQUID,Marshall 6**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-09 Sample Desc : **LIQUID,Marshall 7**				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0076**
Lab No: 9708D25-10 Sample Desc : **LIQUID,Marshall 8**				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0093**
Lab No: 9708D25-11 Sample Desc : **LIQUID,Marshall 9**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-12 Sample Desc : **LIQUID,Marshall 10**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-13 Sample Desc : **LIQUID,Marshall 11**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-14 Sample Desc : **LIQUID,Marshall 12**				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0082**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Marshall Elementary

Lab Proj. ID: 9708D25

Sampled: 08/23/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D25-15 Sample Desc : LIQUID,Marshall 13				
Lead	mg/L	08/28/97	0.0050	0.0066
Lab No: 9708D25-16 Sample Desc : LIQUID,Marshall 14				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-17 Sample Desc : LIQUID,Marshall 15				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-18 Sample Desc : LIQUID,Marshall 16				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-19 Sample Desc : LIQUID,Marshall 17				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-20 Sample Desc : LIQUID,Marshall 18				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D25-21 Sample Desc : LIQUID,Marshall Blank				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Marshall Elementary

Lab Proj. ID: 9708D25

Sampled: 08/23/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D25-22 Sample Desc : LIQUID,Marshall 19				
Lead	mg/L	08/28/97	0.0050	0.048

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
THURGOOD MARSHALL HS

Micro Log In **48050**
Total Samples **19**
Date Sampled **8/26/97**
Date Received **9/3/97**
Date Analyzed **9/3/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **THURGOOD M. 1** Micro 48050-01 **DRINKING FOUNTAIN** **C90** **FIRST DRAW**	**3.0**	1.0	
Client **THURGOOD M. 2** Micro 48050-02 **DRINKING FOUNTAIN** **C90** **FIRST DRAW**	**13.3**	1.0	
Client **THURGOOD M. 3** Micro 48050-03 **DRINKING FOUNTAIN** **C90** **FIRST DRAW**	**11.0**	1.0	
Client **THURGOOD M. 4** Micro 48050-04 **DRINKING FOUNTAIN** **RM. 128 (CAF.)** **FIRST DRAW**	**11.3**	1.0	
Client **THURGOOD M. 5** Micro 48050-05 **DRINKING FOUNTAIN** **RM. 128 (CAF.)** **FIRST DRAW**	**44.4**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
THURGOOD MARSHALL HS

Micro Log In **48050**
Total Samples 19
Date Sampled 8/26/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **THURGOOD M. 6** Micro 48050-06 **DRINKING FOUNTAIN** **C90** **FIRST DRAW**	**5.4**	1.0	
Client **THURGOOD M. 7** Micro 48050-07 **DRINKING FOUNTAIN** **C90** **FIRST DRAW**	**2.9**	1.0	
Client **THURGOOD M. 8** Micro 48050-08 **DRINKING FOUNTAIN** **C90** **FIRST DRAW**	**1.8**	1.0	
Client **THURGOOD M. 9** Micro 48050-09 **DRINKING FOUNTAIN** **C90** **FIRST DRAW**	**18.0**	1.0	
Client **THURGOOD M. 10** Micro 48050-10 **DRINKING FOUNTAIN** **C90** **FIRST DRAW**	**3.1**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
THURGOOD MARSHALL HS

Micro Log In **48050**
Total Samples **19**
Date Sampled **8/26/97**
Date Received **9/3/97**
Date Analyzed **9/3/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **THURGOOD M. 11** Micro 48050-11 DRINKING FOUNTAIN BG1 FIRST DRAW	7.1	1.0	
Client **THURGOOD M. 12** Micro 48050-12 DRINKING FOUNTAIN GG1 FIRST DRAW	9.8	1.0	
Client **THURGOOD M. 13** Micro 48050-13 DRINKING FOUNTAIN BG2 FIRST DRAW	12.8	1.0	
Client **THURGOOD M. 14** Micro 48050-14 DRINKING FOUNTAIN GG2 FIRST DRAW	20.8	1.0	
Client **THURGOOD M. 15** Micro 48050-15 DRINKING FOUNTAIN CB3 FIRST DRAW	41.7	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
THURGOOD MARSHALL HS

Micro Log In **48050**
Total Samples 19
Date Sampled 8/26/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **THURGOOD M. 16** Micro 48050-16 **SINK FAUCET** **124E** **FIRST DRAW**	**2.4**	1.0	
Client **THURGOOD M. 17** Micro 48050-17 **DRINKING FOUNTAIN** **C86** **FIRST DRAW**	**14.3**	1.0	
Client **THURGOOD M. 18** Micro 48050-18 **SINK FAUCET** **127 A** **FIRST DRAW**	**21.3**	1.0	
Client **THURGOOD M. 19** Micro 48050-19 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Marshall HS

Lab Proj. ID: 9710514

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710514-01 Sample Desc : **LIQUID,Marshall 2-A**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-02 Sample Desc : **LIQUID,Marshall 2-B**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.014**
Lab No: 9710514-03 Sample Desc : **LIQUID,Marshall 2-C**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-04 Sample Desc : **LIQUID,Marshall 5-A**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-05 Sample Desc : **LIQUID,Marshall 5-B**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.010**
Lab No: 9710514-06 Sample Desc : **LIQUID,Marshall 5-C**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-07 Sample Desc : **LIQUID,Marshall 9-A**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.0080**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Marshall HS
Lab Proj. ID: 9710514

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710514-08 Sample Desc : **LIQUID,Marshall 9-B**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.025**
Lab No: 9710514-09 Sample Desc : **LIQUID,Marshall 9-C**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-10 Sample Desc : **LIQUID,Marshall 9-C (duplicate)**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-11 Sample Desc : **LIQUID,Marshall 13-A**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-12 Sample Desc : **LIQUID,Marshall 13-B**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-13 Sample Desc : **LIQUID,Marshall 13-C**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-14 Sample Desc : **LIQUID,Marshall 14-A**				
Lead	mg/L	10/13/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Marshall HS

Lab Proj. ID: 9710514

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710514-15 Sample Desc : **LIQUID,Marshall 14-B**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-16 Sample Desc : **LIQUID,Marshall 14-C**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-17 Sample Desc : **LIQUID,Marshall 15-A**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-18 Sample Desc : **LIQUID,Marshall 15-B**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-19 Sample Desc : **LIQUID,Marshall 15-C**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-20 Sample Desc : **LIQUID,Marshall 15-C (duplicate)**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.0060**
Lab No: 9710514-21 Sample Desc : **LIQUID,Marshall 17-A**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.032**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: Marshall HS
Lab Proj. ID: 9710514

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below
Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710514-22 Sample Desc : **LIQUID,Marshall 17-B**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.0080**
Lab No: 9710514-23 Sample Desc : **LIQUID,Marshall 17-C**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.011**
Lab No: 9710514-24 Sample Desc : **LIQUID,Marshall 18-A**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-25 Sample Desc : **LIQUID,Marshall 18-B**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-26 Sample Desc : **LIQUID,Marshall 18-C**				
Lead	mg/L	10/13/97	0.0050	N.D.
Lab No: 9710514-27 Sample Desc : **LIQUID,Marshall 18-D**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.010**
Lab No: 9710514-28 Sample Desc : **LIQUID,Marshall 18-D (duplicate)**				
Lead	**mg/L**	**10/13/97**	**0.0050**	**0.011**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Marshall HS

Lab Proj. ID: 9710514

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710514-29 Sample Desc : **LIQUID,Marshall Blank**				
Lead	mg/L	10/13/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Florence Martin

Lab Proj. ID: 9708B59

Sampled: 08/18/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B59-01 Sample Desc : **LIQUID,Florence Martin 1**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B59-02 Sample Desc : **LIQUID,Florence Martin 1 Dup**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B59-03 Sample Desc : **LIQUID,Florence Martin 2**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B59-04 Sample Desc : **LIQUID,Florence Martin 3**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B59-05 Sample Desc : **LIQUID,Florence Martin 4**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.018**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCATEER HS

Micro Log In **48240**
Total Samples **17**
Date Sampled **9/6/97**
Date Received **9/6/97**
Date Analyzed **9/6/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48240-01 DRINKING FOUNTAIN AUDITORIUM LOBBY FIRST DRAW	47.4	1.0	
Client 2 Micro 48240-02 SINK FAUCET CAFETERIA KIT. WEST FIRST DRAW	3.4	1.0	
Client 3 Micro 48240-03 SINK FAUCET CAFETERIA KIT. CENTER FIRST DRAW	< 1.0	1.0	
Client 4 Micro 48240-04 SINK FAUCET CAFETERIA KIT. EAST FIRST DRAW	13.9	1.0	
Client 5 Micro 48240-05 DRINKING FOUNTAIN GIRLS' LOCKER ROOM NORTH FIRST DRAW	18.0	1.0	

Technical Supervisor: F. Ramezanzadeh, M.S. 9/8/97 Analyst: AL/SL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCATEER HS

Micro Log In **48240**
Total Samples 17
Date Sampled 9/6/97
Date Received 9/6/97
Date Analyzed 9/6/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 48240-06 DRINKING FOUNTAIN BOYS' LOCKER ROOM NORTH FIRST DRAW	9.9	1.0	
Client 7 Micro 48240-07 DRINKING FOUNTAIN BOYS' LOCKER ROOM SOUTH FIRST DRAW	3.9	1.0	
Client 8 Micro 48240-08 DRINKING FOUNTAIN GYM LOBBY EAST FIRST DRAW	< 1.0	1.0	
Client 9 Micro 48240-09 DRINKING FOUNTAIN GYM LOBBY WEST FIRST DRAW	4.1	1.0	
Client 10 Micro 48240-10 BLANK	< 1.0	1.0	

Technical Supervisor: 9/7/97 Analyst: AL/SL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCATEER HS

Micro Log In **48240**
Total Samples 17
Date Sampled 9/6/97
Date Received 9/6/97
Date Analyzed 9/6/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 48240-11 DRINKING FOUNTAIN ACADEMIC -L4 N HALL FIRST DRAW	3.6	1.0	
Client 12 Micro 48240-12 DRINKING FOUNTAIN ACADEMIC - L4 S. HALL E. END FIRST DRAW	10.5	1.0	
Client 14 Micro 48240-13 DRINKING FOUNTAIN ACADEMIC - L3 S. HALL - W. END FIRST DRAW	16.1	1.0	
Client 15 Micro 48240-14 DRINKING FOUNTAIN ACADEMIC - L3 S. HALL - E. END FIRST DRAW	5.7	1.0	
Client 16 Micro 48240-15 DRINKING FOUNTAIN ACADEMIC - L3 S. HALL - E. EN D FIRST DRAW	21.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL/SL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCATEER HS

Micro Log In **48240**
Total Samples 17
Date Sampled 9/6/97
Date Received 9/6/97
Date Analyzed 9/6/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 17 Micro 48240-16 DRINKING FOUNTAIN ACADEMIC - L2 N. HALL FIRST DRAW	2.9	1.0	
Client 18 Micro 48240-17 DRINKING FOUNTAIN ACADEMIC - L2 S. HALL - W. END FIRST DRAW	4.8	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: AL/SL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
MCATEER HS

Micro Log In **49322**
Total Samples 2
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 19 Micro 49322-01 **DRINKING FOUNTAIN - CAFETERIA WEST FIRST DRAW**	7.2	1.0	
Client 22 Micro 49322-02 **DRINKING FOUNTAIN - ACADEMIC L4 SOUTH HALL - WEST END FIRST DRAW**	5.6	1.0	

Technical Supervisor: F. Ramezanzadeh 10/12/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCATEER HS

Micro Log In **50892**
Total Samples 12
Date Sampled 11/22/97
Date Received 11/22/97
Date Analyzed 11/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **4 A** Micro 50892-01 **SINK FAUCET** **CAFETERIA KITCHEN - EAST**	**2.4**	1.0	
Client **4 B** Micro 50892-02 **SINK FAUCET** **CAFETERIA KITCHEN - EAST**	**1.8**	1.0	
Client **4 C** Micro 50892-03 **SINK FAUCET** **CAFETERIA KITCHEN - EAST**	**9.9**	1.0	
Client **1 A** Micro 50892-04 **DRINKING FOUNTAIN** **AUDITORIUM LOBBY**	**11.0**	1.0	
Client **1 B** Micro 50892-05 **DRINKING FOUNTAIN** **AUDITORIUM LOBBY**	**8.8**	1.0	

Technical Supervisor: _____ 11/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCATEER HS

Micro Log In **50892**
Total Samples 12
Date Sampled 11/22/97
Date Received 11/22/97
Date Analyzed 11/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **1C** Micro 50892-06 **DRINKING FOUNTAIN AUDITORIUM LOBBY**	**28.1**	1.0	
Client **5A** Micro 50892-07 **DRINKING FOUNTAIN GIRL'S LOCKER ROOM - NORTH**	**7.3**	1.0	
Client **5B** Micro 50892-08 **DRINKING FOUNTAIN GIRL'S LOCKER ROOM - NORTH**	**5.1**	1.0	
Client **5C** Micro 50892-09 **DRINKING FOUNTAIN GIRL'S LOCKER ROOM - NORTH**	**10.3**	1.0	
Client **14A** Micro 50892-10 **DRINKING FOUNTAIN ACADEMIC - L3 S. HALL - W. END**	**3.8**	1.0	

Technical Supervisor: 11/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCATEER HS

Micro Log In **50892**
Total Samples 12
Date Sampled 11/22/97
Date Received 11/22/97
Date Analyzed 11/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **14B** Micro 50892-11 **DRINKING FOUNTAIN** **ACADEMIC - L3 S. HALL - W. END**	**3.6**	1.0	
Client **14C** Micro 50892-12 **DRINKING FOUNTAIN** **ACADEMIC - L3 S. HALL - W. END**	**9.4**	1.0	

Technical Supervisor: _____ 11/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANK McCOPPIN ES / CC

Micro Log In **47943**
Total Samples 26
Date Sampled 8/24/97
Date Received 9/1/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 47943-01 DRINKING FOUNTAIN RM 14 FIRST DRAW	12.5	1.0	
Client # 2 Micro 47943-02 DRINKING FOUNTAIN RM 15 FIRST DRAW	13.2	1.0	
Client # 3 Micro 47943-03 DRINKING FOUNTAIN RM 13 FIRST DRAW	9.5	1.0	
Client # 4 Micro 47943-04 DRINKING FOUNTAIN RM 16 FIRST DRAW	12.9	1.0	
Client # 5 Micro 47943-05 DRINKING FOUNTAIN CORRIDOR 2ND FLOOR FIRST DRAW	29.8	1.0	

Technical Supervisor: 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANK McCOPPIN ES / CC

Micro Log In **47943**
Total Samples 26
Date Sampled 8/24/97
Date Received 9/1/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #6 Micro 47943-06 **DRINKING FOUNTAIN RM 11 FIRST DRAW**	**6.1**	1.0	
Client #7 Micro 47943-07 **DRINKING FOUNTAIN RM 10 FIRST DRAW**	**7.4**	1.0	
Client #8 Micro 47943-08 **DRINKING FOUNTAIN RM 9 FIRST DRAW**	**5.4**	1.0	
Client #9 Micro 47943-09 **DRINKING FOUNTAIN RM 12 FIRST DRAW**	**2.7**	1.0	
Client #10 Micro 47943-10 **DRINKING FOUNTAIN RM 6 FIRST DRAW**	**2.8**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANK McCOPPIN ES / CC

Micro Log In **47943**
Total Samples 26
Date Sampled 8/24/97
Date Received 9/1/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #11 Micro 47943-11 DRINKING FOUNTAIN RM 7 FIRST DRAW	2.3	1.0	
Client #12 Micro 47943-12 DRINKING FOUNTAIN RM 5 FIRST DRAW	4.1	1.0	
Client #13 Micro 47943-13 DRINKING FOUNTAIN RM 8 FIRST DRAW	3.9	1.0	
Client #14 Micro 47943-14 DRINKING FOUNTAIN CORRIDOR 1ST FLOOR FIRST DRAW	21.2	1.0	
Client #15 Micro 47943-15 DRINKING FOUNTAIN RM 2 FIRST DRAW	8.4	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANK McCOPPIN ES / CC

Micro Log In **47943**
Total Samples 26
Date Sampled 8/24/97
Date Received 9/1/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #16 Micro 47943-16 DRINKING FOUNTAIN RM 3 FIRST DRAW	5.9	1.0	
Client #17 Micro 47943-17 DRINKING FOUNTAIN RM 1 FIRST DRAW	3.0	1.0	
Client #18 Micro 47943-18 DRINKING FOUNTAIN RM 4 FIRST DRAW	4.6	1.0	
Client #19 Micro 47943-19 DRINKING FOUNTAIN OUTSIDE L - DF FIRST DRAW	< 1.0	1.0	
Client #20 Micro 47943-20 DRINKING FOUNTAIN OUTSIDE R - DF FIRST DRAW	< 1.0	1.0	

Technical Supervisor: 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANK McCOPPIN ES / CC

Micro Log In **47943**
Total Samples 26
Date Sampled 8/24/97
Date Received 9/1/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #21 Micro 47943-21 DRINKING FOUNTAIN CC ROOM FIRST DRAW	4.2	1.0	
Client #22 Micro 47943-22 SINK FAUCET CC KITCHEN FIRST DRAW	6.0	1.0	
Client #23 Micro 47943-23 SINK FAUCET FACULTY ROOM FIRST DRAW	1.6	1.0	
Client #24 Micro 47943-24 MULTIPLE DRINKING FOUNTAIN YARD FIRST DRAW	< 1.0	1.0	
Client #25 Micro 47943-25 BLANK	< 1.0	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
FRANK McCOPPIN ES / CC

Micro Log In **47943**
Total Samples 26
Date Sampled 8/24/97
Date Received 9/1/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #26 Micro 47943-26 **MULTIPLE DRINKING FOUNTAIN PRINCIPAL'S OFFICE FIRST DRAW**	**19.4**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCCOPPIN ES

Micro Log In **49316**
Total Samples 15
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 1A Micro 49316-01 DRINKING FOUNTAIN ROOM 14 RE-SAMPLE	2.0	1.0	
Client: 1B Micro 49316-02 DRINKING FOUNTAIN ROOM 14 RE-SAMPLE	1.9	1.0	
Client: 1C Micro 49316-03 DRINKING FOUNTAIN ROOM 14 RE-SAMPLE	1.9	1.0	
Client: 2A Micro 49316-04 DRINKING FOUNTAIN ROOM 15 RE-SAMPLE	2.1	1.0	
Client: 2B Micro 49316-05 DRINKING FOUNTAIN ROOM 15 RE-SAMPLE	2.1	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCCOPPIN ES

Micro Log In 49316
Total Samples 15
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 2C Micro 49316-06 DRINKING FOUNTAIN ROOM 15 RE-SAMPLE	1.9	1.0	
Client ~~3A~~ 4A Micro 49316-07 DRINKING FOUNTAIN ROOM 16 RE-SAMPLE	1.8	1.0	
Client ~~3B~~ 4B Micro 49316-08 DRINKING FOUNTAIN ROOM 16 RE-SAMPLE	1.4	1.0	
Client ~~3C~~ 4C Micro 49316-09 DRINKING FOUNTAIN ROOM 16 RE-SAMPLE	1.7	1.0	
Client ~~4A~~ 5A Micro 49316-10 DRINKING FOUNTAIN CORRIDOR 2ND FLOOR RE-SAMPLE	3.0	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCCOPPIN ES

Micro Log In **49316**
Total Samples 15
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~4B~~ 5B Micro 49316-11 DRINKING FOUNTAIN CORRIDOR 2ND FLOOR RE-SAMPLE	2.4	1.0	
Client ~~4C~~ 5C Micro 49316-12 DRINKING FOUNTAIN CORRIDOR 2ND FLOOR RE-SAMPLE	2.5	1.0	
Client ~~5A~~ 14A Micro 49316-13 DRINKING FOUNTAIN CORRIDOR 1ST FLOOR RE-SAMPLE	3.8	1.0	
Client ~~5B~~ 14B Micro 49316-14 DRINKING FOUNTAIN CORRIDOR 1ST FLOOR RE-SAMPLE	2.6	1.0	
Client ~~5C~~ 14C Micro 49316-15 DRINKING FOUNTAIN CORRIDOR 1ST FLOOR RE-SAMPLE	3.6	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: McKinley, E.S.

Lab Proj. ID: 9708B70

Sampled: 08/19/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B70-01 Sample Desc : **LIQUID,McKinley-1 (Blank)**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B70-02 Sample Desc : **LIQUID,McKinley-2**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.012**
Lab No: 9708B70-03 Sample Desc : **LIQUID,McKinley-2 (Dup)**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.011**
Lab No: 9708B70-04 Sample Desc : **LIQUID,McKinley-3**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.011**
Lab No: 9708B70-05 Sample Desc : **LIQUID,McKinley-4**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0054**
Lab No: 9708B70-06 Sample Desc : **LIQUID,McKinley-5**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B70-07 Sample Desc : **LIQUID,McKinley-6**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.020**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: McKinley, E.S.

Lab Proj. ID: 9708B70

Sampled: 08/19/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B70-08 Sample Desc : **LIQUID,McKinley-7**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.012**
Lab No: 9708B70-09 Sample Desc : **LIQUID,McKinley-8**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0077**
Lab No: 9708B70-10 Sample Desc : **LIQUID,McKinley-9**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0062**
Lab No: 9708B70-11 Sample Desc : **LIQUID,McKinley-10**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.013**
Lab No: 9708B70-12 Sample Desc : **LIQUID,McKinley-11**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.027**
Lab No: 9708B70-13 Sample Desc : **LIQUID,McKinley-12**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B70-14 Sample Desc : **LIQUID,McKinley-13**				
Lead	mg/L	08/26/97	0.0050	N.D.

Spike

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: McKinley, E.S.

Lab Proj. ID: 9708B70

Sampled: 08/19/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B70-15 Sample Desc : **LIQUID,McKinley-14**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0066**
Lab No: 9708B70-16 Sample Desc : **LIQUID,McKinley-15**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0089**
Lab No: 9708B70-17 Sample Desc : **LIQUID,McKinley-16**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.019**
Lab No: 9708B70-18 Sample Desc : **LIQUID,McKinley-17**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0077**
Lab No: 9708B70-19 Sample Desc : **LIQUID,McKinley-18**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B70-20 Sample Desc : **LIQUID,McKinley-18 (Dup)**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B70-21 Sample Desc : **LIQUID,McKinley-19**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0085**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Shella Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: McKinley, E.S.

Lab Proj. ID: 9708B70

Sampled: 08/19/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B70-22 Sample Desc : **LIQUID,McKinley-20**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0076**
Lab No: 9708B70-23 Sample Desc : **LIQUID,McKinley-21**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.010**
Lab No: 9708B70-24 Sample Desc : **LIQUID,McKinley-22**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B70-25 Sample Desc : **LIQUID,McKinley-23**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B70-26 Sample Desc : **LIQUID,McKinley-24**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B70-27 Sample Desc : **LIQUID,McKinley-25**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B70-28 Sample Desc : **LIQUID,McKinley-25 (Dup)**				
Lead	mg/L	08/26/97	0.0050	N.D.

D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCKINLEY ES
B-2243

Micro Log In **49705**
Total Samples 4
Date Sampled 9/10/97
Date Received 10/18/97
Date Analyzed 10/18/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 27 Micro 49705-01 DRINKING FOUNTAIN 1ST FLOOR, ROOM 12 FIRST DRAW	3.5	1.0	
Client 28 Micro 49705-02 DRINKING FOUNTAIN 1ST FLOOR, ROOM 12 FIRST DRAW	2.3	1.0	
Client 30 Micro 49705-03 DRINKING FOUNTAIN 2ND FLOOR, ROOM 27 FIRST DRAW	3.8	1.0	
Client 31 Micro 49705-04 DRINKING FOUNTAIN 2ND FLOOR, ROOM 27 FIRST DRAW	2.6	1.0	

Technical Supervisor: F. Ramezanzadeh 10/20/97 Analyst: SL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCKINLEY ES

Micro Log In **48383**
Total Samples 6
Date Sampled 9/10/97
Date Received 9/10/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 26 Micro 48383-01 DRINKING FOUNTAIN 1ST FLOOR ROOM 12 FIRST DRAW	4.8	1.0	
Client 27 Micro 48383-02 DRINKING FOUNTAIN 1ST FLOOR ROOM 12 FIRST DRAW	< 1.0	1.0	NOT ANALYZED
Client 28 Micro 48383-03 DRINKING FOUNTAIN 1ST FLOOR ROOM 12 FIRST DRAW			NOT ANALYZED
Client 29 Micro 48383-04 DRINKING FOUNTAIN 2ND FLOOR ROOM 27	4.1	1.0	
Client 30 Micro 48383-05 DRINKING FOUNTAIN 2ND FLOOR ROOM 27			NOT ANALYZED

Technical Supervisor: F Ramezanzadeh 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCKINLEY ES

Micro Log In **48383**
Total Samples 6
Date Sampled 9/10/97
Date Received 9/10/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 31 Micro 48383-06 **DRINKING FOUNTAIN** **2ND FLOOR** **ROOM 27**			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCKINLEY ES

Micro Log In **49166**
Total Samples 10
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **2A** Micro 49166-01 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM #17** **FIRST DRAW**	**2.9**	1.0	
Client **2B** Micro 49166-02 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM #17** **FIRST DRAW**	**2.1**	1.0	
Client **2C** Micro 49166-03 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM #17** **FIRST DRAW**	**7.7**	1.0	
Client **7A** Micro 49166-04 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM #13** **FIRST DRAW**	**2.7**	1.0	
Client **7B** Micro 49166-05 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM #13** **FIRST DRAW**	**2.1**	1.0	

Technical Supervisor: _____ 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCKINLEY ES

Micro Log In **49166**
Total Samples 10
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **7C** Micro 49166-06 **DRINKING FOUNTAIN FIRST FLOOR, ROOM #13 FIRST DRAW**	**4.4**	1.0	
Client **10A** Micro 49166-07 **DRINKING FOUNTAIN FIRST FLOOR, ROOM #16 FIRST DRAW**	**4.4**	1.0	
Client **10B** Micro 49166-08 **DRINKING FOUNTAIN FIRST FLOOR, ROOM #16 FIRST DRAW**	**2.0**	1.0	
Client **10C** Micro 49166-09 **DRINKING FOUNTAIN FIRST FLOOR, ROOM #16 FIRST DRAW**	**3.1**	1.0	
Client **BLANK** Micro 49166-10 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCKINLEY ES

Micro Log In **52163**
Total Samples 7
Date Sampled 1/18/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **MCKINLEY 6A** Micro 52163-01 **SINK DRINKING FOUNTAIN** **12**	**5.6**	1.0	
Client **MCKINLEY 6B** Micro 52163-02 **SINK DRINKING FOUNTAIN** **12**	**2.9**	1.0	
Client **MCKINLEY 6C** Micro 52163-03 **SINK DRINKING FOUNTAIN** **12**	**11.9**	1.0	
Client **MCKINLEY 16A** Micro 52163-04 **SINK DRINKING FOUNTAIN** **27**	**2.6**	1.0	
Client **MCKINLEY 16B** Micro 52163-05 **SINK DRINKING FOUNTAIN** **27**	**2.2**	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCKINLEY ES

Micro Log In **52163**
Total Samples 7
Date Sampled 1/18/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **MCKINLEY 16C** Micro 52163-06 **SINK DRINKING FOUNTAIN 27**	**3.1**	1.0	
Client **MCKINLEY BLANK** Micro 52163-07 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCLAREN CC

Micro Log In **47784**
Total Samples 7
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **MCLAREN #1** Micro 47784-01 **DRINKING FOUNTAIN** **1FL OFFICE HALLWAY** **FIRST DRAW**	**1.6**	1.0	
Client **MCLAREN #2** Micro 47784-02 **DRINKING FOUNTAIN** **HALLWAY** **FIRST DRAW**	**< 1.0**	1.0	
Client **MCLAREN #3** Micro 47784-03 **DRINKING FOUNTAIN** **HALLWAY** **FIRST DRAW**	**1.3**	1.0	
Client **MCLAREN #4** Micro 47784-04 **DRINKING FOUNTAIN** **HALLWAY** **FIRST DRAW**	**1.1**	1.0	
Client **MCLAREN #5** Micro 47784-05 **DRINKING FOUNTAIN** **CAFETERIA** **FIRST DRAW**	**5.1**	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MCLAREN CC

Micro Log In **47784**
Total Samples 7
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **MCLAREN #6** Micro 47784-06 **DRINKING FOUNTAIN 2FL HALL FIRST DRAW**	**5.0**	1.0	
Client **MCLAREN #7** Micro 47784-07 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Harvey Milk

Lab Proj. ID: 9708B61

Sampled: 08/16/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B61-01 Sample Desc : **LIQUID,Harvey Milk 1**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B61-02 Sample Desc : **LIQUID,Harvey Milk 2**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B61-03 Sample Desc : **LIQUID,Harvey Milk 2 Duplicate**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B61-04 Sample Desc : **LIQUID,Harvey Milk 3**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B61-05 Sample Desc : **LIQUID,Harvey Milk 4**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.0093**
Lab No: 9708B61-06 Sample Desc : **LIQUID,Harvey Milk 5**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B61-07 Sample Desc : **LIQUID,Harvey Milk 6**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.0067**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Harvey Milk

Lab Proj. ID: 9708B61

Sampled: 08/16/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B61-08 Sample Desc : **LIQUID,Harvey Milk 7**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.0092**
Lab No: 9708B61-09 Sample Desc : **LIQUID,Harvey Milk 8**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.0070**
Lab No: 9708B61-10 Sample Desc : **LIQUID,Harvey Milk 9**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B61-11 Sample Desc : **LIQUID,Harvey Milk 10**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B61-12 Sample Desc : **LIQUID,Harvey Milk 11**				
Lead	mg/L	08/25/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRALOMA ES #722

Micro Log In **47609**
Total Samples 21
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/27/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 722-1 Micro 47609-01 DRINKING FOUNTAIN 1ST FLOOR - C90 OUTSIDE RM 115 FIRST DRAW	7.7	1.0	
Client 722-2 Micro 47609-02 DRINKING FOUNTAIN 1ST FLOOR - RM 107 FIRST DRAW	15.2	1.0	
Client 722-3 Micro 47609-03 DRINKING FOUNTAIN 1ST FLOOR - RM 105 FIRST DRAW	10.1	1.0	
Client 722-4 Micro 47609-04 DRINKING FOUNTAIN 1ST FLOOR - RM 103 FIRST DRAW	52.6	2.0	
Client 722-5 Micro 47609-05 DRINKING FOUNTAIN 1ST FLOOR - RM 101 FIRST DRAW	17.6	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRALOMA ES #722

Micro Log In **47609**
Total Samples 21
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/27/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **722-6** Micro 47609-06 **DRINKING FOUNTAIN** **1ST FLOOR - RM 100** **FIRST DRAW**	**12.5**	1.0	
Client **722-7** Micro 47609-07 **DRINKING FOUNTAIN** **1ST FLOOR - RM 102** **FIRST DRAW**	**9.6**	1.0	
Client **722-8** Micro 47609-08 **DRINKING FOUNTAIN** **1ST FLOOR - RM 106** **FIRST DRAW**	**11.9**	1.0	
Client **722-9** Micro 47609-09 **SINK FAUCET** **1ST FLOOR - RM 110 - FACULTY LOUNGE** **FIRST DRAW**	**1.5**	1.0	
Client **722-10** Micro 47609-10 **DRINKING FOUNTAIN** **BASEMENT FLOOR - RM 001** **FIRST DRAW**	**13.9**	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRALOMA ES #722

Micro Log In **47609**
Total Samples 21
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/27/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 722-11 Micro 47609-11 DRINKING FOUNTAIN BASEMENT FLOOR - RM 010 FIRST DRAW	20.1	1.0	
Client 722-12 Micro 47609-12 DRINKING FOUNTAIN BASEMENT FLOOR - RM 012 FIRST DRAW	9.5	1.0	
Client 722-13 Micro 47609-13 DRINKING FOUNTAIN BASEMENT FLOOR - RM 014 FIRST DRAW	4.4	1.0	
Client 722-14 Micro 47609-14 DRINKING FOUNTAIN BASEMENT FLOOR - RM 016 FIRST DRAW	20.6	1.0	
Client 722-15 Micro 47609-15 DRINKING FOUNTAIN BASEMENT FLOOR - RM 018 FIRST DRAW	21.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRALOMA ES #722

Micro Log In **47609**
Total Samples 21
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/27/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **722-16** Micro 47609-16 **SINK FAUCET** **BASEMENT FLOOR RM 026 - FACULTY LOUNGE** **FIRST DRAW**	**8.6**	1.0	
Client **722-17** Micro 47609-17 **SINK FAUCET** **BASEMENT FLOOR - KITCHEN RM 023** **FIRST DRAW**	**17.2**	1.0	
Client **722-18** Micro 47609-18 **SINK FAUCET** **BASEMENT FLOOR - KITCHEN RM 023** **FIRST DRAW**	**40.4**	1.0	
Client **722-19** Micro 47609-19 **MULTIPLE DRINKING FOUNTAIN** **BASEMENT - OUTSIDE C92** **FIRST DRAW**	**11.6**	1.0	
Client **722-20** Micro 47609-20 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRALOMA ES #722

Micro Log In **47609**
Total Samples 21
Date Sampled 8/17/97
Date Received 8/21/97
Date Analyzed 8/27/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 722-21 Micro 47609-21 DRINKING FOUNTAIN ROOM 123 FIRST DRAW	24.7	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRA LOMA B-2243

Micro Log In **49610**
Total Samples 28
Date Sampled 10/15/97
Date Received 10/16/97
Date Analyzed 10/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **722-2A** Micro 49610-01 **DRINKING FOUNTAIN 1ST FLOOR ROOM 107 1ST DRAW**	**22.0**	1.0	
Client **722-2B** Micro 49610-02 **DRINKING FOUNTAIN 1ST FLOOR ROOM 107 2ND DRAW**	**6.2**	1.0	
Client **722-2C** Micro 49610-03 **DRINKING FOUNTAIN 1ST FLOOR ROOM 107 3RD DRAW**	**18.9**	1.0	
Client **722-5A** Micro 49610-04 **DRINKING FOUNTAIN 1ST FLOOR ROOM 101 1ST DRAW**	**10.8**	1.0	
Client **722-5B** Micro 49610-05 **DRINKING FOUNTAIN 1ST FLOOR ROOM 101 2ND DRAW**	**7.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRA LOMA

Micro Log In **49610**
Total Samples 28
Date Sampled 10/15/97
Date Received 10/16/97
Date Analyzed 10/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **722-5C** Micro 49610-06 **DRINKING FOUNTAIN** **1ST FLOOR ROOM 101** **3RD DRAW**	**9.8**	1.0	
Client **722-8A** Micro 49610-07 **DRINKING FOUNTAIN** **1ST FLOOR ROOM 106** **1ST DRAW**	**1.4**	1.0	
Client **722-8B** Micro 49610-08 **DRINKING FOUNTAIN** **1ST FLOOR ROOM 106** **2ND DRAW**	**1.8**	1.0	
Client **722-8C** Micro 49610-09 **DRINKING FOUNTAIN** **1ST FLOOR ROOM 106** **3RD DRAW**	**2.1**	1.0	
Client **722-10A** Micro 49610-10 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 001** **1ST DRAW**	**18.9**	1.0	

Technical Supervisor: _____ 10/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRA LOMA

Micro Log In **49610**
Total Samples 28
Date Sampled 10/15/97
Date Received 10/16/97
Date Analyzed 10/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **722-10B** Micro 49610-11 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 001** **2ND DRAW**	**36.8**	1.0	
Client **722-10C** Micro 49610-12 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 001** **3RD DRAW**	**18.9**	1.0	
Client **722-11A** Micro 49610-13 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 010** **1ST DRAW**	**5.1**	1.0	
Client **722-11B** Micro 49610-14 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 010** **2ND DRAW**	**2.8**	1.0	
Client **722-11C** Micro 49610-15 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 010** **3RD DRAW**	**8.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRA LOMA

Micro Log In **49610**
Total Samples 28
Date Sampled 10/15/97
Date Received 10/16/97
Date Analyzed 10/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **722-14A** Micro 49610-16 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 016** **1ST DRAW**	**2.9**	1.0	
Client **722-14B** Micro 49610-17 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 016** **2ND DRAW**	**1.7**	1.0	
Client **722-14C** Micro 49610-18 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 016** **3RD DRAW**	**3.7**	1.0	
Client **722-15A** Micro 49610-19 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 018** **1ST DRAW**	**2.7**	1.0	
Client **722-15B** Micro 49610-20 **DRINKING FOUNTAIN** **BASEMENT FLOOR ROOM 018** **2ND DRAW**	**7.5**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRA LOMA

Micro Log In 49610
Total Samples 28
Date Sampled 10/15/97
Date Received 10/16/97
Date Analyzed 10/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 722-15C Micro 49610-21 DRINKING FOUNTAIN BASEMENT FLOOR ROOM 018 3RD DRAW	6.7	1.0	
Client 722-17A Micro 49610-22 SINK FAUCET BASEMENT FLOOR ROOM 023 KITCHEN 1ST DRAW	3.8	1.0	
Client 722-17B Micro 49610-23 SINK FAUCET BASEMENT FLOOR ROOM 023 KITCHEN 2ND DRAW	1.8	1.0	
Client 722-17C Micro 49610-24 SINK FAUCET BASEMENT FLOOR ROOM 023 KITCHEN 3RD DRAW	12.9	1.0	
Client 722-18A Micro 49610-25 SINK FAUCET BASEMENT FLOOR ROOM 023 KITCHEN 1ST DRAW	12.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MIRA LOMA

Micro Log In **49610**
Total Samples 28
Date Sampled 10/15/97
Date Received 10/16/97
Date Analyzed 10/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **722-18B** Micro 49610-26 **SINK FAUCET BASEMENT FLOOR ROOM 023 KITCHEN 2ND DRAW**	**2.9**	1.0	
Client **722-18C** Micro 49610-27 **SINK FAUCET BASEMENT FLOOR ROOM 023 KITCHEN 3RD DRAW**	**35.9**	1.0	
Client **722-20A** Micro 49610-28 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION ANNEX CC

Micro Log In **48021**
Total Samples 2
Date Sampled 8/23/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 2 Micro 48021-01 **SINK FAUCET** **STAFF LOUNGE** **FIRST DRAW**	**3.6**	1.0	
Client 5 Micro 48021-02 **FIELD BLANK**	**< 1.0**	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION ANNEX CC
& Mission Nursery

Micro Log In **48241**
Total Samples 2
Date Sampled 9/5/97
Date Received 9/6/97
Date Analyzed 9/6/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48241-01 SINK FAUCET KITCHEN 421 BARTLETT FIRST DRAW (CC)	4.6	1.0	
Client 4 Micro 48241-02 SINK FAUCET KITCHEN 2950 MISSION FIRST DRAW (Nursery)	7.2	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL/SL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1097. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
1950 MISSION
(MISSION ANNEX) C D
Marshall Amos

Micro Log In **49207**
Total Samples 9
Date Sampled 10/3/97
Date Received 10/4/97
Date Analyzed 10/4/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **3C** Micro 49207-06 **SINK DRINKING FOUNTAIN PORTABLE #5 FIRST DRAW**	**11.5**	1.0	
Client **2A** Micro 49207-07 **SINK DRINKING FOUNTAIN PORTABLE #4**	**8.1**	1.0	
Client **2B** Micro 49207-08 **SINK DRINKING FOUNTAIN PORTABLE #4**	**5.2**	1.0	
Client **2C** Micro 49207-09 **SINK DRINKING FOUNTAIN PORTABLE #4 FIRST DRAW**	**12.6**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
1950 MISSION
(MISSION ANNEX) CD
Marshall Annex

Micro Log In **49207**
Total Samples 9
Date Sampled 10/3/97
Date Received 10/4/97
Date Analyzed 10/4/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **4 A** Micro 49207-01 **SINK DRINKING FOUNTAIN PORTABLE #6**	**8.7**	1.0	
Client **4 B** Micro 49207-02 **SINK DRINKING FOUNTAIN PORTABLE #6**	**7.5**	1.0	
Client **4 C** Micro 49207-03 **SINK DRINKING FOUNTAIN PORTABLE #6 FIRST DRAW**	**10.3**	1.0	
Client **3 A** Micro 49207-04 **SINK DRINKING FOUNTAIN PORTABLE #5**	**4.0**	1.0	
Client **3 B** Micro 49207-05 **SINK DRINKING FOUNTAIN PORTABLE #5**	**3.8**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION HS

Micro Log In **47836**
Total Samples 18
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **725-1** Micro 47836-01 **DRINKING FOUNTAIN** **GIRLS' LOCKER ROOM - ROOM 018** **FIRST DRAW**	**18.9**	1.0	
Client **725-2** Micro 47836-02 **SINK FAUCET** **BASEMENT LEVEL** **FIRST DRAW**	**1.7**	1.0	
Client **725-3** Micro 47836-03 **DRINKING FOUNTAIN** **1ST FLOOR - C97** **OUTSIDE ROOM 130** **FIRST DRAW**	**4.9**	1.0	
Client **725-4** Micro 47836-04 **SINK FAUCET** **1ST FLOOR - RM 116** **FIRST DRAW**	**7.9**	1.0	
Client **725-5** Micro 47836-05 **SINK FAUCET** **1ST FLOOR - ROOM 122** **CAFE KITCHEN - NORTH WALL** **FIRST DRAW**	**7.6**	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION HS

Micro Log In **47836**
Total Samples 18
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **725-6** Micro 47836-06 **SINK FAUCET** **1ST FLOOR - ROOM 122** **CAFE KITCHEN - NORTH WALL** **FIRST DRAW**	**2.5**	1.0	
Client **725-7** Micro 47836-07 **SINK FAUCET** **1ST FLOOR - ROOM122** **CAFE KITCHEN - WEST WALL** **FIRST DRAW**	**5.3**	1.0	
Client **725-8** Micro 47836-08 **SINK FAUCET** **1ST FLOOR - ROOM122** **CAFE KITCHEN - WEST WALL** **FIRST DRAW**	**4.8**	1.0	
Client **725-9** Micro 47836-09 **SINK FAUCET** **1ST FLOOR - ROOM122** **CAFE KITCHEN - SOUTH WALL** **FIRST DRAW**	**6.9**	1.0	
Client **725-10** Micro 47836-10 **SINK FAUCET** **1ST FLOOR - ROOM117** **CAFE KITCHEN - SOUTH WALL** **FIRST DRAW**	**1.3**	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION HS

Micro Log In **47836**
Total Samples 18
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 725-11 Micro 47836-11 DRINKING FOUNTAIN 2ND FLOOR - C97 OUTSIDE AUDITORIUM FIRST DRAW	< 1.0	1.0	
Client 725-12 Micro 47836-12 SINK FAUCET 2ND FLOOR - ROOM 237 COOKING CLASS SINK FIRST DRAW	< 1.0	1.0	
Client 725-13 Micro 47836-13 SINK FAUCET 2ND FLOOR - ROOM 237 COOKING CLASS SINK FIRST DRAW	4.5	1.0	
Client 725-14 Micro 47836-14 SINK FAUCET 2ND FLOOR - ROOM 237 COOKING CLASS SINK FIRST DRAW	10.3	1.0	
Client 725-15 Micro 47836-15 DRINKING FOUNTAIN 2ND FLOOR - C91 OUTSIDE AUDITORIUM FIRST DRAW	4.3	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION HS

Micro Log In **47836**
Total Samples 18
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **725-16** Micro 47836-16 **DRINKING FOUNTAIN** **4TH FLOOR - C97 OUTSIDE ROOM 407** **FIRST DRAW**	**1.8**	1.0	
Client **725-17** Micro 47836-17 **DRINKING FOUNTAIN** **4TH FLOOR - C91 OUTSIDE ROOM 424** **FIRST DRAW**	**4.5**	1.0	
Client **725-18** Micro 47836-18 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 9/8/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION HS

Micro Log In **50887**
Total Samples 4
Date Sampled 11/18/97
Date Received 11/22/97
Date Analyzed 11/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **725-1A** Micro 50887-01 **DRINKING FOUNTAIN GIRLS LOCKER ROOM 1ST DRAW**	**5.3**	1.0	
Client **725-1B** Micro 50887-02 **DRINKING FOUNTAIN GIRLS LOCKER ROOM 2ND DRAW**	**6.1**	1.0	
Client **725-1C** Micro 50887-03 **DRINKING FOUNTAIN GIRLS LOCKER ROOM 3RD DRAW**	**15.4**	1.0	
Client **BLANK** Micro 50887-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 11/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION NURSERY

Micro Log In 66111
Total Samples 13
Date Sampled 3/12/99
Date Received 3/12/99
Date Analyzed 3/15/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client M. NURS. 1A Micro 66111-01 CLASSROOM 1 1ST DRAW	1	1	
Client M. NURS. 1B Micro 66111-02 CLASSROOM 1 2ND DRAW	1	1	
Client M. NURS. 2A Micro 66111-03 TOILET 2 1ST DRAW	< 1	1	
Client M. NURS. 2B Micro 66111-04 TOILET 2 2ND DRAW	< 1	1	
Client M. NURS. 3A 4A Micro 66111-05 KITCHEN 1ST DRAW	2	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/15/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION NURSERY

Micro Log In 66111
Total Samples 13
Date Sampled 3/12/99
Date Received 3/12/99
Date Analyzed 3/15/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client M. NURS. ~~3B~~ 4B (a) Micro 66111-06 KITCHEN 2ND DRAW	< 1	1	
Client M. NURS. ~~4A~~ 3A (a) Micro 66111-07 TOILET 3 1ST DRAW	4	1	
Client M. NURS. ~~4B~~ 3B (a) Micro 66111-08 TOILET 3 2ND DRAW	2	1	
Client M. NURS. 5A Micro 66111-09 TOILET 3 1ST DRAW	< 1	1	
Client M. NURS. 5B Micro 66111-10 TOILET 4 2ND DRAW	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/15/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MISSION NURSERY

Micro Log In 66111
Total Samples 13
Date Sampled 3/12/99
Date Received 3/12/99
Date Analyzed 3/15/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client M. NURS. 6A Micro 66111-11 TOILET 5 1ST DRAW	< 1	1	
Client M. NURS. 6B Micro 66111-12 TOILET 5 2ND DRAW	< 1	1	
Client M. NURS. BL Micro 66111-13 BLANK	< 1	1	

Technical Supervisor: Hamzanzadeh for Farid Ramezanzadeh, M.S. 3/15/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MONROE ES

Micro Log In **47845**
Total Samples 37
Date Sampled 8/24/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47845-01 DRINKING FOUNTAIN 101 NOT OPERATIONAL			SAMPLE NOT RECEIVED
Client 2 Micro 47845-02 SINK DRINKING FOUNTAIN 101	**2.6**	1.0	
Client 3 Micro 47845-03 DRINKING FOUNTAIN 102	**3.3**	1.0	
Client 4 Micro 47845-04 SINK DRINKING FOUNTAIN 102	**2.0**	1.0	
Client 5 Micro 47845-05 DRINKING FOUNTAIN 103	**2.1**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MONROE ES

Micro Log In **47845**
Total Samples 37
Date Sampled 8/24/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47845-06 SINK DRINKING FOUNTAIN 103	2.4	1.0	
Client 7 Micro 47845-07 DRINKING FOUNTAIN 104 NOT OPERATIONAL			SAMPLE NOT RECEIVED
Client 8 Micro 47845-08 SINK DRINKING FOUNTAIN 104	6.3	1.0	
Client 9 Micro 47845-09 DRINKING FOUNTAIN 105 NOT OPERATIONAL			SAMPLE NOT RECEIVED
Client 10 Micro 47845-10 BLANK	<1.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MONROE ES

Micro Log In **47845**
Total Samples 37
Date Sampled 8/24/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47845-11 SINK DRINKING FOUNTAIN 105	2.3	1.0	
Client 12 Micro 47845-12 MULTIPLE DRINKING FOUNTAIN LIBRARY	1.6	1.0	
Client 13 Micro 47845-13 SINK DRINKING FOUNTAIN 106	5.9	1.0	
Client 14 Micro 47845-14 DRINKING FOUNTAIN 107	7.0	1.0	
Client 15 Micro 47845-15 SINK DRINKING FOUNTAIN 107	4.3	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MONROE ES

Micro Log In **47845**
Total Samples 37
Date Sampled 8/24/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47845-16 SINK DRINKING FOUNTAIN 108	8.6	1.0	
Client 17 Micro 47845-17 SINK DRINKING FOUNTAIN 109	2.0	1.0	
Client 18 Micro 47845-18 SINK DRINKING FOUNTAIN 110	2.6	1.0	
Client 19 Micro 47845-19 SINK FAUCET KITCHEN	2.0	1.0	
Client 20 Micro 47845-20 BLANK	<1.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MONROE ES

Micro Log In **47845**
Total Samples 37
Date Sampled 8/24/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **21** Micro 47845-21 **DRINKING FOUNTAIN 201**	**3.0**	1.0	
Client **22** Micro 47845-22 **SINK DRINKING FOUNTAIN 201**	**1.9**	1.0	
Client **23** Micro 47845-23 **DRINKING FOUNTAIN 202**	**2.4**	1.0	
Client **24** Micro 47845-24 **SINK DRINKING FOUNTAIN 202**	**2.3**	1.0	
Client **25** Micro 47845-25 **DRINKING FOUNTAIN 203**	**3.4**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MONROE ES

Micro Log In **47845**
Total Samples 37
Date Sampled 8/24/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 26 Micro 47845-26 SINK DRINKING FOUNTAIN 203	1.9	1.0	
Client 27 Micro 47845-27 SINK DRINKING FOUNTAIN 204	2.8	1.0	
Client 28 Micro 47845-28 SINK DRINKING FOUNTAIN 205	2.3	1.0	
Client 29 Micro 47845-29 SINK FAUCET LOUNGE	2.2	1.0	
Client 30 Micro 47845-30 BLANK	<1.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MONROE ES

Micro Log In **47845**
Total Samples 37
Date Sampled 8/24/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 31 Micro 47845-31 SINK FAUCET WOMEN'S RM	2.4	1.0	
Client 32 Micro 47845-32 SINK FAUCET MEN'S RM	2.3	1.0	
Client 33 Micro 47845-33 MULTIPLE DRINKING FOUNTAIN 2ND FLOOR DRINKING FOUNTAIN	1.6	1.0	
Client 34 Micro 47845-34 SINK FAUCET BOYS' RM.	2.4	1.0	
Client 35 Micro 47845-35 SINK FAUCET GIRLS' RM.	2.3	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
MONROE ES

Micro Log In **47845**
Total Samples 37
Date Sampled 8/24/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **36** Micro 47845-36 **MULTIPLE DRINKING FOUNTAIN OUTSIDE MULTIPLE DRINKING FOUNTAIN**	**<1.0**	1.0	
Client **97-W00753-4** Micro 47845-37 **SPIKED SAMPLE**	**20.4**	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: George Moscone Elem.

Lab Proj. ID: 9709158

Sampled: 09/05/97
Received: 09/05/97
Analyzed: see below

Reported: 09/09/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709158-01 Sample Desc : **LIQUID,1**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-02 Sample Desc : **LIQUID,2**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-03 Sample Desc : **LIQUID,3**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-04 Sample Desc : **LIQUID,4**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-05 Sample Desc : **LIQUID,5**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-06 Sample Desc : **LIQUID,6**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-07 Sample Desc : **LIQUID,7**				
Lead	mg/L	09/08/97	0.0050	N.D.

alytes reported as N.D. were not present above the stated limit of detection.

EQUOIA ANALYTICAL - ELAP #1210

eila Flynn
oject Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: George Moscone Elem.

Lab Proj. ID: 9709158

Sampled: 09/05/97
Received: 09/05/97
Analyzed: see below

Reported: 09/09/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709158-08 Sample Desc : **LIQUID,8**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-09 Sample Desc : **LIQUID,9**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-10 Sample Desc : **LIQUID,9 duplicate**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-11 Sample Desc : **LIQUID,10**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-12 Sample Desc : **LIQUID,11**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-13 Sample Desc : **LIQUID,12**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-14 Sample Desc : **LIQUID,13**				
Lead	mg/L	09/08/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: George Moscone Elem.

Lab Proj. ID: 9709158

Sampled: 09/05/97
Received: 09/05/97
Analyzed: see below

Reported: 09/09/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709158-15 Sample Desc : **LIQUID,14**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-16 Sample Desc : **LIQUID,15**				
Lead	**mg/L**	**09/08/97**	**0.0050**	**0.013**
Lab No: 9709158-17 Sample Desc : **LIQUID,16**				
Lead	mg/L	09/08/97	0.0050	N.D.
Lab No: 9709158-18 Sample Desc : **LIQUID,16 duplicate**				
Lead	mg/L	09/08/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE MOSCONE

Micro Log In **66298**
Total Samples 36
Date Sampled 3/16/99
Date Received 3/18/99
Date Analyzed 3/21/99

~~18~~ 20 ~~16~~ 14
~~34~~ 34

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **MOSCONE 1A** Micro 66298-01 OFFICE, 1ST DRAW SINK DRINKING FOUNTAIN	3	1	
Client **MOSCONE 1B** Micro 66298-02 OFFICE, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 6A** Micro 66298-03 COURTYARD, 1ST DRAW MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 6B** Micro 66298-04 COURTYARD, 2ND DRAW MULTIPLE DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 9A** Micro 66298-05 CAFETERIA, 1ST DRAW SINK FAUCET	< 1	1	

Technical Supervisor: Farid Ramezanzadeh, M.S. 3/21/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE MOSCONE

Micro Log In **66298**
Total Samples 36
Date Sampled 3/16/99
Date Received 3/18/99
Date Analyzed 3/21/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **MOSCONE 9B** Micro 66298-06 CAFETERIA, 1ST DRAW SINK FAUCET	< 1	1	
Client **MOSCONE 10A** Micro 66298-07 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	10	1	
Client **MOSCONE 10B** Micro 66298-08 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	11	1	
Client **MOSCONE 11A** Micro 66298-09 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 11B** Micro 66298-10 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: _____ 3/21/99 Analyst: TT
Eqp Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE MOSCONE

Micro Log In **66298**
Total Samples **36**
Date Sampled **3/16/99**
Date Received **3/18/99**
Date Analyzed **3/21/99**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **MOSCONE 12A** Micro 66298-11 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 12B** Micro 66298-12 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 13A** Micro 66298-13 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 13B** Micro 66298-14 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 14A** Micro 66298-15 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/21/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE MOSCONE

Micro Log In 66298
Total Samples 36
Date Sampled 3/16/99
Date Received 3/18/99
Date Analyzed 3/21/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client MOSCONE 14B Micro 66298-16 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 15A Micro 66298-17 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 15B Micro 66298-18 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 16A Micro 66298-19 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 16B Micro 66298-20 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: Farid Ramezanzadeh, M.S. 3/21/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE MOSCONE

Micro Log In **66298**
Total Samples **36**
Date Sampled **3/16/99**
Date Received **3/18/99**
Date Analyzed **3/21/99**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **MOSCONE 17A** Micro 66298-21 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 17B** Micro 66298-22 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 20A** Micro 66298-23 FACULTY ROOM, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 20B** Micro 66298-24 FACULTY ROOM, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client **MOSCONE 21A** Micro 66298-25 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/22/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE MOSCONE

Micro Log In 66298
Total Samples 36
Date Sampled 3/16/99
Date Received 3/18/99
Date Analyzed 3/21/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client MOSCONE 21B Micro 66298-26 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 22A Micro 66298-27 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 22B Micro 66298-28 CLASS, 2ND DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 23A Micro 66298-29 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 24A Micro 66298-30 EXT. COURTYARD, 1ST DRAW DRINKING FOUNTAIN	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/22/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE MOSCONE

Micro Log In 66298
Total Samples 36
Date Sampled 3/16/99
Date Received 3/18/99
Date Analyzed 3/21/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client MOSCONE 25A Micro 66298-31 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 26A Micro 66298-32 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 27A Micro 66298-33 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE 28A Micro 66298-34 CLASS, 1ST DRAW SINK DRINKING FOUNTAIN	< 1	1	
Client MOSCONE BL1 Micro 66298-35 BLANK 1	< 1	1	

Technical Supervisor: for Farid Rameznazadeh, M.S. 3/22/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE MOSCONE

Micro Log In 66298
Total Samples 36
Date Sampled 3/16/99
Date Received 3/18/99
Date Analyzed 3/22/99

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: MOSCONE BL2 Micro 66298-36 BLANK 2	< 1	1	

Technical Supervisor: for Farid Ramezanzadeh, M.S. 3/22/99 Date Reported Analyst: TT

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Platform Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: John Muir E.S.

Lab Proj. ID: 9708B50

Sampled: 08/17/97
Received: 08/22/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B50-01 Sample Desc : **LIQUID,J. Muir 1 (Blank)**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708B50-02 Sample Desc : **LIQUID,J. Muir 2**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B50-03 Sample Desc : **LIQUID,J. Muir 3**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B50-04 Sample Desc : **LIQUID,J. Muir 4**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B50-05 Sample Desc : **LIQUID,J. Muir 5**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B50-06 Sample Desc : **LIQUID,J. Muir 6**				
Lead	**mg/L**	**08/25/97**	**0.0050**	**0.0068**
Lab No: 9708B50-07 Sample Desc : **LIQUID,J. Muir 7**				
Lead	mg/L	08/25/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: John Muir E.S.

Lab Proj. ID: 9708B50

Sampled: 08/17/97
Received: 08/22/97
Analyzed: see below
Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B50-08 Sample Desc : **LIQUID,J. Muir 8**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B50-09 Sample Desc : **LIQUID,J. Muir 9**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B50-10 Sample Desc : **LIQUID,J. Muir 10**				
Lead	mg/L	08/25/97	0.0050	N.D.
Lab No: 9708B50-11 Sample Desc : **LIQUID,J. Muir 10 (Dup)**				
Lead	mg/L	08/25/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEW TRADITIONS CENTER

Micro Log In **47366**
Total Samples 9
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47366-01 **BLANK**	< 1.0	1.0	
Client 2 Micro 47366-02 **MULTIPLE DRINKING FOUNTAIN SOUTH / WEST OF BASEMENT (OUTSIDE) FIRST DRAW**	4.5	1.0	
Client 3 Micro 47366-03 **DRINKING FOUNTAIN FIRST FLOOR HALLWAY - NORTH OF RM. 02 FIRST DRAW**	25.4	1.0	
Client 4 Micro 47366-04 **SINK FAUCET SECOND FLOOR KITCHEN SINK RM. 013A FIRST DRAW**	2.9	1.0	
Client 5 Micro 47366-05 **DRINKING FOUNTAIN SECOND FLOOR HALLWAY SOUTH OF RM. 008 FIRST DRAW**	10.2	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEW TRADITIONS CENTER

Micro Log In **47366**
Total Samples 9
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47366-06 **MULTIPLE DRINKING FOUNTAIN NORTH / WEST OF BLDG. (OUTSIDE) BASKET BALL COURT FIRST DRAW**	**1.7**	1.0	
Client 7 Micro 47366-07 **MULTIPLE DRINKING FOUNTAIN NORTH / EAST OF BLDG (OUTSIDE) FIRST DRAW**	**3.8**	1.0	
Client 8 Micro 47366-08 **SINK FAUCET SINK INSIDE OF RM. B-14 - WEST WALL FIRST DRAW**	**1.6**	1.0	
Client 9 Micro 47366-09 **SINK FAUCET SINK INSIDE OF RM. B-15 - WEST WALL FIRST DRAW**	**< 1.0**	1.0	

Technical Supervisor: 8/22/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEW TRADITION
ELEMENTARY

Micro Log In **48027**
Total Samples 4
Date Sampled 8/30/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 10 Micro 48027-01 BLANK	< 1.0	1.0	
Client ~~11~~ 3A Micro 48027-02 DRINKING FOUNTAIN FIRST FLOOR - HALLWAY, NORTH OF ROOM 002 FIRST DRAW	< 1.0	1.0	
Client ~~12~~ 3B Micro 48027-03 DRINKING FOUNTAIN FIRST FLOOR - HALLWAY, NORTH OF ROOM 002 SECOND DRAW	< 1.0	1.0	
Client ~~13~~ 3C Micro 48027-04 DRINKING FOUNTAIN FIRST FLOOR - HALLWAY, NORTH OF ROOM 002 THIRD DRAW	< 1.0	1.0	

Technical Supervisor: 8/31/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992. American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEWCOMER HS

Micro Log In **47691**
Total Samples 9
Date Sampled 8/22/97
Date Received 8/23/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47691-01 **BLANK**	< 1.0	1.0	
Client 4 Micro 47691-02 **SINK FAUCET SECOND FLOOR TEACHERS' LIBRARY / KITCHEN FIRST DRAW**	7.2	1.0	
Client 5 Micro 47691-03 **SINK FAUCET SECOND FLOOR TEACHERS' LIBRARY / KITCHEN FIRST DRAW**	9.3	1.0	
Client 6 Micro 47691-04 **DRINKING FOUNTAIN FIRST FLOOR FRONT OF RM 104 FIRST DRAW**	1.3	1.0	
Client 7 Micro 47691-05 **SINK FAUCET FIRST FLOOR CAFETERIA KITCHEN FIRST DRAW**	10.1	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEWCOMER HS

Micro Log In **47691**
Total Samples 9
Date Sampled 8/22/97
Date Received 8/23/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 8 Micro 47691-06 SINK FAUCET FIRST FLOOR CAFETERIA / FOOD AREA FIRST DRAW	28.7	1.0	
Client 9 Micro 47691-07 DRINKING FOUNTAIN FIRST FLOOR PLAYGROUND - NORTH / WEST FIRST DRAW	5.7	1.0	
Client 10 Micro 47691-08 MULTIPLE DRINKING FOUNTAIN FIRST FLOOR PLAYGROUND - NORTH / EAST FIRST DRAW	24.3	1.0	
Client 11 Micro 47691-09 DRINKING FOUNTAIN FIRST FLOOR PARKING LOT - SOUTH / WEST FIRST DRAW	21.3	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEWCOMER HS
B-2243

Micro Log In **49671**
Total Samples 4
Date Sampled 9/10/97
Date Received 10/17/97
Date Analyzed 10/18/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **14B** Micro 49671-01 **SINK FAUCET** **FIRST FLOOR CAFETERIA - FOOD AREA** **FIRST DRAW**	**1.3**	1.0	
Client **15C** Micro 49671-02 **SINK FAUCET** **FIRST FLOOR CAFETERIA - FOOD AREA** **FIRST DRAW**	**< 1.0**	1.0	
Client **17B** Micro 49671-03 **MULTIPLE DRINKING FOUNTAIN** **PLAYGROUND - NORTH / EAST** **FIRST DRAW**	**< 1.0**	1.0	
Client **18C** Micro 49671-04 **MULTIPLE DRINKING FOUNTAIN** **PLAYGROUND - NORTH / EAST** **FIRST DRAW**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/20/97 Analyst: SL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEWCOMER HS

Micro Log In **48372**
Total Samples 6
Date Sampled 9/10/97
Date Received 9/10/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~13A~~ 8A Micro 48372-01 SINK FAUCET FIRST FLOOR CAFETERIA FOOD AREA FIRST DRAW	2.2	1.0	
Client ~~14B~~ 8B Micro 48372-02 SINK FAUCET FIRST FLOOR CAFETERIA FOOD AREA FIRST DRAW			NOT ANALYZED
Client ~~15C~~ 8C Micro 48372-03 SINK FAUCET FIRST FLOOR CAFETERIA FOOD AREA FIRST DRAW			NOT ANALYZED
Client ~~16A~~ 10A Micro 48372-04 MULTIPLE DRINKING FOUNTAIN FIRST FLOOR PLAYGROUND NORTH / EAST FIRST DRAW	2.0	1.0	
Client ~~17B~~ 10B Micro 48372-05 MULTIPLE DRINKING FOUNTAIN FIRST FLOOR PLAYGROUND NORTH / EAST FIRST DRAW			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEWCOMER HS

Micro Log In **48372**
Total Samples 6
Date Sampled 9/10/97
Date Received 9/10/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~16C~~ 16C Micro 48372-06 **MULTIPLE DRINKING FOUNTAIN** **FIRST FLOOR** **PLAYGROUND NORTH / EAST** **FIRST DRAW**			NOT ANALYZED

Technical Supervisor: F Ramezanzadeh 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEW COMER HS

Micro Log In **52060**
Total Samples 6
Date Sampled 1/14/98
Date Received 1/14/98
Date Analyzed 1/15/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **8A** Micro 52060-01 **SINK FAUCET OFF CAFETERIA RESAMPLE**	**1.2**	1.0	
Client **8B** Micro 52060-02 **SINK FAUCET OFF CAFETERIA RESAMPLE**	**< 1.0**	1.0	
Client **8C** Micro 52060-03 **SINK FAUCET OFF CAFETERIA RESAMPLE**	**1.6**	1.0	
Client **10A** Micro 52060-04 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND SOUTH WEST CORNER OF NORTH DRINKING FOUNTAIN RESAMPLE**	**20.4**	1.0	
Client **10B** Micro 52060-05 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND SOUTH WEST CORNER NORTH DRINKING FOUNTAIN RESAMPLE**	**5.4**	1.0	

Technical Supervisor: F Ramezanzadeh 1/15/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEW COMER HS

Micro Log In **52060**
Total Samples 6
Date Sampled 1/14/98
Date Received 1/14/98
Date Analyzed 1/15/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **10C** Micro 52060-06 **MULTIPLE DRINKING FOUNTAIN PLAYGROUND SOUTH WEST CORNER OF NORTH DRINKING FOUNTAIN RESAMPLE**	**18.2**	1.0	

Technical Supervisor: F. Ramezanzadeh 1/15/98 Analyst: FR
Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NEWCOMER HS

Micro Log In **52169**
Total Samples 4
Date Sampled 1/16/983
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **NEWCOMER 8A** Micro 52169-01 **SINK FAUCET CAFETERIA**	**8.6**	1.0	
Client **NEWCOMER 8B** Micro 52169-02 **SINK FAUCET CAFETERIA**	**5.5**	1.0	
Client **NEWCOMER 8C** Micro 52169-03 **SINK FAUCET CAFETERIA**	**4.1**	1.0	
Client **NEWCOMER BLANK** Micro 52169-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NORIEGA CC

Micro Log In **47499**
Total Samples 15
Date Sampled 8/16/97
Date Received 8/18/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 47499-01 DRINKING FOUNTAIN / ROOM 003 RIGHT HAND CORNER FIRST DRAW	2.7	1.0	
Client # 2 Micro 47499-02 DRINKING FOUNTAIN / ROOM 003 LEFT HAND CORNER FIRST DRAW	3.1	1.0	
Client # 3 Micro 47499-03 SINK FAUCET KITCHEN AREA 003C NORTH SINK FAUCET FIRST DRAW	2.7	1.0	
Client # 4 Micro 47499-04 SINK FAUCET KITCHEN AREA 003C EAST SINK FAUCET FIRST DRAW	1.8	1.0	
Client # 5 Micro 47499-05 DRINKING FOUNTAIN ROOM 001 BY NORTH SIDE FIRST DRAW	3.5	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NORIEGA CC

Micro Log In **47499**
Total Samples 15
Date Sampled 8/16/97
Date Received 8/18/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #6 Micro 47499-06 DRINKING FOUNTAIN ROOM 002 JUST BY ENTRANCE DOOR FIRST DRAW	< 1.0	1.0	
Client #7 Micro 47499-07 WATER FAUCET ROOM 004 NORTH SIDE CORNER FIRST DRAW	< 1.0	1.0	
Client #8 Micro 47499-08 WATER FAUCET/ ROOM 005 BY EAST CORNER FIRST DRAW	1.4	1.0	
Client #9 Micro 47499-09 WATER FAUCET / ROOM 006 BY NORTH CORNER FIRST DRAW	< 1.0	1.0	
Client #10 Micro 47499-10 WATER FAUCET ROOM 007 BY EAST CORNER FIRST DRAW	1.5	1.0	

Technical Supervisor: _____ 9/1/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
NORIEGA CC

Micro Log In **47499**
Total Samples 15
Date Sampled 8/16/97
Date Received 8/18/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #11 Micro 47499-11 DRINKING FAUCET SOUTH SIDE OF THE YARD (OUTSIDE) FIRST DRAW	1.4	1.0	
Client #12 Micro 47499-12 DRINKING FOUNTAIN OUTSIDE YARD BY CORNER OF ROOM 004 BACK SIDE FIRST DRAW	1.6	1.0	
Client #13 Micro 47499-13 DRINKING FOUNTAIN OUTSIDE YARD SOUTH SIDE FIRST DRAW	7.2	1.0	
Client #14 Micro 47499-14 BLANK	< 1.0	1.0	
Client #15 Micro 47499-15 DRINKING FOUNTAIN CORRIDOR C-90 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOHN O' CONNELL HS

Micro Log In **47475**
Total Samples 20
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47475-01 DRINKING FOUNTAIN CORRIDOR - BASEMENT FIRST DRAW	1.4	1.0	
Client 2 Micro 47475-02 DRINKING FOUNTAIN CORRIDOR - BASEMENT FIRST DRAW	1.2	1.0	
Client 3 Micro 47475-03 SINK FAUCET CLASS 7 FIRST DRAW	2.0	1.0	
Client 4 Micro 47475-04 DRINKING FOUNTAIN CORRIDOR - 1ST FLOOR FIRST DRAW	3.2	1.0	
Client 5 Micro 47475-05 SINK FAUCET CLASS 108 FIRST DRAW	4.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOHN O' CONNELL HS

Micro Log In **47475**
Total Samples 20
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47475-06 SINK FAUCET CLASS 106 FIRST DRAW	< 1.0	1.0	
Client 7 Micro 47475-07 SINK FAUCET CLASS 104 FIRST DRAW	3.3	1.0	
Client 8 Micro 47475-08 SINK FAUCET CLASS 102 FIRST DRAW	< 1.0	1.0	
Client 9 Micro 47475-09 DRINKING FOUNTAIN CORRIDOR 1ST FLOOR FIRST DRAW	1.7	1.0	
Client 10 Micro 47475-10 DRINKING FOUNTAIN CLASS 103 FIRST DRAW	4.2	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOHN O' CONNELL HS

Micro Log In **47475**
Total Samples 20
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47475-11 DRINKING FOUNTAIN CLASS 105 FIRST DRAW	6.2	1.0	
Client 12 Micro 47475-12 SINK FAUCET LOUNGE - 1ST FLOOR FIRST DRAW	< 1.0	1.0	
Client 13 Micro 47475-13 SINK FAUCET RM. 115 BATH FIRST DRAW	< 1.0	1.0	
Client 14 Micro 47475-14 SINK FAUCET RM 110 FIRST DRAW	8.1	1.0	
Client 15 Micro 47475-15 DRINKING FOUNTAIN CORRIDOR -1ST FLOOR FIRST DRAW	< 1.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOHN O' CONNELL HS

Micro Log In **47475**
Total Samples 20
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **16** Micro 47475-16 **SINK FAUCET** **KITCHEN** **FIRST DRAW**	**1.7**	1.0	
Client **17** Micro 47475-17 **SINK FAUCET** **KITCHEN** **FIRST DRAW**	**1.5**	1.0	
Client **18** Micro 47475-18 **SINK FAUCET** **KITCHEN** **FIRST DRAW**	**7.0**	1.0	
Client **19** Micro 47475-19 **DRINKING FOUNTAIN** **PLAYGROUND** **FIRST DRAW**	**20.6**	1.0	
Client **20** Micro 47475-20 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOSE' ORTEGA ES

Micro Log In **47476**
Total Samples 31
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47476-01 SINK DRINKING FOUNTAIN CLASS - 100 FIRST DRAW	1.2	1.0	
Client 2 Micro 47476-02 SINK DRINKING FOUNTAIN CLASS - 101 FIRST DRAW	8.4	1.0	
Client 3 Micro 47476-03 SINK DRINKING FOUNTAIN CLASS - 102 FIRST DRAW	3.2	1.0	
Client 4 Micro 47476-04 SINK DRINKING FOUNTAIN CLASS -103 FIRST DRAW	11.0	1.0	
Client 5 Micro 47476-05 DRINKING FOUNTAIN CORRIDOR - 1ST FLOOR FIRST DRAW	4.8	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOSE' ORTEGA ES

Micro Log In **47476**
Total Samples 31
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47476-06 DRINKING FOUNTAIN CORRIDOR - 1ST FLOOR FIRST DRAW	< 1.0	1.0	
Client 7 Micro 47476-07 DRINKING FOUNTAIN CLASS - 002 FIRST DRAW	16.0	1.0	
Client 8 Micro 47476-08 DRINKING FOUNTAIN CLASS - 003 FIRST DRAW	< 1.0	1.0	
Client 9 Micro 47476-09 DRINKING FOUNTAIN CLASS - 004 FIRST DRAW	1.5	1.0	
Client 10 Micro 47476-10 DRINKING FOUNTAIN CLASS - 007 FIRST DRAW	1.4	1.0	

Technical Supervisor: 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOSE' ORTEGA ES

Micro Log In **47476**
Total Samples 31
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47476-11 DRINKING FOUNTAIN CLASS - 011 FIRST DRAW	6.6	1.0	
Client 12 Micro 47476-12 DRINKING FOUNTAIN CLASS - 012 FIRST DRAW	13.6	1.0	
Client 13 Micro 47476-13 DRINKING FOUNTAIN CLASS - 013 FIRST DRAW	2.8	1.0	
Client 14 Micro 47476-14 DRINKING FOUNTAIN CLASS - 014 FIRST DRAW	4.9	1.0	
Client 15 Micro 47476-15 DRINKING FOUNTAIN CORRIDOR - 2ND FLOOR FIRST DRAW	1.8	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOSE' ORTEGA ES

Micro Log In **47476**
Total Samples 31
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **16** Micro 47476-16 **SINK FAUCET ROOM 207A FIRST DRAW**	**2.6**	1.0	
Client **17** Micro 47476-17 **SINK DRINKING FOUNTAIN CLASS - 200 FIRST DRAW**	**7.8**	1.0	
Client **18** Micro 47476-18 **SINK DRINKING FOUNTAIN CLASS - 202 FIRST DRAW**	**16.7**	1.0	
Client **19** Micro 47476-19 **SINK DRINKING FOUNTAIN CLASS - 203 FIRST DRAW**	**9.3**	1.0	
Client **20** Micro 47476-20 **SINK DRINKING FOUNTAIN CLASS - 204 FIRST DRAW**	**14.8**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOSE' ORTEGA ES

Micro Log In **47476**
Total Samples 31
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 21 Micro 47476-21 SINK DRINKING FOUNTAIN CLASS - 205 FIRST DRAW	2.9	1.0	
Client 22 Micro 47476-22 SINK DRINKING FOUNTAIN CLASS - 206 FIRST DRAW	14.8	1.0	
Client 23 Micro 47476-23 DRINKING FOUNTAIN CORRIDOR - 2ND FLOOR FIRST DRAW	1.7	1.0	
Client 24 Micro 47476-24 SINK FAUCET LOUNGE - 208A FIRST DRAW	1.7	1.0	
Client 25 Micro 47476-25 DRINKING FOUNTAIN CAFETERIA - 209 FIRST DRAW	30.8	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOSE' ORTEGA ES

Micro Log In **47476**
Total Samples 31
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 26 Micro 47476-26 SINK FAUCET KITCHEN FIRST DRAW	1.7	1.0	
Client 27 Micro 47476-27 SINK FAUCET KITCHEN FIRST DRAW	7.4	1.0	
Client 28 Micro 47476-28 SINK FAUCET KITCHEN FIRST DRAW	18.9	1.0	
Client 29 Micro 47476-29 MULTIPLE DRINKING FOUNTAIN PLAYGROUND FIRST DRAW	7.1	1.0	
Client 30 Micro 47476-30 MULTIPLE DRINKING FOUNTAIN PLAYGROUND FIRST DRAW	23.4	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOSE' ORTEGA ES

Micro Log In **47476**
Total Samples 31
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 31 Micro 47476-31 **BLANK**	< 1.0	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Jose Ortega ES

Lab Proj. ID: 9712752

Sampled: 12/11/97
Received: 12/12/97
Analyzed: see below

Reported: 12/18/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9712752-01 Sample Desc : **LIQUID,3-1**				
Lead	mg/L	12/17/97	0.0050	N.D.
Lab No: 9712752-02 Sample Desc : **LIQUID,3-2**				
Lead	mg/L	12/17/97	0.0050	N.D.
Lab No: 9712752-03 Sample Desc : **LIQUID,3-3**				
Lead	mg/L	12/17/97	0.0050	N.D.
Lab No: 9712752-04 Sample Desc : **LIQUID,3-4**				
Lead	mg/L	12/17/97	0.0050	N.D.
Lab No: 9712752-05 Sample Desc : **LIQUID,3-5**				
Lead	mg/L	12/17/97	0.0050	N.D.
Lab No: 9712752-06 Sample Desc : **LIQUID,3-6**				
Lead	**mg/L**	**12/17/97**	**0.0050**	**0.0076**
Lab No: 9712752-07 Sample Desc : **LIQUID,3-7**				
Lead	mg/L	12/17/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Jose Ortega ES

Lab Proj. ID: 9712752

Sampled: 12/11/97
Received: 12/12/97
Analyzed: see below

Reported: 12/18/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
20B Lab No: 9712752-08 Sample Desc : LIQUID,3-8				
Lead	mg/L	12/17/97	0.0050	N.D.
22A Lab No: 9712752-09 Sample Desc : LIQUID,3-9				
Lead	**mg/L**	**12/18/97**	**0.0050**	**0.0075**
22A Lab No: 9712752-10 Sample Desc : LIQUID,3-9 Dup				
Lead	**mg/L**	**12/18/97**	**0.0050**	**0.0078**
22B Lab No: 9712752-11 Sample Desc : LIQUID,3-10				
Lead	**mg/L**	**12/17/97**	**0.0050**	**0.0063**
28A Lab No: 9712752-12 Sample Desc : LIQUID,3-13				
Lead	**mg/L**	**12/17/97**	**0.0050**	**0.0066**
28B Lab No: 9712752-13 Sample Desc : LIQUID,3-14				
Lead	**mg/L**	**12/18/97**	**0.010**	**0.11**
7C Lab No: 9712752-14 Sample Desc : LIQUID,3-15				
Lead	mg/L	12/17/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Gianninl

Client Proj. ID: Jose Ortega ES

Lab Proj. ID: 9712752

Sampled: 12/11/97
Received: 12/12/97
Analyzed: see below

Reported: 12/18/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9712752-15 Sample Desc : **LIQUID,3-16**				
Lead	**mg/L**	**12/17/97**	**0.0050**	**0.016**
Lab No: 9712752-16 Sample Desc : **LIQUID,3-17**				
Lead	mg/L	12/18/97	0.0050	N.D.
Lab No: 9712752-17 Sample Desc : **LIQUID,3-18**				
Lead	mg/L	12/17/97	0.0050	N.D.
Lab No: 9712752-18 Sample Desc : **LIQUID,3-19**				
Lead	**mg/L**	**12/18/97**	**0.0050**	**0.017**
Lab No: 9712752-19 Sample Desc : **LIQUID,3-21**				
Lead	**mg/L**	**12/17/97**	**0.0050**	**0.046**
Lab No: 9712752-20 Sample Desc : **LIQUID,3-21 Dup**				
Lead	**mg/L**	**12/17/97**	**0.0050**	**0.048**
Lab No: 9712752-21 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	12/17/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: J. Parker

Lab Proj. ID: 9708D15

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D15-01 Sample Desc : **LIQUID,J. Parker 1**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-02 Sample Desc : **LIQUID,J. Parker 1 Duplicate**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-03 Sample Desc : **LIQUID,J. Parker 2**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-04 Sample Desc : **LIQUID,J. Parker 2 Duplicate**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-05 Sample Desc : **LIQUID,J. Parker 3**				
Lead	mg/L	08/29/97	0.0050	N.D.
Lab No: 9708D15-06 Sample Desc : **LIQUID,J. Parker 3 Duplicate**				
Lead	mg/L	08/29/97	0.0050	N.D.
Lab No: 9708D15-07 Sample Desc : **LIQUID,J. Parker 4**				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: J. Parker

Lab Proj. ID: 9708D15

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D15-08 Sample Desc : **LIQUID,J. Parker 5**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-09 Sample Desc : **LIQUID,J. Parker 6**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-10 Sample Desc : **LIQUID,J. Parker 7**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-11 Sample Desc : **LIQUID,J. Parker 8**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-12 Sample Desc : **LIQUID,J. Parker 9**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-13 Sample Desc : **LIQUID,J. Parker 10**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-14 Sample Desc : **LIQUID,J. Parker 11**				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: J. Parker

Lab Proj. ID: 9708D15

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D15-15 Sample Desc : **LIQUID,J. Parker 12**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-16 Sample Desc : **LIQUID,J. Parker 13**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-17 Sample Desc : **LIQUID,J. Parker 14**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-18 Sample Desc : **LIQUID,J. Parker 15**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-19 Sample Desc : **LIQUID,J. Parker 16**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-20 Sample Desc : **LIQUID,J. Parker 17**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-21 Sample Desc : **LIQUID,J. Parker 18**				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: J. Parker

Lab Proj. ID: 9708D15

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D15-22 Sample Desc : **LIQUID,J. Parker 19**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-23 Sample Desc : **LIQUID,J. Parker 20**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-24 Sample Desc : **LIQUID,J. Parker 21**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-25 Sample Desc : **LIQUID,J. Parker 22**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-26 Sample Desc : **LIQUID,J. Parker 23**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-27 Sample Desc : **LIQUID,J. Parker 24**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-28 Sample Desc : **LIQUID,J. Parker 25**				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: J. Parker

Lab Proj. ID: 9708D15

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D15-29 Sample Desc : **LIQUID,J. Parker 26**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-30 Sample Desc : **LIQUID,J. Parker 27**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-31 Sample Desc : **LIQUID,J. Parker Blank**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D15-32 Sample Desc : **LIQUID,J. Parker 28**				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.051**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROSA PARKS ES

Micro Log In 60294
Total Samples 37
Date Sampled 9/17/98
Date Received 9/18/98
Date Analyzed 9/18/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client PARKS 1 Micro 60294-01 DRINKING FOUNTAIN 4TH HALL	1	1	
Client PARKS 1A Micro 60294-02 DRINKING FOUNTAIN 4TH HALL	< 1	1	
Client PARKS 1B Micro 60294-03 DRINKING FOUNTAIN 4TH HALL	< 1	1	
Client PARKS 2 Micro 60294-04 DRINKING FOUNTAIN 4TH HALL	2	1	
Client PARKS 2A Micro 60294-05 DRINKING FOUNTAIN 4TH HALL	2	1	

Technical Supervisor: F. Ramezanzadeh 9/18/98 Analyst: FR

Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROSA PARKS ES

Micro Log In **60294**
Total Samples **37**
Date Sampled **9/17/98**
Date Received **9/18/98**
Date Analyzed **9/18/98**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **PARKS 2B** Micro 60294-06 DRINKING FOUNTAIN 4TH HALL	2	1	
Client **PARKS 3** Micro 60294-07 SINK FAUCET 4TH TEACHER'S LOUNGE	1	1	
Client **PARKS 3A** Micro 60294-08 SINK FAUCET 4TH TEACHER'S LOUNGE	< 1	1	
Client **PARKS 3B** Micro 60294-09 SINK FAUCET 4TH TEACHER'S LOUNGE	< 1	1	
Client **PARKS 4** Micro 60294-10 DRINKING FOUNTAIN ROOF / EXTERIOR	3	1	

Technical Supervisor: _____ 9/18/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROSA PARKS ES

Micro Log In 60294
Total Samples 37
Date Sampled 9/17/98
Date Received 9/18/98
Date Analyzed 9/18/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client PARKS 4A Micro 60294-11 DRINKING FOUNTAIN ROOF / EXTERIOR	2	1	
Client PARKS 4B Micro 60294-12 DRINKING FOUNTAIN ROOF / EXTERIOR	3	1	
Client PARKS 5 Micro 60294-13 DRINKING FOUNTAIN 3RD HALL	< 1	1	
Client PARKS 5A Micro 60294-14 DRINKING FOUNTAIN 3RD HALL	< 1	1	
Client PARKS 5B Micro 60294-15 DRINKING FOUNTAIN 3RD HALL	< 1	1	

Technical Supervisor: _____ 9/18/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROSA PARKS ES

Micro Log In 60294
Total Samples 37
Date Sampled 9/17/98
Date Received 9/18/98
Date Analyzed 9/18/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client PARKS 6 Micro 60294-16 DRINKING FOUNTAIN 3RD HALL	1	1	
Client PARKS 6A Micro 60294-17 DRINKING FOUNTAIN 3RD HALL	< 1	1	
Client PARKS 6B Micro 60294-18 DRINKING FOUNTAIN 3RD HALL	< 1	1	
Client PARKS 7 Micro 60294-19 DRINKING FOUNTAIN 2ND HALL	1	1	
Client PARKS 7A Micro 60294-20 DRINKING FOUNTAIN 2ND HALL	< 1	1	

Technical Supervisor: F. Ramezanzadeh 9/18/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROSA PARKS ES

Micro Log In 60294
Total Samples 37
Date Sampled 9/17/98
Date Received 9/18/98
Date Analyzed 9/18/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client PARKS 7B Micro 60294-21 DRINKING FOUNTAIN 2ND HALL	< 1	1	
Client PARKS 8 Micro 60294-22 DRINKING FOUNTAIN 2ND HALL	< 1	1	
Client PARKS 8A Micro 60294-23 DRINKING FOUNTAIN 2ND HALL	< 1	1	
Client PARKS 8B Micro 60294-24 DRINKING FOUNTAIN 2ND HALL	< 1	1	
Client PARKS 9 Micro 60294-25 DRINKING FOUNTAIN 2ND HALL - AUDITORIUM	< 1	1	

Technical Supervisor: _____ 9/18/98 Analyst: FR
Farid Rameznazadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROSA PARKS ES

Micro Log In 60294
Total Samples 37
Date Sampled 9/17/98
Date Received 9/18/98
Date Analyzed 9/18/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client PARKS 9A Micro 60294-26 DRINKING FOUNTAIN 2ND HALL - AUDITORIUM	< 1	1	
Client PARKS 9B Micro 60294-27 DRINKING FOUNTAIN 2ND HALL - AUDITORIUM	< 1	1	
Client PARKS 10 Micro 60294-28 DRINKING FOUNTAIN 1ST CAFETERIA	3	1	
Client PARKS 10A Micro 60294-29 DRINKING FOUNTAIN 1ST CAFETERIA	2	1	
Client PARKS 10B Micro 60294-30 DRINKING FOUNTAIN 1ST CAFETERIA	1	1	

Technical Supervisor: F. Ramezanzadeh 9/18/98 Analyst: FR

Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROSA PARKS ES

Micro Log In 60294
Total Samples 37
Date Sampled 9/17/98
Date Received 9/18/98
Date Analyzed 9/18/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client PARKS 11 Micro 60294-31 MULTIPLE SINK FAUCET 1ST KITCHEN	10	1	
Client PARKS 11A Micro 60294-32 MULTIPLE SINK FAUCET 1ST KITCHEN	< 1	1	
Client PARKS 11B Micro 60294-33 MULTIPLE SINK FAUCET 1ST KITCHEN	< 1	1	
Client PARKS 12 Micro 60294-34 SINK FAUCET 1ST TEACHERS' EATING AREA	< 1	1	
Client PARKS 12A Micro 60294-35 SINK FAUCET 1ST TEACHERS' EATING AREA	< 1	1	

Technical Supervisor: _____ 9/18/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROSA PARKS ES

Micro Log In 60294
Total Samples 37
Date Sampled 9/17/98
Date Received 9/18/98
Date Analyzed 9/18/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client PARKS 12B Micro 60294-36 SINK FAUCET 1ST TEACHERS' EATING AREA	< 1	1	
Client PARKS BLANK Micro 60294-37 BLANK	< 1	1	

Technical Supervisor: _____ 9/18/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SANCHEZ ES

Micro Log In **48026**
Total Samples 4
Date Sampled 8/30/97
Date Received 8/30/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 10 Micro 48026-01 **BLANK**	< **1.0**	1.0	
Client ~~11~~ 5A Micro 48026-02 **DRINKING FOUNTAIN** **2ND FLOOR - HALLWAY NEXT TO ROOM 024** **FIRST DRAW**	**4.7**	1.0	
Client ~~12~~ 5B Micro 48026-03 **DRINKING FOUNTAIN** **2ND FLOOR - HALLWAY NEXT TO ROOM 024** **SECOND DRAW**	**1.4**	1.0	
Client ~~13~~ 5C Micro 48026-04 **DRINKING FOUNTAIN** **2ND FLOOR - HALLWAY NEXT TO ROOM 024** **THIRD DRAW**	**1.9**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE PEABODY ES

Micro Log In **47939**
Total Samples 20
Date Sampled 8/23/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47939-01 DRINKING FOUNTAIN RM 4 FIRST DRAW	3.8	1.0	
Client 2 Micro 47939-02 DRINKING FOUNTAIN RM 3 FIRST DRAW	15.1	1.0	
Client 3 Micro 47939-03 DRINKING FOUNTAIN RM 5 FIRST DRAW	5.8	1.0	
Client 4 Micro 47939-04 DRINKING FOUNTAIN RM 6 FIRST DRAW	2.8	1.0	
Client 5 Micro 47939-05 DRINKING FOUNTAIN CORRIDOR 1ST FLOOR FIRST DRAW	4.8	1.0	

Technical Supervisor: 9/4/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE PEABODY ES

Micro Log In **47939**
Total Samples 20
Date Sampled 8/23/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47939-06 DRINKING FOUNTAIN RM 8 FIRST DRAW	7.6	1.0	
Client 7 Micro 47939-07 DRINKING FOUNTAIN RM 7 FIRST DRAW	4.5	1.0	
Client 8 Micro 47939-08 DRINKING FOUNTAIN RM 10 FIRST DRAW	7.2	1.0	
Client 9 Micro 47939-09 DRINKING FOUNTAIN RM 9 FIRST DRAW	20.1	1.0	
Client 10 Micro 47939-10 DRINKING FOUNTAIN RM 11 FIRST DRAW	5.8	1.0	

Technical Supervisor: _____ 9/4/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE PEABODY ES

Micro Log In **47939**
Total Samples 20
Date Sampled 8/23/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47939-11 DRINKING FOUNTAIN RM 12 FIRST DRAW	9.4	1.0	
Client 12 Micro 47939-12 DRINKING FOUNTAIN LOBBY 2ND FLOOR FIRST DRAW	14.0	1.0	
Client 13 Micro 47939-13 SINK FAUCET TEACHERS' LUNCH ROOM FIRST DRAW	9.6	1.0	
Client 14 Micro 47939-14 MULTIPLE DRINKING FOUNTAIN UPPER YARD FIRST DRAW	< 1.0	1.0	
Client 15 Micro 47939-15 DRINKING FAUCET K-1/ RM 2 FIRST DRAW	48.2	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE PEABODY ES

Micro Log In **47939**
Total Samples 20
Date Sampled 8/23/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **16** Micro 47939-16 **DRINKING FAUCET RM 1 FIRST DRAW**	**4.3**	1.0	
Client **17** Micro 47939-17 **DRINKING FAUCET OUTSIDE RM 2 FIRST DRAW**	**1.6**	1.0	
Client **18** Micro 47939-18 **MULTIPLE DRINKING FOUNTAIN LOWER YARD FIRST DRAW**	**< 1.0**	1.0	
Client **19** Micro 47939-19 **BLANK**	**< 1.0**	1.0	
Client **20** Micro 47939-20 **DRINKING FAUCET PRINCIPAL'S OFFICE FIRST DRAW**	**96.7**	3.3	

Technical Supervisor: _____ 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE PEABODY ES /CC

Micro Log In **49315**
Total Samples 12
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~1-A~~ 2A Micro 49315-01 DRINKING FOUNTIAN ROOM 3 RE-SAMPLE	2.3	1.0	
Client ~~1-B~~ 2B Micro 49315-02 DRINKING FOUNTIAN ROOM 3 RE-SAMPLE	1.3	1.0	
Client ~~1-C~~ 2C Micro 49315-03 DRINKING FOUNTIAN ROOM 3 RE-SAMPLE	2.3	1.0	
Client ~~2-A~~ 9A Micro 49315-04 DRINKING FOUNTIAN ROOM 9 RE-SAMPLE	5.6	1.0	
Client ~~2-B~~ 9B Micro 49315-05 DRINKING FOUNTIAN ROOM 9 RE-SAMPLE	4.7	1.0	

Technical Supervisor: _____ 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE PEABODY ES /CC

Micro Log In **49315**
Total Samples 12
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~2-C~~ 9C Micro 49315-06 **DRINKING FOUNTIAN ROOM 9 RE-SAMPLE**	**8.6**	1.0	
Client ~~3-A~~ 12A Micro 49315-07 **DRINKING FOUNTIAN LOBBY 2ND FLOOR RE-SAMPLE**	**2.1**	1.0	
Client ~~3-B~~ 12B Micro 49315-08 **DRINKING FOUNTIAN LOBBY 2ND FLOOR RE-SAMPLE**	**2.2**	1.0	
Client ~~3-C~~ 12C Micro 49315-09 **DRINKING FOUNTIAN LOBBY 2ND FLOOR RE-SAMPLE**	**3.5**	1.0	
Client ~~4-A~~ 15A Micro 49315-10 **DRINKING FOUNTIAN K-1 / ROOM 2 RE-SAMPLE**	**6.4**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE PEABODY ES /CC

Micro Log In **49315**
Total Samples 12
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~4-B~~ 15B Micro 49315-11 DRINKING FOUNTIAN K-1 / ROOM 2 RE-SAMPLE	4.6	1.0	
Client ~~4-C~~ 15C Micro 49315-12 DRINKING FOUNTIAN K-1 / ROOM 2 RE-SAMPLE	11.0	1.0	

Technical Supervisor: _____ 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **47745**
Total Samples 24
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47745-01 **BLANK**	< 1.0	1.0	
Client 2 Micro 47745-02 **DRINKING FOUNTAIN** **SECOND FLOOR - OUTSIDE ROOM 203** **FIRST DRAW**	7.9	1.0	
Client 3 Micro 47745-03 **DRINKING FOUNTAIN** **SECOND FLOOR - OUTSIDE ROOM 217A** **FIRST DRAW**	3.8	1.0	
Client 4 Micro 47745-04 **DRINKING FOUNTAIN** **THIRD FLOOR ACROSS ROOM 310** **FIRST DRAW**	5.2	1.0	
Client 5 Micro 47745-05 **DRINKING FOUNTAIN** **THIRD FLOOR - OUTSIDE ROOM 581** **FIRST DRAW**	8.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **47745**
Total Samples 24
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47745-06 SINK FAUCET THIRD FLOOR - FACULTY LOUNGE ROOM 307 FIRST DRAW	4.6	1.0	
Client 7 Micro 47745-07 SINK FAUCET FIRST FLOOR - CAFETERIA KITCHEN FIRST DRAW	2.0	1.0	
Client 8 Micro 47745-08 SINK FAUCET FIRST FLOOR - CAFETERIA KITCHEN FIRST DRAW	1.4	1.0	
Client 9 Micro 47745-09 SINK FAUCET FIRST FLOOR - CAFETERIA KITCHEN FIRST DRAW	1.9	1.0	
Client 10 Micro 47745-10 SINK FAUCET FIRST FLOOR - CAFETERIA KITCHEN FIRST DRAW	1.5	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **47745**
Total Samples 24
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **11** Micro 47745-11 **SINK FAUCET** **FIRST FLOOR - CAFETERIA KITCHEN** **FIRST DRAW**	**3.4**	1.0	
Client **12** Micro 47745-12 **DRINKING FOUNTAIN** **FIRST FLOOR - OUTSIDE ROOM 108** **FIRST DRAW**	**10.4**	1.0	
Client **13** Micro 47745-13 **MULTIPLE DRINKING FOUNTAIN** **FIRST FLOOR - OUTSIDE OF BLDG. OF ROOM 101**	**77.6**	2.9	
Client **14** Micro 47745-14 **DRINKING FOUNTAIN** **BASEMENT FLOOR** **GIRLS' GYM BATHROOM** **FIRST DRAW**	**13.9**	1.0	
Client **15** Micro 47745-15 **MULTIPLE DRINKING FOUNTAIN** **BASEMENT LEVEL** **OUTSIDE GYM - BOYS' ROOM** **FIRST DRAW**	**30.2**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **47745**
Total Samples 24
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47745-16 DRINKING FOUNTAIN FIRST FLOOR - GYMNASIUM NORTH / WEST FIRST DRAW	15.3	1.0	
Client 17 Micro 47745-17 DRINKING FOUNTAIN FIRST FLOOR - GYMNASIUM NORTH / EAST FIRST DRAW	13.8	1.0	
Client 18 Micro 47745-18 MULTIPLE DRINKING FOUNTAIN FIRST FLOOR - OUTSIDE GYMNASIUM ROOM 130 FIRST DRAW	12.5	1.0	
Client 19 Micro 47745-19 MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL - OUTSIDE OF ROOM 030D FIRST DRAW	1.4	1.0	
Client 20 Micro 47745-20 DRINKING FOUNTAIN FIRST FLOOR - INSIDE ROOM 103 FIRST DRAW	24.7	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **47745**
Total Samples 24
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 21 Micro 47745-21 DRINKING FOUNTAIN FIRST FLOOR - INSIDE ROOM 104 FIRST DRAW	14.7	1.0	
Client 22 Micro 47745-22 DRINKING FOUNTAIN FIRST FLOOR - INSIDE ROOM 105 FIRST DRAW	14.0	1.0	
Client 23 Micro 47745-23 DRINKING FOUNTAIN FIRST FLOOR - INSIDE ROOM 106 FIRST DRAW	33.4	1.0	
Client 24 Micro 47745-24 DRINKING FOUNTAIN FIRST FLOOR - OUTSIDE ROOM 103 FIRST DRAW	39.9	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **48315**
Total Samples 12
Date Sampled 9/9/97
Date Received 9/9/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~25-A~~ 13A Micro 48315-01 MULTIPLE DRINKING FOUNTAIN FIRST FLOOR OUTSIDE OF BLDG OF ROOM 101 FIRST DRAW	2.1	1.0	
Client ~~26-B~~ 13B Micro 48315-02 MULTIPLE DRINKING FOUNTAIN FIRST FLOOR OUTSIDE OF BLDG OF ROOM 101 FIRST DRAW			NOT ANALYZED
Client ~~27-C~~ 13C Micro 48315-03 MULTIPLE DRINKING FOUNTAIN FIRST FLOOR OUTSIDE OF BLDG OF ROOM 101 FIRST DRAW	1.2	1.0	
Client ~~28-A~~ 15A Micro 48315-04 MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL - OUTSIDE GYM - BOYS' ROOM FIRST DRAW	1.6	1.0	
Client ~~29-B~~ 15B Micro 48315-05 MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL - OUTSIDE GYM - BOYS' ROOM FIRST DRAW			NOT ANALYZED

Technical Supervisor: F. Ramezanzadeh 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **48315**
Total Samples 12
Date Sampled 9/9/97
Date Received 9/9/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~30-C~~ 15C Micro 48315-06 **MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL - OUTSIDE GYM - BOYS' ROOM FIRST DRAW**	**1.5**	1.0	
Client ~~31-A~~ 16A Micro 48315-07 **DRINKING FOUNTAIN FIRST FLOOR - GYMNASIUM NORTH / WEST FIRST DRAW**	**5.2**	1.0	
Client ~~32-B~~ 16B Micro 48315-08 **DRINKING FOUNTAIN FIRST FLOOR - GYMNASIUM NORTH / WEST FIRST DRAW**	**2.5**	1.0	
Client ~~33-C~~ 16C Micro 48315-09 **DRINKING FOUNTAIN FIRST FLOOR - GYMNASIUM NORTH / WEST FIRST DRAW**	**2.1**	1.0	
Client ~~34-A~~ 20A Micro 48315-10 **DRINKING FOUNTAIN FIRST FLOOR INSIDE ROOM 103 FIRST DRAW**	**10.0**	1.0	

Technical Supervisor: F. Ramezanzaden 9/14/97 Analyst: FR

Farid Ramezanzaden, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **48315**
Total Samples 12
Date Sampled 9/9/97
Date Received 9/9/97
Date Analyzed 9/10/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~35-B~~ 20B Micro 48315-11 DRINKING FOUNTAIN FIRST FLOOR INSIDE ROOM 103 FIRST DRAW	2.5	1.0	
Client ~~35-C~~ 20C Micro 48315-12 DRINKING FOUNTAIN FIRST FLOOR INSIDE ROOM 103 FIRST DRAW	2.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **49220**
Total Samples 10
Date Sampled 10/3/97
Date Received 10/4/97
Date Analyzed 10/4/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **14A** Micro 49220-01 **DRINKING FOUNTAIN** **BASEMENT LEVEL - GIRL'S GYM BATHROOM** **FIRST DRAW**	**1.4**	1.0	
Client **14B** Micro 49220-02 **DRINKING FOUNTAIN** **BASEMENT LEVEL - GIRL'S GYM BATHROOM** **FIRST DRAW**	**1.3**	1.0	
Client **14C** Micro 49220-03 **DRINKING FOUNTAIN** **BASEMENT LEVEL - GIRL'S GYM BATHROOM** **FIRST DRAW**	**1.2**	1.0	
Client **17A** Micro 49220-04 **DRINKING FOUNTAIN** **FIRST FLOOR - GYMNASIUM NORTH / EAST** **FIRST DRAW**	< **1.0**	1.0	
Client **17B** Micro 49220-05 **DRINKING FOUNTAIN** **FIRST FLOOR - GYMNASIUM NORTH / EAST** **FIRST DRAW**	< **1.0**	1.0	

Technical Supervisor: _____ 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL JH

Micro Log In **49220**
Total Samples 10
Date Sampled 10/3/97
Date Received 10/4/97
Date Analyzed 10/4/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **17C** Micro 49220-06 **DRINKING FOUNTAIN** **FIRST FLOOR - GYMNASIUM NORTH / EAST** **FIRST DRAW**	< **1.0**	1.0	
Client **18A** Micro 49220-07 **MULTIPLE DRINKING FOUNTAIN** **FIRST FLOOR - OUTSIDE GYM ROOM 130** **FIRST DRAW**	< **1.0**	1.0	
Client **18B** Micro 49220-08 **MULTIPLE DRINKING FOUNTAIN** **FIRST FLOOR - OUTSIDE GYM ROOM 130** **FIRST DRAW**	< **1.0**	1.0	
Client **18C** Micro 49220-09 **MULTIPLE DRINKING FOUNTAIN** **FIRST FLOOR - OUTSIDE GYM ROOM 130** **FIRST DRAW**	< **1.0**	1.0	
Client **BLANK** Micro 49220-10 **BLANK**	< **1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL

Micro Log In **52059**
Total Samples 9
Date Sampled 1/14/98
Date Received 1/14/98
Date Analyzed 1/15/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **21A** Micro 52059-01 **DRINKING FOUNTAIN ROOM 104 RESAMPLE**	**2.0**	1.0	
Client **21B** Micro 52059-02 **DRINKING FOUNTAIN ROOM 104 RESAMPLE**	**1.4**	1.0	
Client **21C** Micro 52059-03 **DRINKING FOUNTAIN ROOM 104 RESAMPLE**	**3.9**	1.0	
Client **22A** Micro 52059-04 **DRINKING FOUNTAIN ROOM 105 RESAMPLE**	**4.4**	1.0	
Client **22B** Micro 52059-05 **DRINKING FOUNTAIN ROOM 105 RESAMPLE**	**2.7**	1.0	

Technical Supervisor: F Ramezanzadeh 1/15/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL

Micro Log In **52059**
Total Samples 9
Date Sampled 1/14/98
Date Received 1/14/98
Date Analyzed 1/15/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **22C** Micro 52059-06 **DRINKING FOUNTAIN ROOM 105 RESAMPLE**	**6.6**	1.0	
Client **23A** Micro 52059-07 **DRINKING FOUNTAIN ROOM 106 RESAMPLE**	**15.6**	1.0	
Client **23B** Micro 52059-08 **DRINKING FOUNTAIN ROOM 106 RESAMPLE**	**7.6**	1.0	
Client **23C** Micro 52059-09 **DRINKING FOUNTAIN ROOM 106 RESAMPLE**	**16.0**	1.0	

Technical Supervisor: _____ 1/15/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL MS

Micro Log In **52164**
Total Samples 9
Date Sampled 1/17/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **POTRERO HILL 21A** Micro 52164-01 **DRINKING FOUNTAIN 104**	**3.4**	1.0	
Client **POTRERO HILL 21B** Micro 52164-02 **DRINKING FOUNTAIN 104**	**3.3**	1.0	
Client **POTRERO HILL 21C** Micro 52164-03 **DRINKING FOUNTAIN 104**	**10.4**	1.0	
Client **POTRERO HILL 22A** Micro 52164-04 **DRINKING FOUNTAIN 105**	**2.7**	1.0	
Client **POTRERO HILL 22B** Micro 52164-05 **DRINKING FOUNTAIN 105**	**4.2**	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL MS

Micro Log In **52164**
Total Samples 9
Date Sampled 1/17/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **POTRERO HILL 22C** Micro 52164-06 **DRINKING FOUNTAIN 105**	**13.2**	1.0	
Client **POTRERO HILL 23A** Micro 52164-07 **DRINKING FOUNTAIN 106**	**16.7**	1.0	
Client **POTRERO HILL 23B** Micro 52164-08 **DRINKING FOUNTAIN 106**	**7.3**	1.0	
Client **POTRERO HILL 23C** Micro 52164-09 **DRINKING FOUNTAIN 106**	**20.6**	1.0	

Technical Supervisor: F. Ramezanzadeh 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL MS

Micro Log In 52533
Total Samples 3
Date Sampled 1/31/98
Date Received 2/2/98
Date Analyzed 2/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client POTRERO HILL 13A Micro 52533-01 MULTIPLE DRINKING FOUNTAIN YARD RESAMPLE	1.7	1.0	
Client POTRERO HILL 13B Micro 52533-02 MULTIPLE DRINKING FOUNTAIN RESAMPLE	< 1.0	1.0	
Client POTRERO HILL 13C Micro 52533-03 MULTIPLE DRINKING FOUNTAIN RESAMPLE	2.2	1.0	

Technical Supervisor: F. Ramezanzadeh 2/4/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
POTRERO HILL MS

Micro Log In **52568**
Total Samples 3
Date Sampled 2/2/98
Date Received 2/3/98
Date Analyzed 2/4/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client POTRERO HILL ~~16A~~ 15A Micro 52568-01 MULTIPLE DF YARD - RESAMPLE	4.2	1.0	
Client POTRERO HILL ~~16B~~ 15B Micro 52568-02 MULTIPLE DF YARD - RESAMPLE	1.9	1.0	
Client POTRERO HILL ~~16C~~ 15C Micro 52568-03 MULTIPLE DF YARD - RESAMPLE	5.2	1.0	

Technical Supervisor: F. Ramezanzadeh 2/4/98 Analyst: FR/JS

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: Potrero Hill Neighborhood
Lab Proj. ID: 9710G14

Sampled: 10/29/97
Received: 10/29/97
Analyzed: see below

Reported: 11/03/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710G14-01 Sample Desc : **LIQUID,1**				
Lead	mg/L	10/31/97	0.0050	N.D.
Lab No: 9710G14-02 Sample Desc : **LIQUID,2**				
Lead	mg/L	10/31/97	0.0050	N.D.
Lab No: 9710G14-03 Sample Desc : **LIQUID,3**				
Lead	mg/L	10/31/97	0.0050	N.D.
Lab No: 9710G14-04 Sample Desc : **LIQUID,4**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.028**
Lab No: 9710G14-05 Sample Desc : **LIQUID,4-Duplicate**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.029**
Lab No: 9710G14-06 Sample Desc : **LIQUID,5-Blank**				
Lead	mg/L	10/31/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO CC #7

Micro Log In **47782**
Total Samples 21
Date Sampled 8/23/97
Date Received 9/1/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 7-1 Micro 47782-01 SINK FAUCET ROOM #1 KITCHEN FAUCET FIRST DRAW	1.6	1.0	
Client 7-2 Micro 47782-02 SINK FAUCET ROOM #2 KITCHEN FAUCET FIRST DRAW	5.2	1.0	
Client 7-3 Micro 47782-03 DRINKING FOUNTAIN CORRIDOR ADJACENT TO ROOMS 3 & 4 FIRST DRAW	< 1.0	1.0	
Client 7-4 Micro 47782-04 SINK DRINKING FOUNTAIN ROOM #4 SINK DRINKING FOUNTAIN FIRST DRAW	< 1.0	1.0	
Client 7-5 Micro 47782-05 SINK DRINKING FOUNTAIN ROOM #3 SINK DRINKING FOUNTAIN FIRST DRAW	1.6	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO CC #7

Micro Log In **47782**
Total Samples 21
Date Sampled 8/23/97
Date Received 9/1/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 7-6 Micro 47782-06 SINK FAUCET SINK FOUNTAIN IN MAIN KITCHEN FIRST DRAW	6.7	1.0	
Client 7-7 Micro 47782-07 SINK FAUCET SINK FOUNTAIN IN MAIN KITCHEN ADJACENT TO STOVE FIRST DRAW	1.1	1.0	
Client 7-8 Micro 47782-08 SINK FAUCET SINK FOUNTAIN IN EMPLOYEE BREAKROOM FIRST DRAW	6.3	1.0	
Client 7-9 Micro 47782-09 SINK DRINKING FOUNTAIN ROOM #5 SINK DRINKING FOUNTAIN FIRST DRAW	1.1	1.0	
Client 7-10 Micro 47782-10 SINK DRINKING FOUNTAIN ROOM #5 ADJ TO ACTIVITY ROOM FIRST DRAW	< 1.0	1.0	

Technical Supervisor: 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO CC #7

Micro Log In **47782**
Total Samples 21
Date Sampled 8/23/97
Date Received 9/1/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 7-11 Micro 47782-11 SINK DRINKING FOUNTAIN ROOM #12 SINK DRINKING FOUNTAIN FIRST DRAW	3.1	1.0	
Client 7-12 Micro 47782-12 SINK FAUCET ROOM #12 SINK FOUNTAIN CLOSER TO ACTIVITY ROOM FIRST DRAW	15.0	1.0	
Client 7-13 Micro 47782-13 SINK DRINKING FOUNTAIN ROOM #10 SINK DRINKING FOUNTAIN FIRST DRAW	2.2	1.0	
Client 7-14 Micro 47782-14 SINK DRINKING FOUNTAIN ROOM #7 SINK DRINKING FOUNTAIN FIRST DRAW	1.8	1.0	
Client 7-15 Micro 47782-15 SINK DRINKING FOUNTAIN ROOM #9 SINK DRINKING FOUNTAIN FIRST DRAW	1.8	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO CC #7

Micro Log In **47782**
Total Samples 21
Date Sampled 8/23/97
Date Received 9/1/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **7-16** Micro 47782-16 **SINK DRINKING FOUNTAIN ROOM #8 SINK DRINKING FOUNTAIN FIRST DRAW**	< **1.0**	1.0	
Client **7-17** Micro 47782-17 **DRINKING FOUNTAIN OUTSIDE DRINKING FOUNTAIN ADJ TO ROOM 11 FIRST DRAW**	**16.2**	1.0	
Client **7-18** Micro 47782-18 **DRINKING FOUNTAIN OUTSIDE DRINKING FOUNTAIN ADJ TO ROOM #5 FIRST DRAW**	**5.3**	1.0	
Client **7-19** Micro 47782-19 **DRINKING FOUNTAIN OUTSIDE DRINKING FOUNTAIN ADJ TO ROOM 5 FIRST DRAW**	**12.3**	1.0	
Client **7-20** Micro 47782-20 **DRINKING FOUNTAIN FIRST DRAW**	**21.1**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO CC #7

Micro Log In **47782**
Total Samples 21
Date Sampled 8/23/97
Date Received 9/1/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: BLANK Micro 47782-21 BLANK	< 1.0	1.0	

Technical Supervisor: 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO CC

Micro Log In **50560**
Total Samples 8
Date Sampled 11/6/97
Date Received 11/11/97
Date Analyzed 11/13/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **7-17A** Micro 50560-01 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN OUTSIDE ROOM 11** **1ST DRAW**	**5.8**	1.0	
Client **7-17B** Micro 50560-02 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN OUTSIDE ROOM 11** **2ND DRAW**	**5.5**	1.0	
Client **7-17C** Micro 50560-03 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN ROOM 11** **3RD DRAW**	**5.5**	1.0	
Client **7-19A** Micro 50560-04 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN OUTSIDE ROOM 5** **1ST DRAW**	**2.7**	1.0	
Client **7-19B** Micro 50560-05 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN OUTSIDE ROOM 5** **2ND DRAW**	**2.1**	1.0	

Technical Supervisor: F. Ramezanzadeh 11/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO CC

Micro Log In **50560**
Total Samples 8
Date Sampled 11/6/97
Date Received 11/11/97
Date Analyzed 11/13/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: **7-19C** Micro 50560-06 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN OUTSIDE ROOM 5** **3RD DRAW**	**3.4**	1.0	
Client: **SPIKE 1** Micro 50560-07 **SPIKE** **97-WOO-771-8**	**10.2**	1.0	
Client: **BLANK - 1** Micro 50560-08 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 11/13/97 Analyst: FR
Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO MS

Micro Log In **47904**
Total Samples 16
Date Sampled 8/26/97
Date Received 8/25/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 47904-01 MULTIPLE DRINKING FOUNTAIN OUTSIDE LOWER YARD INITIAL DRAW	5.9	1.0	
Client # 2 Micro 47904-02 MULTIPLE DRINKING FOUNTAIN OUTSIDE YARD BY STAIRWAY INITIAL DRAW	4.4	1.0	
Client # 3 Micro 47904-03 DRINKING FOUNTAIN CORRIDOR C90 SOUTH SIDE - 1ST FLOOR INITIAL DRAW	32.6	1.0	
Client # 4 Micro 47904-04 DRINKING FOUNTAIN CORRIDOR C90 NORTH SIDE - 1ST FLOOR INITIAL DRAW	4.8	1.0	
Client # 5 Micro 47904-05 DRINKING FOUNTAIN CORRIDOR C90 SOUTH SIDE - 2ND FLOOR INITIAL DRAW	46.9	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO MS

Micro Log In **47904**
Total Samples 16
Date Sampled 8/26/97
Date Received 8/28/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 6 Micro 47904-06 DRINKING FOUNTAIN CORRIDOR C90 NORTH SIDE - 2ND FLOOR INITIAL DRAW	11.3	1.0	
Client # 7 Micro 47904-07 DRINKING FOUNTAIN CORRIDOR C90 SOUTH SIDE - THIRD FLOOR INITIAL DRAW	48.7	1.0	
Client # 8 Micro 47904-08 DRINKING FOUNTAIN CORRIDOR C90 NORTH SIDE - THIRD FLOOR INITIAL DRAW	6.9	1.0	
Client # 9 Micro 47904-09 SINK FAUCET KITCHEN ROOM 213, 2ND FLOOR INITIAL DRAW	<1.0	1.0	
Client # 10 Micro 47904-10 SINK FAUCET KITCHEN ROOM 213, SECOND FLOOR INITIAL DRAW	<1.0	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO MS

Micro Log In **47904**
Total Samples 16
Date Sampled 8/26/97
Date Received 8/28/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 11 Micro 47904-11 **SINK FAUCET** **KITCHEN ROOM 213, 2ND FLOOR** **INITIAL DRAW**	**1.1**	1.0	
Client # 12 Micro 47904-12 **DRINKING FOUNTAIN** **ROOM 230, 2ND FLOOR** **INITIAL DRAW**	**9.2**	1.0	
Client # 13 Micro 47904-13 **DRINKING FOUNTAIN** **CORRIDOR C-95, 1ST FLOOR** **INITIAL DRAW**	**<1.0**	1.0	
Client # 14 Micro 47904-14 **DRINKING FOUNTAIN** **AREA 147A, FIRST FLOOR** **INITIAL DRAW**	**36.6**	1.0	
Client # 15 Micro 47904-15 **BLANK**	**<1.0**	1.0	

Technical Supervisor: _____ 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO MS

Micro Log In **47904**
Total Samples 16
Date Sampled 8/26/97
Date Received 8/28/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 16 Micro 47904-16 **DRINKING FOUNTAIN ROOM 021, BASEMENT INITIAL DRAW**	**181**	5.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO MS

Micro Log In **49321**
Total Samples 12
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **1 A** Micro 49321-01 **DRINKING FOUNTAIN ROOM 147A, 1ST FLOOR RE-SAMPLE**	< **1.0**	1.0	
Client **1 B** Micro 49321-02 **DRINKING FOUNTAIN ROOM 147A,1ST FLOOR RE-SAMPLE**	**2.0**	1.0	
Client **1 C** Micro 49321-03 **DRINKING FOUNTAIN ROOM 147A, 1ST FLOOR RE-SAMPLE**	< **1.0**	1.0	
Client **2 A** Micro 49321-04 **DRINKING FOUNTAIN CORRIDOR C-90, 1ST FLOOR RE-SAMPLE**	**1.5**	1.0	
Client **2 B** Micro 49321-05 **DRINKING FOUNTAIN CORRIDOR C-90, 1ST FLOOR RE-SAMPLE**	< **1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO MS

Micro Log In **49321**
Total Samples 12
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **2C** Micro 49321-06 **DRINKING FOUNTAIN CORRIDOR C-90, 1ST FLOOR RE-SAMPLE**	**1.4**	1.0	
Client **3A** Micro 49321-07 **DRINKING FOUNTAIN CORRIDOR C-90, 2ND FLOOR RE-SAMPLE**	**2.6**	1.0	
Client **3B** Micro 49321-08 **DRINKING FOUNTAIN CORRIDOR C-90, 2ND FLOOR RE-SAMPLE**	**< 1.0**	1.0	
Client **3C** Micro 49321-09 **DRINKING FOUNTAIN CORRIDOR C-90, 2ND FLOOR RE-SAMPLE**	**< 1.0**	1.0	
Client **4A** Micro 49321-10 **DRINKING FOUNTAIN CORRIDOR C-90, 2RD FLOOR RE-SAMPLE**	**103.2**	3.3	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO MS

Micro Log In **49321**
Total Samples 12
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **4B** Micro 49321-11 **DRINKING FOUNTAIN CORRIDOR C-90, 3RD FLOOR RE-SAMPLE**	< **1.0**	1.0	
Client **4C** Micro 49321-12 **DRINKING FOUNTAIN CORRIDOR C-90, 3RD FLOOR RE-SAMPLE**	**1.5**	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO MS

Micro Log In **51849**
Total Samples 6
Date Sampled 1/6/98
Date Received 1/6/98
Date Analyzed 1/7/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 5A Micro 51849-01 DRINKING FOUNTAIN CORRIDOR C90 SOUTH SIDE 2ND FLOOR RESAMPLE	7.7	1.0	
Client 5B Micro 51849-02 DRINKING FOUNTAIN CORRIDOR C90 SOUTH SIDE 2ND FLOOR RESAMPLE	6.8	1.0	
Client 5C Micro 51849-03 DRINKING FOUNTAIN CORRIDOR C90 SOUTH SIDE 2ND FLOOR RESAMPLE	11.3	1.0	
Client 14A Micro 51849-04 DRINKING FOUNTAIN AREA 147A FIRST FLOOR OFF GIRLS LOCKER RESAMPLE	3.8	1.0	
Client 14B Micro 51849-05 DRINKING FOUNTAIN AREA 147A FIRST FLOOR OFF GIRLS LOCKER RESAMPLE	2.9	1.0	

Technical Supervisor: F. R. 1/7/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PRESIDIO MS

Micro Log In **51849**
Total Samples 6
Date Sampled 1/6/98
Date Received 1/6/98
Date Analyzed 1/7/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: 14C Micro: 51849-06 DRINKING FOUNTAIN AREA 147A FIRST FLOOR OFF GIRLS LOCKER RESAMPLE	7.0	1.0	

Technical Supervisor: F. Ramezanzadeh 1/7/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 19th edition, 1992. American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
REDDING ELEMENTARY
PK / CC

Micro Log In **47848**
Total Samples **11**
Date Sampled **8/25/97**
Date Received **8/27/97**
Date Analyzed **8/31/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47848-01 MULTIPLE DRINKING FOUNTAIN OUTSIDE PLAYGROUND FIRST DRAW	< 1.0	1.0	
Client 2 Micro 47848-02 MULTIPLE DRINKING FOUNTAIN OUTSIDE PLAYGROUND FIRST DRAW	< 1.0	1.0	
Client 3 Micro 47848-03 MULTIPLE DRINKING FOUNTAIN OUTSIDE PLAYGROUND FIRST DRAW	< 1.0	1.0	
Client 4 Micro 47848-04 MULTIPLE DRINKING FOUNTAIN OUTSIDE PLAYGROUND FIRST DRAW	9.3	1.0	
Client 5 Micro 47848-05 SINK FAUCET FACULTY ROOM FIRST DRAW	< 1.0	1.0	

Technical Supervisor: _____ 8/31/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
REDDING ELEMENTARY
PK / CC

Micro Log In **47848**
Total Samples 11
Date Sampled 8/25/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **6** Micro 47848-06 **SINK FAUCET KITCHEN FIRST DRAW**	< **1.0**	1.0	
Client **7** Micro 47848-07 **DRINKING FOUNTAIN 2ND FLOOR HALLWAY FIRST DRAW**	**1.2**	1.0	
Client **8** Micro 47848-08 **DRINKING FOUNTAIN 2ND FLOOR HALLWAY FIRST DRAW**	**18.4**	1.0	
Client **9** Micro 47848-09 **DRINKING FOUNTAIN 3RD FLOOR HALLWAY FIRST DRAW**	**2.6**	1.0	
Client **10** Micro 47848-10 **BLANK**	< **1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 8/31/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
REDDING ELEMENTARY
PK / CC

Micro Log In **47848**
Total Samples 11
Date Sampled 8/25/97
Date Received 8/27/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47848-11 **SPIKED SAMPLE**	**47.2**	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
REDDING PK

Micro Log In **49289**
Total Samples 4
Date Sampled 10/3/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **8A** Micro 49289-01 **DRINKING FOUNTAIN 2ND FLOOR HALLWAY FIRST DRAW**	**1.4**	1.0	
Client **8B** Micro 49289-02 **DRINKING FOUNTAIN 2ND FLOOR HALLWAY SECOND DRAW**	**1.1**	1.0	
Client **8C** Micro 49289-03 **DRINKING FOUNTAIN 2ND FLOOR HALLWAY THIRD DRAW**	**1.2**	1.0	
Client **13B** Micro 49289-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 10/12/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PAUL REVERE ES / ANNEX

Micro Log In **47847**
Total Samples 35
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47847-01 SINK DRINKING FOUNTAIN ROOM 214 FIRST DRAW	< 1.0	1.0	
Client 2 Micro 47847-02 SINK DRINKING FOUNTAIN ROOM 215 FIRST DRAW	< 1.0	1.0	
Client 3 Micro 47847-03 SINK DRINKING FOUNTAIN ROOM 213 FIRST DRAW	< 1.0	1.0	
Client 4 Micro 47847-04 SINK DRINKING FOUNTAIN ROOM 211 FIRST DRAW	< 1.0	1.0	
Client 5 Micro 47847-05 SINK DRINKING FOUNTAIN ROOM 209 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PAUL REVERE ES / ANNEX

Micro Log In 47847
Total Samples 35
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47847-06 DRINKING FOUNTAIN 2ND FLOOR HALL FIRST DRAW	< 1.0	1.0	
Client 7 Micro 47847-07 SINK DRINKING FOUNTAIN ROOM 208 FIRST DRAW	1.1	1.0	
Client 8 Micro 47847-08 SINK DRINKING FOUNTAIN ROOM 207 FIRST DRAW	< 1.0	1.0	
Client 9 Micro 47847-09 SINK DRINKING FOUNTAIN ROOM 205 FIRST DRAW	1.3	1.0	
Client 10 Micro 47847-10 SINK DRINKING FOUNTAIN ROOM 203 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PAUL REVERE ES / ANNEX

Micro Log In **47847**
Total Samples 35
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47847-11 SINK DRINKING FOUNTAIN ROOM 201 FIRST DRAW	< 1.0	1.0	
Client 12 Micro 47847-12 SINK DRINKING FOUNTAIN ROOM 202 FIRST DRAW	< 1.0	1.0	
Client 13 Micro 47847-13 SINK DRINKING FOUNTAIN ROOM 210 FIRST DRAW	1.2	1.0	
Client 14 Micro 47847-14 DRINKING FOUNTAIN 1ST FLOOR HALL FIRST DRAW	< 1.0	1.0	
Client 15 Micro 47847-15 MULTIPLE DRINKING FOUNTAIN PLAY YARD FIRST DRAW	< 1.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PAUL REVERE ES / ANNEX

Micro Log In **47847**
Total Samples 35
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47847-16 **BLANK**	< 1.0	1.0	
Client 17 Micro 47847-17 **SINK DRINKING FOUNTAIN ANNEX 116 FIRST DRAW**	1.6	1.0	
Client 18 Micro 47847-18 **SINK DRINKING FOUNTAIN ANNES 105 FIRST DRAW**	1.6	1.0	
Client 19 Micro 47847-19 **SINK DRINKING FOUNTAIN ANNEX 106 FIRST DRAW**	1.7	1.0	
Client 20 Micro 47847-20 **SINK DRINKING FOUNTAIN ANNEX 113 FIRST DRAW**	9.9	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PAUL REVERE ES / ANNEX

Micro Log In **47847**
Total Samples 35
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **21** Micro 47847-21 **SINK DRINKING FOUNTAIN ANNEX 121 FIRST DRAW**	< **1.0**	1.0	
Client **22** Micro 47847-22 **SINK DRINKING FOUNTAIN ANNEX 122 FIRST DRAW**	< **1.0**	1.0	
Client **23** Micro 47847-23 **SINK DRINKING FOUNTAIN ANNEX 114 FIRST DRAW**	< **1.0**	1.0	
Client **24** Micro 47847-24 **SINK DRINKING FOUNTAIN ANNEX 115 FIRST DRAW**	**1.4**	1.0	
Client **25** Micro 47847-25 **SINK FAUCET ANNEX OFFICE FIRST DRAW**	**1.2**	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PAUL REVERE ES / ANNEX

Micro Log In **47847**
Total Samples 35
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **26** Micro 47847-26 **SINK DRINKING FOUNTAIN ANNEX RM 211 FIRST DRAW**	**1.8**	1.0	
Client **27** Micro 47847-27 **SINK DRINKING FOUNTAIN ANNEX RM 201 FIRST DRAW**	**2.5**	1.0	
Client **28** Micro 47847-28 **SINK DRINKING FOUNTAIN ANNEX RM 212 FIRST DRAW**	**1.0**	1.0	
Client **29** Micro 47847-29 **SINK DRINKING FOUNTAIN ANNEX RM 202 FIRST DRAW**	**2.3**	1.0	
Client **30** Micro 47847-30 **SINK DRINKING FOUNTAIN ANNEX RM 209 FIRST DRAW**	**2.6**	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
PAUL REVERE ES / ANNEX

Micro Log In **47847**
Total Samples 35
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 31 Micro 47847-31 SINK DRINKING FOUNTAIN ANNEX RM 217 FIRST DRAW	< 1.0	1.0	
Client 32 Micro 47847-32 SINK FAUCET FACULTY ROOM	1.3	1.0	
Client 33 Micro 47847-33 MULTIPLE DRINKING FOUNTAIN PLAYGROUND FIRST DRAW	1.5	1.0	
Client 34 Micro 47847-34 MULTIPLE DRINKING FOUNTAIN ANNEX HALLWAY FIRST DRAW	4.6	1.0	
Client 35 Micro 47847-35 SPIKED SAMPLE	49.4	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOFTOP ES

Micro Log In 48049
Total Samples 14
Date Sampled 9/1/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48049-01 DRINKING FOUNTAIN C-90 (S) - 1ST FLOOR INITIAL SCREENING	3.5	1.0	
Client 2 Micro 48049-02 DRINKING FOUNTAIN C-90 (MID) - 1ST FLOOR INITIAL SCREENING	2.4	1.0	
Client 3 Micro 48049-03 DRINKING FOUNTAIN C-90 (N) - 1ST FLOOR INITIAL SCREENING	2.9	1.0	
Client 4 Micro 48049-04 SINK FAUCET TEACHERS' LUNCH ROOM R-104 INITIAL SCREENING	10.7	1.0	
Client 5 Micro 48049-05 SINK FAUCET KITCHEN R-110 A INITIAL SCREENING	3.1	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOFTOP ES

Micro Log In **48049**
Total Samples 14
Date Sampled 9/1/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 48049-06 DRINKING FOUNTAIN C-90 (S) - BASEMENT LEVEL INITIAL SCREENING	3.9	1.0	
Client 7 Micro 48049-07 DRINKING FOUNTAIN 007 INITIAL SCREENING	5.0	1.0	
Client 8 Micro 48049-08 DRINKING FOUNTAIN 005 INITIAL SCREENING	6.0	1.0	
Client 9 Micro 48049-09 DRINKING FOUNTAIN C-91- BASEMENT LEVEL INITIAL SCREENING	1.8	1.0	
Client 10 Micro 48049-10 DRINKING FOUNTAIN C-90 (N) - BASEMENT LEVEL INITIAL SCREENING	6.2	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOFTOP ES

Micro Log In 48049
Total Samples 14
Date Sampled 9/1/97
Date Received 9/3/97
Date Analyzed 9/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 48049-11 MULTIPLE DRINKING FOUNTAIN EXT. YARD EAST YARD (GATE) INITIAL SCREENING	21.4	1.0	
Client 12 Micro 48049-12 MULTIPLE DRINKING FOUNTAIN EXT. YARD WEST YARD (FENCE) INITIAL SCREENING	7.2	1.0	
Client 13 Micro 48049-13 MULTIPLE DRINKING FOUNTAIN EXT. YARD WEST YARD INITIAL SCREENING	4.2	1.0	
Client 14 Micro 48049-14 BLANK	< 1.0	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOFTOP MS

Micro Log In **49318**
Total Samples 4
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 49318-01 MULTIPLE DRINKING FOUNTAIN ROOF INITIAL SCREENING	25.5	1.0	
Client 2 Micro 49318-02 DRINKING FOUNTAIN R-203 INITIAL SCREENING	2.8	1.0	
Client 3 Micro 49318-03 DRINKING FOUNTAIN R-203 INITIAL SCREENING	3.4	1.0	
Client 4 Micro 49318-04 BLANK	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOFTOP MS
WORK ORDER NO. WT-97

Micro Log In **50108**
Total Samples 13
Date Sampled 10/25/97
Date Received 10/30/97
Date Analyzed 10/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 4 Micro 50108-01 DRINKING FOUNTAIN R-214 INITIAL SCREENING	1.7	1.0	
Client 5 Micro 50108-02 DRINKING FOUNTAIN R-213 INITIAL SCREENING	2.4	1.0	
Client 6 Micro 50108-03 DRINKING FOUNTAIN R-212 INITIAL SCREENING	< 1.0	1.0	
Client 7 Micro 50108-04 DRINKING FOUNTAIN R-211 INITIAL SCREENING	1.1	1.0	
Client 8 Micro 50108-05 DRINKING FOUNTAIN R-310 INITIAL SCREENING	< 1.0	1.0	

Technical Supervisor: _____ 10/30/97 Analyst: FR
Farid Ramazanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

Rooftop MS

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOFTOP MS
WORK ORDER NO. WT-97

Micro Log In **50108**
Total Samples 13
Date Sampled 10/25/97
Date Received 10/30/97
Date Analyzed 10/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 9 Micro 50108-06 DRINKING FOUNTAIN R-312 INITIAL SCREENING	1.1	1.0	
Client 10 Micro 50108-07 DRINKING FOUNTAIN R-311 INITIAL SCREENING	2.2	1.0	
Client 11 Micro 50108-08 DRINKING FOUNTAIN R-313 INITIAL SCREENING	2.1	1.0	
Client 12 Micro 50108-09 DRINKING FOUNTAIN 3RD FLOOPR C-90 INITIAL SCREENING	22.4	1.0	
Client 13 Micro 50108-10 DRINKING FOUNTAIN R-152 PERFORMING ARTS INITIAL SCREENING	< 1.0	1.0	

Technical Supervisor: 10/30/97 Analyst: PR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (*Standard Methods for the Examination of Water and Wastewater*, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOFTOP MS

Micro Log In **50907**
Total Samples 3
Date Sampled 11/20/97
Date Received 11/24/97
Date Analyzed 11/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **1 A** Micro 50907-01 **MULTIPLE DRINKING FOUNTAIN ROOF PLAY ROOM NORTHEAST END RE-SAMPLE**	**4.3**	1.0	
Client **1 B** Micro 50907-02 **MULTIPLE DRINKING FOUNTAIN ROOF PLAY ROOM NORTHEAST END RE-SAMPLE**	**3.9**	1.0	
Client **1 C** Micro 50907-03 **MULTIPLE DRINKING FOUNTAIN ROOF PLAY ROOM NORTHEAST END RE-SAMPLE**	**16.8**	1.0	

Technical Supervisor: F Ramezanzadeh 11/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOFTOP MS
WORK ORDER NO. WT-97

Micro Log In **50108**
Total Samples 13
Date Sampled 10/25/97
Date Received 10/30/97
Date Analyzed 10/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 14 Micro 50108-11 SINK FAUCET R-155 TEACHER LOUNGE INITIAL SCREENING	4.3	1.0	
Client 15 Micro 50108-12 DRINKING FOUNTAIN LOWER EXT. YARD INITIAL SCREENING	5.8	1.0	
Client 16 Micro 50108-13 DRINKING FOUNTAIN UPPER EXT. YARD INITIAL SCREENING	2.2	1.0	

Technical Supervisor: _____ 10/30/97 Analyst: FR
Farid Rameranzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S. F. U. S. D.
ROOSEVELT MS

Micro Log In **48275**
Total Samples 29
Date Sampled 9/7/97
Date Received 9/8/97
Date Analyzed 9/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48275-01 MULTIPLE DRINKING FOUNTAIN EXT. YARD C-97, EAST INITIAL SCREENING	**11.4**	1.0	
Client 2 Micro 48275-02 MULTIPLE DRINKING FOUNTAIN EXT. YARD C-97, WEST INITIAL SCREENING	**4.6**	1.0	
Client 3 Micro 48275-03 MULTIPLE DRINKING FOUNTAIN EXT. YARD EAST INITIAL SCREENING	**21.5**	1.0	
Client 4 Micro 48275-04 MULTIPLE DRINKING FOUNTAIN EXT. YARD C-96, EAST INITIAL SCREENING	**3.7**	1.0	
Client 5 Micro 48275-05 MULTIPLE DRINKING FOUNTAIN EXT. YARD C-96, WEST INITIAL SCREENING	**2.9**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/9/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S. F. U. S. D.
ROOSEVELT MS

Micro Log In **48275**
Total Samples 29
Date Sampled 9/7/97
Date Received 9/8/97
Date Analyzed 9/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 48275-06 DRINKING FOUNTAIN 1ST FLOOR C-92, NORTH INITIAL SCREENING	6.6	1.0	
Client 7 Micro 48275-07 DRINKING FOUNTAIN 1ST FLOOR C-92, SOUTH INITIAL SCREENING	4.3	1.0	
Client 8 Micro 48275-08 SINK FAUCET 120C, KITCHEN NORTH SINK INITIAL SCREENING	24.8	1.0	
Client 9 Micro 48275-09 SINK FAUCET 120C, KITCHEN CENTER SINK INITIAL SCREENING	5.5	1.0	
Client 10 Micro 48275-10 SINK FAUCET 120C, KITCHEN SOUTH SINK INITIAL SCREENING	3.3	1.0	

Technical Supervisor: F. Ramezanzadeh 9/9/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S. F. U. S. D.
ROOSEVELT MS

Micro Log In **48275**
Total Samples 29
Date Sampled 9/7/97
Date Received 9/8/97
Date Analyzed 9/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 48275-11 POT FILLER 120 KITCHEN POT FILLER, CENTER INITIAL SCREENING	38.3	1.0	
Client 12 Micro 48275-12 SINK FAUCET 120 KITCHEN SOUTH WALL INITIAL SCREENING	2.8	1.0	
Client 13 Micro 48275-13 DRINKING FOUNTAIN 2ND FLOOR C-92, NORTH INITIAL SCREENING	7.4	1.0	
Client 14 Micro 48275-14 SINK FAUCET 2ND FLOOR ROOM 205 INITIAL SCREENING	3.0	1.0	
Client 15 Micro 48275-15 DRINKING FOUNTAIN 2ND FLOOR C-92, SOUTH INITIAL SCREENING	4.3	1.0	

Technical Supervisor: F. Ramezanzadeh 9/9/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S. F. U. S. D.
ROOSEVELT MS

Micro Log In **48275**
Total Samples 29
Date Sampled 9/7/97
Date Received 9/8/97
Date Analyzed 9/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 48275-16 DRINKING FOUNTAIN 2ND FLOOR C-95 INITIAL SCREENING	6.9	1.0	
Client 17 Micro 48275-17 DRINKING FOUNTAIN 2ND FLOOR R.212 INITIAL SCREENING	4.6	1.0	
Client 18 Micro 48275-18 DRINKING FOUNTAIN 3RD FLOOR C-92, NORTH INITIAL SCREENING	9.8	1.0	
Client 19 Micro 48275-19 DRINKING FOUNTAIN 3RD FLOOR C-92, SOUTH INITIAL SCREENING	4.5	1.0	
Client 20 Micro 48275-20 DRINKING FOUNTAIN 3RD FLOOR C-93 INITIAL SCREENING	11.4	1.0	

Technical Supervisor: F. Ramezanzadeh 9/9/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S. F. U. S. D.
ROOSEVELT MS

Micro Log In **48275**
Total Samples 29
Date Sampled 9/7/97
Date Received 9/8/97
Date Analyzed 9/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 21 Micro 48275-21 DRINKING FOUNTAIN 3RD FLOOR C-95, GIRLS LOCKER RM. INITIAL SCREENING	4.7	1.0	
Client 22 Micro 48275-22 SINK FAUCET 3RD FLOOR HOME EC CLASS NORTH WALL INITIAL SCREENING	7.5	1.0	
Client 23 Micro 48275-23 SINK FAUCET 3RD FLOOR HOME EC CLASS NORTH WALL INITIAL SCREENING	3.1	1.0	
Client 24 Micro 48275-24 SINK FAUCET 3RD FLOOR HOME EC CLASS NORTH WALL INITIAL SCREENING	21.2	1.0	
Client 25 Micro 48275-25 SINK FAUCET 3RD FLOOR HOME EC CLASS NORTH WALL INITIAL SCREENING	4.5	1.0	

Technical Supervisor: F. Ramezanzadeh 9/9/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S. F. U. S. D.
ROOSEVELT MS

Micro Log In **48275**
Total Samples 29
Date Sampled 9/7/97
Date Received 9/8/97
Date Analyzed 9/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 26 Micro 48275-26 SINK FAUCET 3RD FLOOR HOME EC CLASS NORTH WALL INITIAL SCREENING	5.4	1.0	
Client 27 Micro 48275-27 SINK FAUCET 3RD FLOOR HOME EC CLASS NORTH WALL INITIAL SCREENING	4.9	1.0	
Client 28 Micro 48275-28 SINK FAUCET 3RD FLOOR HOME EC CLASS SOUTH WALL INITIAL SCREENING	4.5	1.0	
Client 29 Micro 48275-29 BLANK	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/9/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOSEVELT MS

Micro Log In **50906**
Total Samples 9
Date Sampled 11/20/97
Date Received 11/24/97
Date Analyzed 11/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **24A** Micro 50906-01 **SINK FAUCET** **3RD FLOOR HOME EC. EAST END NORTH WALL** **RE-SAMPLE**	**1.5**	1.0	
Client **24B** Micro 50906-02 **SINK FAUCET** **3RD FLOOR HOME EC. EAST END NORTH WALL** **RE-SAMPLE**	**1.2**	1.0	
Client **24C** Micro 50906-03 **SINK FAUCET** **3RD FLOOR HOME EC. EAST END NORTH WALL** **RE-SAMPLE**	**3.0**	1.0	
Client **11A** Micro 50906-04 **SINK FAUCET** **RM 120 KITCHEN POT FILLER - CENTER** **RE-SAMPLE**	**1.1**	1.0	
Client **11B** Micro 50906-05 **SINK FAUCET** **RM 120 KITCHEN POT FILLER - CENTER** **RE-SAMPLE**	**< 1.0**	1.0	

Technical Supervisor: 11/26/97
Farid Ramezanzadeh, M.S.

Analyst: FR

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ROOSEVELT MS

Micro Log In **50906**
Total Samples 9
Date Sampled 11/20/97
Date Received 11/24/97
Date Analyzed 11/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **11C** Micro 50906-06 **SINK FAUCET** **RM 120 KITCHEN POT FILLER - CENTER** **RE-SAMPLE**	**2.2**	1.0	
Client **8A** Micro 50906-07 **SINK FAUCET** **120C KITCHEN NORTH END WEST WALL** **RE-SAMPLE**	**1.8**	1.0	
Client **8B** Micro 50906-08 **SINK FAUCET** **120C KITCHEN NORTH END WEST WALL** **RE-SAMPLE**	**1.6**	1.0	
Client **8C** Micro 50906-09 **SINK FAUCET** **120C KITCHEN NORTH END WEST WALL** **RE-SAMPLE**	**5.7**	1.0	

Technical Supervisor: F. Ramezanzadeh 11/26/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Samoan Affairs CD

Lab Proj. ID: 9710G12

Sampled: 10/29/97
Received: 10/29/97
Analyzed: see below

Reported:

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710G12-01 Sample Desc : **LIQUID,1**				
Lead	mg/L	10/31/97	0.0050	N.D.
Lab No: 9710G12-02 Sample Desc : **LIQUID,2**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.0096**
Lab No: 9710G12-03 Sample Desc : **LIQUID,3**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.0078**
Lab No: 9710G12-04 Sample Desc : **LIQUID,4**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.032**
Lab No: 9710G12-05 Sample Desc : **LIQUID,4-Duplicate**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.032**
Lab No: 9710G12-06 Sample Desc : **LIQUID,5-Blank**				
Lead	mg/L	10/31/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SF CHARTER
EARLY CHILDHOOD

Micro Log In **47833**
Total Samples 9
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client CR-1 Micro 47833-01 DRINKING FOUNTAIN DRINKING FOUNTAIN ROOM 3 FIRST DRAW	< 1.0	1.0	
Client CR-2 Micro 47833-02 SINK FAUCET SINK FAUCET IN ROOM 4 FIRST DRAW	< 1.0	1.0	
Client CR-3 Micro 47833-03 DRINKING FOUNTAIN DRINKING FOUNTAIN IN ROOM 6 NOT ENOUGH PRESSURE FOR SAMPLE FIRST DRAW	1.9	1.0	NOT ENOUGH PRESSURE FOR SAMPLE
Client CR-4 Micro 47833-04 SINK DRINKING FOUNTAIN SINK DRINKING FOUNTAIN ROOM 1 - KINDERGARTEN ROOM FIRST DRAW	< 1.0	1.0	
Client CR-5 Micro 47833-05 SINK DRINKING FOUNTAIN SINK DRINKING FOUNTAIN ROOM 2 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SF CHARTER
EARLY CHILDHOOD

Micro Log In **47833**
Total Samples 9
Date Sampled 8/26/97
Date Received 8/26/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **CR-6** Micro 47833-06 **SINK FAUCET** **SINK FAUCET IN KITCHENETTE AREA** **ADJ TO MICROWAVE** **FIRST DRAW**	**2.3**	1.0	
Client **CR-7** Micro 47833-07 **SINK FAUCET** **SINK FAUCET IN ART ROOM** **FIRST DRAW**	**5.9**	1.0	
Client **CR-8** Micro 47833-08 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN THE BUNGALOW (2ND GRADE)**	**< 1.0**	1.0	
Client **BLANK** Micro 47833-09 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SAN FRANCISCO COMMUNITY

Micro Log In **47410**
Total Samples 10
Date Sampled 8/15/97
Date Received 8/15/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47410-01 SINK FAUCET FIRST DRAW , 3RD FLOOR	5.4	1.0	
Client 2 Micro 47410-02 DRINKING FOUNTAIN C90 FIRST DRAW, 3RD FLOOR	8.9	1.0	
Client 3 Micro 47410-03 WATER FAUCET T62 FIRST DRAW, 3RD FLOOR	< 1.0	1.0	
Client 4 Micro 47410-04 SINK OF 002A FIRST DRAW	34.0	1.0	
Client 5 Micro 47410-05 SINK DRINKING FOUNTAIN 005A FIRST DRAW	1.9	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SAN FRANCISCO COMMUNITY

Micro Log In **47410**
Total Samples 10
Date Sampled 8/15/97
Date Received 8/15/97
Date Analyzed 8/15/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47410-06 **DRINKING FOUNTAIN** **C90** **FIRST DRAW, 2ND FLOOR**	**3.9**	1.0	
Client 7 Micro 47410-07 **WATER FOUNTAIN** **T61** **FIRST DRAW, WOMEN'S RR**	**1.4**	1.0	
Client 8 Micro 47410-08 **WATER FOUNTAIN** **T51** **FIRST DRAW, MEN'S RR**	**1.5**	1.0	
Client 9 Micro 47410-09 **SINK DRINKING FOUNTAIN** **004A** **FIRST DRAW**	**1.8**	1.0	
Client 10 Micro 47410-10 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/6/97 _____ Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SAN FRANCISCO COMMUNITY

Micro Log In **49249**
Total Samples 4
Date Sampled 9/30/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **4A** Micro 49249-01 **SINK DRINKING FOUNTAIN 002A 1ST**	< **1.0**	1.0	
Client **4B** Micro 49249-02 **SINK DRINKING FOUNTAIN 002A 2ND**	< **1.0**	1.0	
Client **4C** Micro 49249-03 **SINK DRINKING FOUNTAIN 002A 3RD**	< **1.0**	1.0	
Client **4D** Micro 49249-04 **BLANK**	< **1.0**	1.0	

Technical Supervisor: _____ 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: San Miguel CC

Lab Proj. ID: 9708D01

Sampled: 08/25/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D01-01 Sample Desc : **LIQUID,San Miguel 1 Duplicate**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-02 Sample Desc : **LIQUID,San Miguel 1**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-03 Sample Desc : **LIQUID,San Miguel 2**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-04 Sample Desc : **LIQUID,San Miguel 3**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-05 Sample Desc : **LIQUID,San Miguel 4**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-06 Sample Desc : **LIQUID,San Miguel 5**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-07 Sample Desc : **LIQUID,San Miguel 6**				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: San Miguel CC

Lab Proj. ID: 9708D01

Sampled: 08/25/97
Received: 08/25/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D01-08 Sample Desc : **LIQUID,San Miguel 7**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-09 Sample Desc : **LIQUID,San Miguel 8**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-10 Sample Desc : **LIQUID,San Miguel 9**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-11 Sample Desc : **LIQUID,San Miguel 10 Blank**				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D01-12 Sample Desc : **LIQUID,San Miguel 11**				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.043**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SANCHEZ ES

Micro Log In **47365**
Total Samples 9
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/14/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47365-01 **BLANK**	< 1.0	1.0	
Client 2 Micro 47365-02 **DRINKING FOUNTAIN** **SECOND FLOOR HALLWAY - NEXT TO RM. 20** **FIRST DRAW**	2.8	1.0	
Client 3 Micro 47365-03 **DRINKING FOUNTAIN** **FIRST FLOOR HALLWAY - NEXT TO RM. 12** **FIRST DRAW**	11.4	1.0	
Client 4 Micro 47365-04 **DRINKING FOUNTAIN** **FIRST FLOOR HALLWAY - NEXT TO RM. 6** **FIRST DRAW**	10.3	1.0	
Client 5 Micro 47365-05 **DRINKING FOUNTAIN** **FIRST FLOOR HALLWAY - NEXT TO RM. 24** **FIRST DRAW**	23.0	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SANCHEZ ES

Micro Log In **47365**
Total Samples 9
Date Sampled 8/14/97
Date Received 8/14/97
Date Analyzed 8/14/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47365-06 MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL OUTSIDE PLAYGROUND SOUTH / EAST SIDE FIRST DRAW	4.0	1.0	
Client 7 Micro 47365-07 MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL OUTSIDE PLAYGROUND SOUTH / WEST SIDE FIRST DRAW	10.4	1.0	
Client 8 Micro 47365-08 MULTIPLE DRINKING FOUNTAIN BASEMENT LEVEL OUTSIDE PLAYGROUND SOUTH / WEST SIDE FIRST DRAW	8.8	1.0	
Client 9 Micro 47365-09 DRINKING FOUNTAIN HALLWAY OUTSIDE BASKETBALL COURT FIRST DRAW	4.6	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SCHOOL OF THE ARTS

Micro Log In **48768**
Total Samples 24
Date Sampled 9/17/97
Date Received 9/23/97
Date Analyzed 9/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **694-1** Micro 48768-01 **SINK DRINKING FOUNTAIN INSIDE CLASSROOM 003, WEST FAUCET FIRST DRAW**	**34.0**	1.0	
Client **694-2** Micro 48768-02 **SINK DRINKING FOUNTAIN INSIDE CLASSROOM 003, EAST FAUCET FIRST DRAW**	**29.8**	1.0	
Client **694-3** Micro 48768-03 **DRINKING FOUNTAIN DRINKING FOUNTAIN IN CORRIDOR C90 ADJACENT TO ROOM 003 FIRST DRAW**	**55.1**	2.0	
Client **694-4** Micro 48768-04 **DRINKING FOUNTAIN DRINKING FOUNTAIN IN CORRIDOR C90 ADJACENT TO T60 FIRST DRAW**	**18.9**	1.0	
Client **694-5** Micro 48768-05 **DRINKING FOUNTAIN DRINKING FOUNTAIN IN CORRIDOR C90 ADJACENT TO T50 FIRST DRAW**	**18.5**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SCHOOL OF THE ARTS

Micro Log In **48768**
Total Samples 24
Date Sampled 9/17/97
Date Received 9/23/97
Date Analyzed 9/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **694-6** Micro 48768-06 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN IN CORRIDOR C90** **ADJACENT TO ROOM J03** **FIRST DRAW**	**10.4**	1.0	
Client **694-7** Micro 48768-07 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN IN CORRIDOR C93E** **ADJACENT TO ROOM 005** **FIRST DRAW**	**5.5**	1.0	
Client **694-8** Micro 48768-08 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 005** **FIRST DRAW**	**5.6**	1.0	
Client **694-9** Micro 48768-09 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 006** **FIRST DRAW**	**10.7**	1.0	
Client **694-10** Micro 48768-10 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 026** **FIRST DRAW**	**4.2**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SCHOOL OF THE ARTS

Micro Log In **48768**
Total Samples 24
Date Sampled 9/17/97
Date Received 9/23/97
Date Analyzed 9/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **694-11** Micro 48768-11 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 025** **FIRST DRAW**	**2.4**	1.0	
Client **694-12** Micro 48768-12 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 012** **FIRST DRAW**	**9.5**	1.0	
Client **694-13** Micro 48768-13 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 013** **FIRST DRAW**	**4.8**	1.0	
Client **694-14** Micro 48768-14 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 014** **FIRST DRAW**	**8.5**	1.0	
Client **694-15** Micro 48768-15 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 016** **FIRST DRAW**	**8.7**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SCHOOL OF THE ARTS

Micro Log In **48768**
Total Samples 24
Date Sampled 9/17/97
Date Received 9/23/97
Date Analyzed 9/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **694-16** Micro 48768-16 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 018** **FIRST DRAW**	**4.0**	1.0	
Client **694-17** Micro 48768-17 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 014** **FIRST DRAW**	**8.9**	1.0	
Client **694-18** Micro 48768-18 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 020** **FIRST DRAW**	**6.5**	1.0	
Client **694-19** Micro 48768-19 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 021** **FIRST DRAW**	**3.0**	1.0	
Client **694-20** Micro 48768-20 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 022** **FIRST DRAW**	**5.1**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SCHOOL OF THE ARTS

Micro Log In **48768**
Total Samples 24
Date Sampled 9/17/97
Date Received 9/23/97
Date Analyzed 9/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **694-21** Micro 48768-21 **SINK DRINKING FOUNTAIN** **SINK DRINKING FOUNTAIN IN ROOM 023** **FIRST DRAW**	**4.0**	1.0	
Client **694-22** Micro 48768-22 **DRINKING FOUNTAIN** **DRINKING FOUNTAIN IN CORRIDOR C92W** **WEST SIDE OF CORRIDOR** **FIRST DRAW**	**13.6**	1.0	
Client **694-23** Micro 48768-23 **SPIKE #97-W00774-19** **SPIKED**	**19.8**	1.0	
Client **694-24** Micro 48768-24 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SOTA
B-2243

Micro Log In **50764**
Total Samples 16
Date Sampled 11/18/97
Date Received 11/18/97
Date Analyzed 11/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **694-1A** Micro 50764-01 **DRINKING FOUNTAIN ROOM 003 WEST 1ST DRAW**	**18.7**	1.0	
Client **694-1B** Micro 50764-02 **DRINKING FOUNTAIN ROOM 003 WEST 2ND DRAW**	**17.1**	1.0	
Client **694-1C** Micro 50764-03 **DRINKING FOUNTAIN ROOM 003 WEST 3RD DRAW**	**26.6**	1.0	
Client **694-2A** Micro 50764-04 **DRINKING FOUNTAIN ROOM 003 EAST 1ST DRAW**	**7.2**	1.0	
Client **694-2B** Micro 50764-05 **DRINKING FOUNTAIN ROOM 003 EAST 2ND DRAW**	**5.6**	1.0	

Technical Supervisor: _____ 11/19/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SOTA

Micro Log In 50764
Total Samples 16
Date Sampled 11/18/97
Date Received 11/18/97
Date Analyzed 11/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 694-2C Micro 50764-06 DRINKING FOUNTAIN ROOM 003 EAST 3RD DRAW	24.1	1.0	
Client 694-3A Micro 50764-07 DRINKING FOUNTAIN ADJ. TO ROOM 003 1ST DRAW	122.1	4.0	
Client 694-3B Micro 50764-08 DRINKING FOUNTAIN ADJ. TO ROOM 003 2ND DRAW	80.6	2.9	
Client 694-3C Micro 50764-09 DRINKING FOUNTAIN ADJ. TO ROOM 003 3RD DRAW	36.1	1.0	
Client 694-4A Micro 50764-10 DRINKING FOUNTAIN ADJ. TO ROOM 160 1ST DRAW	10.5	1.0	

Technical Supervisor: F. Ramezanzadeh 11/19/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SOTA

Micro Log In **50764**
Total Samples 16
Date Sampled 11/18/97
Date Received 11/18/97
Date Analyzed 11/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **694-4B** Micro 50764-11 **DRINKING FOUNTAIN ADJ. TO ROOM 160 2ND DRAW**	**5.9**	1.0	
Client **694-4C** Micro 50764-12 **DRINKING FOUNTAIN ADJ. TO ROOM 160 3RD DRAW**	**11.7**	1.0	
Client **694-22A** Micro 50764-13 **DRINKING FOUNTAIN CORRIDOR C-92 WEST 1ST DRAW**	**2.1**	1.0	
Client **694-22B** Micro 50764-14 **DRINKING FOUNTAIN CORRIDOR C-92 WEST 2ND DRAW**	**1.8**	1.0	
Client **694-22C** Micro 50764-15 **DRINKING FOUNTAIN CORRIDOR C-92 WEST 3RD DRAW**	**5.0**	1.0	

Technical Supervisor: _____ 11/19/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SOTA

Micro Log In **50764**
Total Samples 16
Date Sampled 11/18/97
Date Received 11/18/97
Date Analyzed 11/19/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: **694-BLANK** Micro 50764-16 **BLANK**	< **1.0**	1.0	

Technical Supervisor: 11/19/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA
ANNEX CC

Micro Log In **47764**
Total Samples 16
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47764-01 SINK DRINKING FOUNTAIN 3025A	5.8	1.0	
Client 2 Micro 47764-02 DRINKING FOUNTAIN 3025A	12.9	1.0	
Client 3 Micro 47764-03 SINK DRINKING FOUNTAIN 3025B	6.5	1.0	
Client 4 Micro 47764-04 DRINKING FOUNTAIN 3025B	4.1	1.0	
Client 5 Micro 47764-05 DRINKING FOUNTAIN MAIN YARD	2.8	1.0	

Technical Supervisor: _____ 8/31/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA
ANNEX CC

Micro Log In **47764**
Total Samples 16
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47764-06 **WATER FAUCET** **3024**	< 1.0	1.0	
Client 7 Micro 47764-07 **WATER FAUCET** **3023**	< 1.0	1.0	
Client 8 Micro 47764-08 **SINK FAUCET** **3023**	< 1.0	1.0	
Client 9 Micro 47764-09 **WATER FAUCET** **3021**	< 1.0	1.0	
Client 10 Micro 47764-10 **BLANK**	< 1.0	1.0	

Technical Supervisor: 8/31/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA
ANNEX CC

Micro Log In **47764**
Total Samples 16
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47764-11 **WATER FAUCET** 3021	< 1.0	1.0	
Client 12 Micro 47764-12 **WATER FAUCET** 3021	< 1.0	1.0	
Client 13 Micro 47764-13 **MULTIPLE DRINKING FAUCET BACK YARD AREA**	< 1.0	1.0	
Client 14 Micro 47764-14 **DRINKING FAUCET** 3020	8.7	1.0	
Client 15 Micro 47764-15 **SINK DRINKING FOUNTAIN** 3020	< 1.0	1.0	

Technical Supervisor: 8/31/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA
ANNEX CC

Micro Log In 47764
Total Samples 16
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/30/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47764-16 WATER FAUCET 3023	2.5	1.0	

Technical Supervisor: 8/31/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SERRA ANNEX CC

Micro Log In **49250**
Total Samples 3
Date Sampled 9/29/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **2A** Micro 49250-01 **DRINKING FOUNTAIN 3025A 1ST**	**4.8**	1.0	
Client **2B** Micro 49250-01 **DRINKING FOUNTAIN 3025A 2ND**	**4.7**	1.0	
Client **2C** Micro 49250-01 **DRINKING FOUNTAIN 3025A 3RD**	**11.2**	1.0	

Technical Supervisor: F Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA ES

Micro Log In **47766**
Total Samples 22
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47766-01 **WATER FAUCET ADULT RESTROOM**	< **1.0**	1.0	
Client 2 Micro 47766-02 **SINK DRINKING FOUNTAIN ROOM 206**	**2.9**	1.0	
Client 3 Micro 47766-03 **SINK FAUCET ROOM 206**	**3.5**	1.0	
Client 4 Micro 47766-04 **SINK DRINKING FOUNTAIN ROOM 207**	**3.2**	1.0	
Client 5 Micro 47766-05 **SINK FAUCET ROOM 207**	**3.5**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA ES

Micro Log In **47766**
Total Samples 22
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47766-06 SINK DRINKING FOUNTAIN ROOM 208	2.9	1.0	
Client 7 Micro 47766-07 SINK FAUCET ROOM 208	2.7	1.0	
Client 8 Micro 47766-08 SINK DRINKING FOUNTAIN ROOM 209	2.4	1.0	
Client 9 Micro 47766-09 SINK FAUCET ROOM 209	3.0	1.0	
Client 10 Micro 47766-10 BLANK	< 1.0	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA ES

Micro Log In **47766**
Total Samples 22
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47766-11 SINK FAUCET SINK NEAR STOVE	1.4	1.0	
Client 12 Micro 47766-12 SINK FAUCET TEACHER RESTROOM	2.0	1.0	
Client 13 Micro 47766-13 SINK FAUCET 2ND ADULT RESTROOM	< 1.0	1.0	
Client 14 Micro 47766-14 SINK FAUCET TEACHERS' LUNCH ROOM	1.4	1.0	
Client 15 Micro 47766-15 SINK FAUCET BOYS' ROOM	2.3	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA ES

Micro Log In 47766
Total Samples 22
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47766-16 SINK DRINKING FOUNTAIN GIRLS' ROOM	1.6	1.0	
Client 17 Micro 47766-17 DRINKING FOUNTAIN HALL DRINKING FOUNTAIN	3.8	1.0	
Client 18 Micro 47766-18 SINK DRINKING FOUNTAIN ROOM 205	1.6	1.0	
Client 19 Micro 47766-19 SINK FAUCET ROOM 205	< 1.0	1.0	
Client 20 Micro 47766-20 BLANK SAMPLE	< 1.0	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA ES

Micro Log In **47766**
Total Samples 22
Date Sampled 8/21/97
Date Received 8/25/97
Date Analyzed 8/31/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **21** Micro 47766-21 **MULTIPLE DRINKING FOUNTAIN PLAY YARD AREA**	< **1.0**	1.0	
Client **97-W00753-2** Micro 47766-22 **SPIKED SAMPLE**	**21.2**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA (SA)

Micro Log In **47765**
Total Samples 21
Date Sampled 8/20/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47765-01 SINK DRINKING FOUNTAIN CAFE	< 1.0	1.0	
Client 2 Micro 47765-02 SINK FAUCET OFFICE	< 1.0	1.0	
Client 3 Micro 47765-03 SINK DRINKING FOUNTAIN GIRLS' ROOM	1.5	1.0	
Client 4 Micro 47765-04 WATER FAUCET GIRLS' ROOM	< 1.0	1.0	
Client 5 Micro 47765-05 SINK DRINKING FOUNTAIN BOYS' ROOM	2.0	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA (SA)

Micro Log In **47765**
Total Samples 21
Date Sampled 8/20/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47765-06 **WATER FAUCET BOYS' ROOM**	< **1.0**	1.0	
Client 7 Micro 47765-07 **DRINKING FOUNTAIN HALL OUTSIDE OF RESTROOM**	< **1.0**	1.0	
Client 8 Micro 47765-08 **WATER FAUCET ADULT RESTROOM**	< **1.0**	1.0	
Client 9 Micro 47765-09 **DRINKING FOUNTAIN CLASSROOM #5**	< **1.0**	1.0	
Client 10 Micro 47765-10 **BLANK**	< **1.0**	1.0	

Technical Supervisor: _____ 8/31/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA (SA)

Micro Log In **47765**
Total Samples 21
Date Sampled 8/20/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47765-11 SINK DRINKING FOUNTAIN CLASSROOM #5	2.0	1.0	
Client 12 Micro 47765-12 DRINKING FOUNTAIN CLASSROOM #4	< 1.0	1.0	
Client 13 Micro 47765-13 SINK DRINKING FOUNTAIN CLASSROOM #4	2.9	1.0	
Client 14 Micro 47765-14 DRINKING FOUNTAIN CLASSROOM #3	< 1.0	1.0	
Client 15 Micro 47765-15 SINK DRINK FOUNTAIN CLASSROOM #3	1.8	1.0	

Technical Supervisor: F Ramezanzadeh 8/31/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA (SA)

Micro Log In **47765**
Total Samples 21
Date Sampled 8/20/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **16** Micro 47765-16 **DRINKING FOUNTAIN CLASSROOM #2**	**1.0**	1.0	
Client **17** Micro 47765-17 **SINK DRINKING FOUNTAIN CLASSROOM #2**	**3.5**	1.0	
Client **18** Micro 47765-18 **DRINKING FOUNTAIN CLASSROOM #1**	**< 1.0**	1.0	
Client **19** Micro 47765-19 **SINK DRINKING FOUNTAIN CLASSROOM #1**	**1.4**	1.0	
Client **20** Micro 47765-20 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 8/31/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
S.F.U.S.D.
1551 Newcomb Ave. Room 206
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JUNIPERO SERRA (SA)

Micro Log In **47765**
Total Samples 21
Date Sampled 8/20/97
Date Received 8/26/97
Date Analyzed 8/26/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 97-W007 53-1 Micro 47765-21 SPIKED SAMPLE	20.6	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERIDAN ES

Micro Log In **47474**
Total Samples 26
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47474-01 SINK FAUCET LOUNGE 100F FIRST DRAW	< 1.0	1.0	
Client 2 Micro 47474-02 SINK FAUCET KITCHEN 102 B FIRST DRAW	7.0	1.0	
Client 3 Micro 47474-03 SINK DRINKING FOUNTAIN CLASSROOM 103 FIRST DRAW	3.7	1.0	
Client 4 Micro 47474-04 SINK DRINKING FOUNTAIN CLASSROOM 104 FIRST DRAW	2.4	1.0	
Client 5 Micro 47474-05 DRINKING FOUNTAIN CORRIDOR C101 FIRST DRAW	1.3	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERIDAN ES

Micro Log In **47474**
Total Samples 26
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47474-06 DRINKING FOUNTAIN CORRIDOR C201 FIRST DRAW	8.6	1.0	
Client 7 Micro 47474-07 SINK DRINKING FOUNTAIN CLASSROOM 205 FIRST DRAW	< 1.0	1.0	
Client 8 Micro 47474-08 SINK DRINKING FOUNTAIN CLASSROOM 204 FIRST DRAW	< 1.0	1.0	
Client 9 Micro 47474-09 SINK DRINKING FOUNTAIN LABORATORY 206A FIRST DRAW	4.2	1.0	
Client 10 Micro 47474-10 SINK DRINKING FOUNTAIN CLASSROOM 201 FIRST DRAW	3.9	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERIDAN ES

Micro Log In **47474**
Total Samples 26
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47474-11 SINK DRINKING FOUNTAIN LABORATORY 106A FIRST DRAW	< 1.0	1.0	
Client 12 Micro 47474-12 SINK DRINKING FOUNTAIN CLASSROOM 12 FIRST DRAW	31.0	1.0	
Client 13 Micro 47474-13 SINK DRINKING FOUNTAIN CLASSROOM 11 FIRST DRAW	45.1	1.0	
Client 14 Micro 47474-14 SINK DRINKING FOUNTAIN CLASSROOM 10 FIRST DRAW	18.8	1.0	
Client 15 Micro 47474-15 SINK DRINKING FOUNTAIN CLASSROOM 09 FIRST DRAW	12.7	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERIDAN ES

Micro Log In **47474**
Total Samples 26
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47474-16 SINK DRINKING FOUNTAIN CLASSROOM 08 FIRST DRAW	29.3	1.0	
Client 17 Micro 47474-17 SINK DRINKING FOUNTAIN CLASSROOM 07 FIRST DRAW	11.0	1.0	
Client 18 Micro 47474-18 SINK DRINKING FOUNTAIN CLASSROOM 06 FIRST DRAW	17.4	1.0	
Client 19 Micro 47474-19 SINK DRINKING FOUNTAIN CLASSROOM 05 FIRST DRAW	34.3	1.0	
Client 20 Micro 47474-20 SINK DRINKING FOUNTAIN CLASSROOM 04 FIRST DRAW	8.5	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERIDAN ES

Micro Log In **47474**
Total Samples 26
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **21** Micro 47474-21 **SINK DRINKING FOUNTAIN** **CLASSROOM 03** **FIRST DRAW**	**65.5**	2.5	
Client **22** Micro 47474-22 **SINK DRINKING FOUNTAIN** **CLASSROOM 02** **FIRST DRAW**	**16.2**	1.0	
Client **23** Micro 47474-23 **SINK DRINKING FOUNTAIN** **CLASSROOM 01** **FIRST DRAW**	**11.1**	1.0	
Client **24** Micro 47474-24 **MULTIPLE DRINKING FOUNTAIN** **PLAYGROUND** **FIRST DRAW**	**4.0**	1.0	
Client **25** Micro 47474-25 **MULTIPLE DRINKING FOUNTAIN** **PLAYGROUND** **FIRST DRAW**	**21.4**	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERIDAN ES

Micro Log In **47474**
Total Samples 26
Date Sampled 8/15/97
Date Received 8/18/97
Date Analyzed 8/21/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 26 Micro 47474-26 **BLANK**	< 1.0	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sheridan E.S.

Lab Proj. ID: 9712589

Sampled: 12/10/97
Received: 12/10/97
Analyzed: see below

Reported: 12/17/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9712589-01 Sample Desc : **LIQUID,Sheridan 3-1**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-02 Sample Desc : **LIQUID,Sheridan 3-2**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-03 Sample Desc : **LIQUID,Sheridan 3-3**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.014**
Lab No: 9712589-04 Sample Desc : **LIQUID,Sheridan 3-4**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.0061**
Lab No: 9712589-05 Sample Desc : **LIQUID,Sheridan 3-5**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-06 Sample Desc : **LIQUID,Sheridan 3-6**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-07 Sample Desc : **LIQUID,Sheridan 3-7**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.0061**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sheridan E.S.

Lab Proj. ID: 9712589

Sampled: 12/10/97
Received: 12/10/97
Analyzed: see below

Reported: 12/17/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
15B Lab No: 9712589-08 Sample Desc : **LIQUID,Sheridan 3-8**				
Lead	mg/L	12/16/97	0.0050	N.D.
16A Lab No: 9712589-09 Sample Desc : **LIQUID,Sheridan 3-9**				
Lead	mg/L	12/16/97	0.0050	N.D.
16A Lab No: 9712589-10 Sample Desc : **LIQUID,Sheridan 3-9 dup**				
Lead	mg/L	12/16/97	0.0050	N.D.
16B Lab No: 9712589-11 Sample Desc : **LIQUID,Sheridan 3-10**				
Lead	mg/L	12/16/97	0.0050	N.D.
18A Lab No: 9712589-12 Sample Desc : **LIQUID,Sheridan 3-11**				
Lead	mg/L	12/16/97	0.0050	N.D.
18B Lab No: 9712589-13 Sample Desc : **LIQUID,Sheridan 3-12**				
Lead	mg/L	12/16/97	0.0050	N.D.
19A Lab No: 9712589-14 Sample Desc : **LIQUID,Sheridan 3-13**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.0054**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sheridan E.S.

Lab Proj. ID: 9712589

Sampled: 12/10/97
Received: 12/10/97
Analyzed: see below

Reported: 12/17/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9712589-15				
Sample Desc : **LIQUID,Sheridan 3-14**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-16				
Sample Desc : **LIQUID,Sheridan 3-15**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-17				
Sample Desc : **LIQUID,Sheridan 3-16**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-18				
Sample Desc : **LIQUID,Sheridan 3-17**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-19				
Sample Desc : **LIQUID,Sheridan 3-18**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-20				
Sample Desc : **LIQUID,Sheridan 3-19**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.0079**
Lab No: 9712589-21				
Sample Desc : **LIQUID,Sheridan 3-20**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.018** 13C

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sheridan E.S.

Lab Proj. ID: 9712589

Sampled: 12/10/97
Received: 12/10/97
Analyzed: see below

Reported: 12/17/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9712589-22				
13C Sample Desc : **LIQUID,Sheridan 3-20 dup**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.018**
Lab No: 9712589-23				
14C Sample Desc : **LIQUID,Sheridan 3-21**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.0083**
Lab No: 9712589-24				
15C Sample Desc : **LIQUID,Sheridan 3-22**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.0056**
Lab No: 9712589-25				
16C Sample Desc : **LIQUID,Sheridan 3-23**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.0070**
Lab No: 9712589-26				
18C Sample Desc : **LIQUID,Sheridan 3-24**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.011**
Lab No: 9712589-27				
19C Sample Desc : **LIQUID,Sheridan 3-25**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.0072**
Lab No: 9712589-28				
21C Sample Desc : **LIQUID,Sheridan 3-26**				
Lead	mg/L	12/16/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sheridan E.S.

Lab Proj. ID: 9712589

Sampled: 12/10/97
Received: 12/10/97
Analyzed: see below

Reported: 12/17/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9712589-29 Sample Desc : **LIQUID,Sheridan 3-27**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-30 Sample Desc : **LIQUID,Sheridan 3-27 dup**				
Lead	mg/L	12/16/97	0.0050	N.D.
Lab No: 9712589-31 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	12/16/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERMAN ES

Micro Log In **47727**
Total Samples 15
Date Sampled 8/20/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 47727-01 SINK FAUCET 1ST FLOOR TEACHER LOUNGE FIRST DRAW	6.3	1.0	
Client # 2 Micro 47727-02 SINK FAUCET 1ST FLOOR KITCHEN SINK FIRST DRAW	1.1	1.0	
Client # 3 Micro 47727-03 DRINKING FOUNTAIN 1ST FLOOR AUDITORIUM LOBBY FIRST DRAW	1.8	1.0	
Client # 4 Micro 47727-04 SINK DRINKING FOUNTAIN 1ST FLOOR LIBRARY FIRST DRAW	< 1.0	1.0	
Client # 5 Micro 47727-05 SINK FAUCET 1ST FLOOR LIBRARY STORAGE FIRST DRAW	11.2	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERMAN ES

Micro Log In **47727**
Total Samples 15
Date Sampled 8/20/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 6 Micro 47727-06 MULTIPLE DRINKING FOUNTAIN OUTSIDE PLAYGROUND BY LIBRARY FIRST DRAW	3.7	1.0	
Client # 7 Micro 47727-07 MULTIPLE DRINKING FOUNTAIN OUTSIDE UPPER PLAYGROUND LEVEL FIRST DRAW	3.4	1.0	
Client # 8 Micro 47727-08 MULTIPLE DRINKING FOUNTAIN OUTSIDE PLAYGROUND, SOUTH FIRST DRAW	3.0	1.0	
Client # 9 Micro 47727-09 DRINKING FOUNTAIN 2ND FLOOR CORRIDOR - NORTH FIRST DRAW	7.5	1.0	
Client #21 Micro 47727-10 DRINKING FOUNTAIN 3RD FLOOR CORRIDOR - NORTH FIRST DRAW	9.7	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERMAN ES

Micro Log In **47727**
Total Samples 15
Date Sampled 8/20/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #23 Micro 47727-11 DRINKING FOUNTAIN 3RD FLOOR CORRIDOR, SOUTH FIRST DRAW	1.5	1.0	
Client #24 Micro 47727-12 MULTIPLE DRINKING FOUNTAIN OUTSIDE S. W. PLAYGROUND FIRST DRAW	23.5	1.0	
Client #25 Micro 47727-13 DRINKING FOUNTAIN OUTSIDE S. W. PLAYGROUND FIRST DRAW	7.5	1.0	
Client #26 Micro 47727-14 1ST FLOOR KITCHEN SINK BLANK	< 1.0	1.0	
Client #27 Micro 47727-15 SPIKED	55.0	2.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SHERMAN ES

Micro Log In **49294**
Total Samples 5
Date Sampled 9/30/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **24A** Micro 49294-01 **MULTIPLE DRINKING FOUNTAIN OUTSIDE S.W PLAYGROUND FIRST DRAW**	**1.3**	1.0	
Client **24B** Micro 49294-02 **MULTIPLE DRINKING FOUNTAIN OUTSIDE S.W PLAYGROUND FIRST DRAW**	**1.7**	1.0	
Client **24C** Micro 49294-03 **MULTIPLE DRINKING FOUNTAIN OUTSIDE S.W PLAYGROUND FIRST DRAW**	**4.3**	1.0	
Client **BLANK** Micro 49294-04 **BLANK**	**< 1.0**	1.0	
Client **SHERMAN S** Micro 49294-05 **SPIKE**	**95.5**	3.3	

Technical Supervisor: 10/12/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1937. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9708755

Sampled: 08/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708755-01 Sample Desc : LIQUID,1				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.37**
Lab No: 9708755-02 Sample Desc : LIQUID,2				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708755-03 Sample Desc : LIQUID,3				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708755-04 Sample Desc : LIQUID,4				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0091**
Lab No: 9708755-05 Sample Desc : LIQUID,5				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.013**
Lab No: 9708755-06 Sample Desc : LIQUID,6				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0068**
Lab No: 9708755-07 Sample Desc : LIQUID,7				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.018**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9708755

Sampled: 08/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708755-08 Sample Desc : **LIQUID,8**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0072**
Lab No: 9708755-09 Sample Desc : **LIQUID,9**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708755-10 Sample Desc : **LIQUID,10**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0063**
Lab No: 9708755-11 Sample Desc : **LIQUID,11**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.032**
Lab No: 9708755-12 Sample Desc : **LIQUID,12**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708755-13 Sample Desc : **LIQUID,13**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0051**
Lab No: 9708755-14 Sample Desc : **LIQUID,14**				
Lead	mg/L	08/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9708755

Sampled: 08/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708755-15 Sample Desc : LIQUID,15				
Lead	**mg/L**	**08/21/97**	**0.0050**	**0.019**
Lab No: 9708755-16 Sample Desc : LIQUID,16				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0068**
Lab No: 9708755-17 Sample Desc : LIQUID,17				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708755-18 Sample Desc : LIQUID,18				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.019**
Lab No: 9708755-19 Sample Desc : LIQUID,19				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.013**
Lab No: 9708755-20 Sample Desc : LIQUID,20				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.086**
Lab No: 9708755-21 Sample Desc : LIQUID,21				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0099**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9708755

Sampled: 08/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708755-22 Sample Desc : **LIQUID,22**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.011**
Lab No: 9708755-23 Sample Desc : **LIQUID,23**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.017**
Lab No: 9708755-24 Sample Desc : **LIQUID,24**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0061**
Lab No: 9708755-25 Sample Desc : **LIQUID,25**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708755-26 Sample Desc : **LIQUID,26**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708755-27 Sample Desc : **LIQUID,27**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.0062**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9708755

Sampled:
Received: 08/14/97
Analyzed: see below

Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708755-28 Sample Desc : LIQUID,28 (Blank)				
Lead	mg/L	08/21/97	0.0050	N.D.

B

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9708755

Sampled: 08/14/97
Received: 08/14/97
Analyzed: see below

Reported: 08/21/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708755-29 Sample Desc : **LIQUID,9 (Dup)**				
Lead	mg/L	08/19/97	0.0050	N.D.
Lab No: 9708755-30 Sample Desc : **LIQUID,15 (Dup)**				
Lead	**mg/L**	**08/21/97**	**0.0050**	**0.019**
Lab No: 9708755-31 Sample Desc : **LIQUID,22 (Dup)**				
Lead	**mg/L**	**08/19/97**	**0.0050**	**0.010**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat ES

Lab Proj. ID: 9708F10

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below

Reported: 09/03/97

LABORATORY ANALYSIS

Analyte		Units	Date Analyzed	Detection Limit	Sample Results	
Lab No: 9708F10-01 Sample Desc : **LIQUID,Sloat ES 2-1**						
1A	Lead	mg/L	09/02/97	0.0050	N.D.	R1
Lab No: 9708F10-02 Sample Desc : **LIQUID,Sloat ES 2-2**						
1B	Lead	mg/L	09/02/97	0.0050	N.D.	R2
Lab No: 9708F10-03 Sample Desc : **LIQUID,Sloat ES 2-3**						
7A	Lead	mg/L	09/02/97	0.0050	N.D.	R1
Lab No: 9708F10-04 Sample Desc : **LIQUID,Sloat ES 2-4**						
7B	Lead	mg/L	09/02/97	0.0050	N.D.	R2
Lab No: 9708F10-05 Sample Desc : **LIQUID,Sloat ES 2-5**						
11A	**Lead**	**mg/L**	**09/02/97**	**0.0050**	**0.0094**	R1
Lab No: 9708F10-06 Sample Desc : **LIQUID,Sloat ES 2-6**						
11B	Lead	mg/L	09/02/97	0.0050	N.D.	R2
Lab No: 9708F10-07 Sample Desc : **LIQUID,Sloat ES 2-7**						
15A	Lead	mg/L	09/02/97	0.0050	N.D.	R1

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat ES

Lab Proj. ID: 9708F10

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below

Reported: 09/03/97

LABORATORY ANALYSIS

	Analyte	Units	Date Analyzed	Detection Limit	Sample Results
	Lab No: 9708F10-08 Sample Desc : **LIQUID,Sloat ES 2-8**				
15B	Lead	mg/L	09/02/97	0.0050	N.D. R2
	Lab No: 9708F10-09 Sample Desc : **LIQUID,Sloat ES 2-9**				
18A	Lead	mg/L	09/02/97	0.0050	N.D. R1
	Lab No: 9708F10-10 Sample Desc : **LIQUID,Sloat ES 2-9 Duplicate**				
18A	Lead	mg/L	09/02/97	0.0050	N.D. D
	Lab No: 9708F10-11 Sample Desc : **LIQUID,Sloat ES 2-10**				
18B	Lead	mg/L	09/02/97	0.0050	N.D. R2
	Lab No: 9708F10-12 Sample Desc : **LIQUID,Sloat ES 2-11**				
20A	Lead	mg/L	09/02/97	0.0050	N.D. R1
	Lab No: 9708F10-13 Sample Desc : **LIQUID,Sloat ES 2-12**				
20B	Lead	mg/L	09/02/97	0.0050	N.D. R2
	Lab No: 9708F10-14 Sample Desc : **LIQUID,Sloat ES 2-13**				
23A	Lead	mg/L	09/02/97	0.0050	N.D. R1

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat ES

Lab Proj. ID: 9708F10

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below

Reported: 09/03/97

LABORATORY ANALYSIS

Analyte		Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708F10-15					
Sample Desc : **LIQUID,Sloat ES 2-14**					
23B	Lead	mg/L	09/02/97	0.0050 R2	N.D.
Lab No: 9708F10-16					
Sample Desc : **LIQUID,Sloat ES 2-14 Duplicate**					
23B	Lead	mg/L	09/02/97	0.0050	N.D. D
Lab No: 9708F10-17					
Sample Desc : **LIQUID,Blank**					
BL	Lead	mg/L	09/02/97	0.0050	N.D. B

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat Elem

Lab Proj. ID: 9709823

Sampled: 09/16/97
Received: 09/16/97
Analyzed: see below

Reported: 09/19/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709823-01 Sample Desc : **LIQUID,Sloat 3-1**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709823-02 Sample Desc : **LIQUID,Sloat 3-2**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709823-03 Sample Desc : **LIQUID,Sloat 3-3**				
Lead	**mg/L**	**09/19/97**	**0.0050**	**0.0079**
Lab No: 9709823-04 Sample Desc : **LIQUID,Sloat 3-4**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709823-05 Sample Desc : **LIQUID,Sloat 3-5**				
Lead	**mg/L**	**09/19/97**	**0.0050**	**0.0071**
Lab No: 9709823-06 Sample Desc : **LIQUID,Sloat 3-6**				
Lead	**mg/L**	**09/19/97**	**0.0050**	**0.019**
Lab No: 9709823-07 Sample Desc : **LIQUID,Sloat 3-7**				
Lead	mg/L	09/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat Elem

Lab Proj. ID: 9709823

Sampled: 09/16/97
Received: 09/16/97
Analyzed: see below

Reported: 09/19/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709823-08 Sample Desc : **LIQUID,Sloat 3-7 dup**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709823-09 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	09/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9710E55

Sampled: 10/23/97
Received: 10/24/97
Analyzed: see below

Reported: 10/30/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710E55-01 Sample Desc : **LIQUID,1-A**				
Lead	mg/L	10/28/97	0.0050	N.D.
Lab No: 9710E55-02 Sample Desc : **LIQUID,1-B**				
Lead	mg/L	10/28/97	0.0050	N.D.
Lab No: 9710E55-03 Sample Desc : **LIQUID,7-A**				
Lead	mg/L	10/28/97	0.0050	N.D.
Lab No: 9710E55-04 Sample Desc : **LIQUID,7-B**				
Lead	mg/L	10/28/97	0.0050	N.D.
Lab No: 9710E55-05 Sample Desc : **LIQUID,11-A**				
Lead	**mg/L**	**10/28/97**	**0.0050**	**0.0088**
Lab No: 9710E55-06 Sample Desc : **LIQUID,11-B**				
Lead	mg/L	10/28/97	0.0050	N.D.
Lab No: 9710E55-07 Sample Desc : **LIQUID,15-A**				
Lead	mg/L	10/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9710E55

Sampled: 10/23/97
Received: 10/24/97
Analyzed: see below

Reported: 10/30/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710E55-08 Sample Desc : **LIQUID,15-B**				
Lead	mg/L	10/28/97	0.0050	N.D.
Lab No: 9710E55-09 Sample Desc : **LIQUID,18-A**				
Lead	mg/L	10/28/97	0.0050	N.D.
Lab No: 9710E55-10 Sample Desc : **LIQUID,18-A Duplicate**				
Lead	mg/L	10/28/97	0.0050	N.D.
Lab No: 9710E55-11 Sample Desc : **LIQUID,18-B**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E55-12 Sample Desc : **LIQUID,20-A**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E55-13 Sample Desc : **LIQUID,20-B**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E55-14 Sample Desc : **LIQUID,23-A**				
Lead	mg/L	10/29/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9710E55

Sampled: 10/23/97
Received: 10/24/97
Analyzed: see below

Reported: 10/30/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710E55-15 Sample Desc : **LIQUID,23-B**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E55-16 Sample Desc : **LIQUID,1-C**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E55-17 Sample Desc : **LIQUID,7-C**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.0055**
Lab No: 9710E55-18 Sample Desc : **LIQUID,11-C**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.020**
Lab No: 9710E55-19 Sample Desc : **LIQUID,15-C**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.0070**
Lab No: 9710E55-20 Sample Desc : **LIQUID,15-C Duplicate**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.0077**
Lab No: 9710E55-21 Sample Desc : **LIQUID,18-C**				
Lead	mg/L	10/29/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sloat E.S.

Lab Proj. ID: 9710E55

Sampled: 10/23/97
Received: 10/24/97
Analyzed: see below

Reported: 10/30/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710E55-22 Sample Desc : **LIQUID,20-C**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.018**
Lab No: 9710E55-23 Sample Desc : **LIQUID,23-C**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.0051**
Lab No: 9710E55-24 Sample Desc : **LIQUID,23-C Duplicate**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E55-25 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	10/29/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SLOAT ES

Micro Log In **52168**
Total Samples 7
Date Sampled 1/18/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SLOAT 5A** Micro 52168-01 **SINK DF A**	< **1.0**	1.0	
Client **SLOAT 5B** Micro 52168-02 **SINK DF A**	**2.7**	1.0	
Client **SLOAT 5C** Micro 52168-03 **SINK DF A**	**5.5**	1.0	
Client **SLOAT 19A** Micro 52168-04 **SINK DF CA**	**2.6**	1.0	
Client **SLOAT 19B** Micro 52168-05 **SINK DF CA**	**3.0**	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SLOAT ES

Micro Log In **52168**
Total Samples 7
Date Sampled 1/18/98
Date Received 1/20/98
Date Analyzed 1/20/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SLOAT 19C** Micro 52168-06 **SINK DF CA**	**4.4**	1.0	
Client **SLOAT BLANK** Micro 52168-07 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 1/22/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SPRING VALLEY ES

Micro Log In **47526**
Total Samples 23
Date Sampled 8/19/97
Date Received 8/19/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SPRING VALLEY 1** Micro 47526-01 **WATER-COOLED DRINKING FOUNTAIN C91 / FIRST DRAW**	**9.7**	1.0	
Client **SPRING VALLEY 2** Micro 47526-02 **SINK DRINKING FOUNTAIN 018A / FIRST DRAW**	**36.5**	1.0	
Client **SPRING VALLEY 3** Micro 47526-03 **WATER-COOLED DRINKING FOUNTAIN C91 / FIRST DRAW**	**11.6**	1.0	
Client **SPRING VALLEY 4** Micro 47526-04 **SINK DRINKING FOUNTAIN 019 / FIRST DRAW**	**20.3**	1.0	
Client **SPRING VALLEY 5** Micro 47526-05 **SINK DRINKING FOUNTAIN 020 / FIRST DRAW**	**60.9**	2.2	

Technical Supervisor: F Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SPRING VALLEY ES

Micro Log In **47526**
Total Samples 23
Date Sampled 8/19/97
Date Received 8/19/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SPRING VALLEY 6** Micro 47526-06 **SINK DRINKING FOUNTAIN** **011A / FIRST DRAW**	**3.8**	1.0	
Client **SPRING VALLEY 7** Micro 47526-07 **SINK DRINKING FOUNTAIN** **013A / FIRST DRAW**	**14.5**	1.0	
Client **SPRING VALLEY 8** Micro 47526-08 **SINK DRINKING FOUNTAIN** **014A / FIRST DRAW**	**7.3**	1.0	
Client **SPRING VALLEY 9** Micro 47526-09 **WATER-COOLED DRINKING FOUNTAIN** **C90 / FIRST DRAW**	**39.0**	1.0	
Client **SPRING VALLEY 10** Micro 47526-10 **SINK DRINKING FOUNTAIN** **021A / FIRST DRAW**	**4.5**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SPRING VALLEY ES

Micro Log In **47526**
Total Samples 23
Date Sampled 8/19/97
Date Received 8/19/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SPRING VALLEY 11** Micro 47526-11 **SINK DRINKING FOUNTAIN** **023A / FIRST DRAW**	**3.7**	1.0	
Client **SPRING VALLEY 12** Micro 47526-12 **SINK DRINKING FOUNTAIN** **024A / FIRST DRAW**	**58.1**	2.2	
Client **SPRING VALLEY 13** Micro 47526-13 **DRINKING FOUNTAIN** **C90 / FIRST DRAW**	**4.7**	1.0	
Client **SPRING VALLEY 14** Micro 47526-14 **SINK DRINKING FOUNTAIN** **005A / FIRST DRAW**	**2.9**	1.0	
Client **SPRING VALLEY 15** Micro 47526-15 **WATER-COOLED DRINKING FOUNTAIN** **C91 / FIRST DRAW**	**65.0**	2.5	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SPRING VALLEY ES

Micro Log In **47526**
Total Samples 23
Date Sampled 8/19/97
Date Received 8/19/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SPRING VALLEY 16** Micro 47526-16 **WATER-COOLED DRINKING FOUNTAIN C91 / FIRST DRAW**	**36.3**	1.0	
Client **SPRING VALLEY 17** Micro 47526-17 **SINK DRINKING FOUNTAIN 006A / FIRST DRAW**	**2.6**	1.0	
Client **SPRING VALLEY 18** Micro 47526-18 **SINK DRINKING FOUNTAIN 001A / FIRST DRAW**	**< 1.0**	1.0	
Client **SPRING VALLEY 19** Micro 47526-19 **SINK DRINKING FOUNTAIN 004 / FIRST DRAW**	**7.5**	1.0	
Client **SPRING VALLEY 20** Micro 47526-20 **SINK DRINKING FOUNTAIN 003 / FIRST DRAW**	**13.2**	1.0	

Technical Supervisor: F Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SPRING VALLEY ES

Micro Log In **47526**
Total Samples 23
Date Sampled 8/19/97
Date Received 8/19/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SPRING VALLEY 21** Micro 47526-21 **SINK FAUCET** **C91 / FIRST DRAW**	**6.1**	1.0	
Client **SPRING VALLEY 22** Micro 47526-22 **WATER-COOLED DRINKING FOUNTAIN** **C93 / FIRST DRAW**	**27.8**	1.0	
Client **SPRING VALLEY 23** Micro 47526-23 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1651 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Spring Valley ES
Lab Proj. ID: 9710485

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below
Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710485-01 Sample Desc : **LIQUID,SV 2-A**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0070**
Lab No: 9710485-02 Sample Desc : **LIQUID,SV 2-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-03 Sample Desc : **LIQUID,SV 2-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.043**
Lab No: 9710485-04 Sample Desc : **LIQUID,SV 4-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-05 Sample Desc : **LIQUID,SV 4-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-06 Sample Desc : **LIQUID,SV 4-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0070**
Lab No: 9710485-07 Sample Desc : **LIQUID,SV 5-A**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Spring Valley ES
Lab Proj. ID: 9710485

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below
Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710485-08 Sample Desc : **LIQUID,SV 5-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-09 Sample Desc : **LIQUID,SV 5-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.014**
Lab No: 9710485-10 Sample Desc : **LIQUID,SV 5-C (duplicate)**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.013**
Lab No: 9710485-11 Sample Desc : **LIQUID,SV 7-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-12 Sample Desc : **LIQUID,SV 7-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-13 Sample Desc : **LIQUID,SV 7-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-14 Sample Desc : **LIQUID,SV 9-A**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Spring Valley ES

Lab Proj. ID: 9710485

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710485-15 Sample Desc : **LIQUID,SV 9-B**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0060**
Lab No: 9710485-16 Sample Desc : **LIQUID,SV 9-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.014**
Lab No: 9710485-17 Sample Desc : **LIQUID,SV 12-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-18 Sample Desc : **LIQUID,SV 12-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-19 Sample Desc : **LIQUID,SV 12-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-20 Sample Desc : **LIQUID,SV 12-C (duplicate)**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-21 Sample Desc : **LIQUID,SV 15-A**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.012**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Spring Valley ES
Lab Proj. ID: 9710485

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below
Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710485-22 Sample Desc : **LIQUID,SV 15-B**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0090**
Lab No: 9710485-23 Sample Desc : **LIQUID,SV 15-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.026**
Lab No: 9710485-24 Sample Desc : **LIQUID,SV 15-D**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.013**
Lab No: 9710485-25 Sample Desc : **LIQUID,SV 16-A**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.011**
Lab No: 9710485-26 Sample Desc : **LIQUID,SV 16-B**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.013**
Lab No: 9710485-27 Sample Desc : **LIQUID,SV 16-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.077**
Lab No: 9710485-28 Sample Desc : **LIQUID,SV 20-A**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Spring Valley ES

Lab Proj. ID: 9710485

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710485-29 Sample Desc : **LIQUID,SV 20-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-30 Sample Desc : **LIQUID,SV 20-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-31 Sample Desc : **LIQUID,SV 20-C (duplicate)**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710485-32 Sample Desc : **LIQUID,SV Blank**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Shella Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SPRING VALLEY ES

Micro Log In 52538
Total Samples 3
Date Sampled 1/31/98
Date Received 2/2/98
Date Analyzed 2/2/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: SPRING VALLEY 3A Micro 52538-01 DRINKING FOUNTAIN 2 HALL - RESAMPLE	7.5	1.0	
Client: SPRING VALLEY 3B Micro 52538-02 DRINKING FOUNTAIN 2 HALL - RESAMPLE	2.7	1.0	
Client: SPRING VALLEY 3C Micro 52538-03 DRINKING FOUNTAIN 2 HALL - RESAMPLE	7.9	1.0	

Technical Supervisor: _____ 2/4/98 Analyst: FR
Farid Rameganzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ST. ELIZABETH PREG.

Micro Log In **47850**
Total Samples 2
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47850-01 SINK FAUCET FACILITY ROOM FIRST DRAW	1.9	1.0	
Client 2 Micro 47850-02 BLANK	< 1.0	1.0	

Technical Supervisor: 9/1/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
STEVENSON ES

Micro Log In **47726**
Total Samples 18
Date Sampled 8/20/97
Date Received 8/24/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 3 Micro 47726-01 DRINKING FOUNTAIN HALLWAY FIRST DRAW	2.2	1.0	
Client # 7 Micro 47726-02 DRINKING FOUNTAIN HALL FIRST DRAW	< 1.0	1.0	
Client # 8 Micro 47726-03 DRINKING FOUNTAIN HALL FIRST DRAW	1.6	1.0	
Client # 9 Micro 47726-04 DRINKING FOUNTAIN ROOM 11 FIRST DRAW	3.9	1.0	
Client # 11 Micro 47726-05 DRINKING FOUNTAIN ROOM 12 FIRST DRAW	8.0	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
STEVENSON ES

Micro Log In **47726**
Total Samples 18
Date Sampled 8/20/97
Date Received 8/24/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #14 Micro 47726-06 DRINKING FOUNTAIN ROOM 13 FIRST DRAW	2.0	1.0	
Client #16 Micro 47726-07 DRINKING FOUNTAIN ROOM 14 FIRST DRAW	2.4	1.0	
Client #19 Micro 47726-08 DRINKING FOUNTAIN HALL FIRST DRAW	1.2	1.0	
Client #20 Micro 47726-09 DRINKING FOUNTAIN HALL FIRST DRAW	1.6	1.0	
Client #22 Micro 47726-10 DRINKING FOUNTAIN OUTSIDE FIRST DRAW	2.5	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
STEVENSON ES

Micro Log In 47726
Total Samples 18
Date Sampled 8/20/97
Date Received 8/24/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client #23 Micro 47726-11 SINK FAUCET KITCHEN (NE) FIRST DRAW	3.5	1.0	
Client #24 Micro 47726-12 SINK FAUCET KITCHEN (SE) FIRST DRAW	< 1.0	1.0	
Client #25 Micro 47726-13 SINK FAUCET KITCHEN (NW) FIRST DRAW	28.5	1.0	
Client #26 Micro 47726-14 SINK FAUCET KITCHEN (SW) FIRST DRAW	< 1.0	1.0	
Client #27 Micro 47726-15 DRINKING FOUNTAIN ROOM 25 FIRST DRAW	1.5	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
STEVENSON ES

Micro Log In **47726**
Total Samples **18**
Date Sampled **8/20/97**
Date Received **8/24/97**
Date Analyzed **8/24/97**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **#33** Micro 47726-16 **DRINKING FOUNTAIN OUTSIDE COURTYARD FIRST DRAW**	**2.7**	1.0	
Client **#34** Micro 47726-17 **DRINKING FOUNTAIN OUTSIDE COURTYARD BLANK**	**< 1.0**	1.0	
Client **#35** Micro 47726-18 **SPIKED**	**49.9**	1.0	

Technical Supervisor: F Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
STEVENSON ES

Micro Log In **49295**
Total Samples 4
Date Sampled 10/2/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **25A** Micro 49295-01 **SINK FAUCET KITCHEN N.W FIRST DRAW**	**1.8**	1.0	
Client **25B** Micro 49295-02 **SINK FAUCET KITCHEN N.W FIRST DRAW**	**2.1**	1.0	
Client **25C** Micro 49295-03 **SINK FAUCET KITCHEN N.W FIRST DRAW**	**2.9**	1.0	
Client **BLANK** Micro 49295-04 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F Ramezanzadeh 10/12/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Stockton

Lab Proj. ID: 9708D04

Sampled: 08/23/97
Received: 08/25/97
Analyzed: see below

Reported: 08/28/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D04-01 Sample Desc : LIQUID,Stockton 1				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D04-02 Sample Desc : LIQUID,Stockton 1 Duplicate				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D04-03 Sample Desc : LIQUID,Stockton 2				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.0077**
Lab No: 9708D04-04 Sample Desc : LIQUID,Stockton 3				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D04-05 Sample Desc : LIQUID,Stockton Blank				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNNYSIDE ES

Micro Log In 47785
Total Samples 13
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client SUNNYSIDE #1 Micro 47785-01 SINK FAUCET 008B FIRST DRAW	14.7	1.0	
Client SUNNYSIDE #2 Micro 47785-02 SINK FAUCET 004B FIRST DRAW	2.4	1.0	
Client SUNNYSIDE #3 Micro 47785-03 SINK FAUCET 003B FIRST DRAW	4.8	1.0	
Client SUNNYSIDE #4 Micro 47785-04 SINK FAUCET 021B FIRST DRAW	16.1	1.0	
Client SUNNYSIDE #5 Micro 47785-05 SINK FAUCET 018B FIRST DRAW	4.9	1.0	

Technical Supervisor: 8/29/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNNYSIDE ES

Micro Log In **47785**
Total Samples 13
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SUNNYSIDE #6** Micro 47785-06 **SINK FAUCET** **016B** **FIRST DRAW**	**9.8**	1.0	
Client **SUNNYSIDE #7** Micro 47785-07 **SINK FAUCET** **015A** **FIRST DRAW**	**14.6**	1.0	
Client **SUNNYSIDE #8** Micro 47785-08 **SINK FAUCET** **014B** **FIRST DRAW**	**1.7**	1.0	
Client **SUNNYSIDE #9** Micro 47785-09 **SINK FAUCET** **013B** **FIRST DRAW**	**1.1**	1.0	
Client **SUNNYSIDE #10** Micro 47785-10 **SINK FAUCET** **TEACHERS LOUNGE** **FIRST DRAW**	**1.4**	1.0	

Technical Supervisor: F Ramezanzadeh 8/29/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNNYSIDE ES

Micro Log In **47785**
Total Samples 13
Date Sampled 8/23/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SUNNYSIDE #11** Micro 47785-11 **MULTIPLE DRINKING FOUNTAIN EXT. YARD FIRST DRAW**	**11.9**	1.0	
Client **SUNNYSIDE #12** Micro 47785-12 **MULTIPLE DRINKING FOUNTAIN EXT. YARD FIRST DRAW**	**5.8**	1.0	
Client **SUNNYSIDE #13** Micro 47785-13 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 8/29/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sunnyside ES

Lab Proj. ID: 9710492

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710492-01 Sample Desc : **LIQUID,Sunnyside 1-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710492-02 Sample Desc : **LIQUID,Sunnyside 1-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710492-03 Sample Desc : **LIQUID,Sunnyside 1-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.010**
Lab No: 9710492-04 Sample Desc : **LIQUID,Sunnyside 4-A**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0060**
Lab No: 9710492-05 Sample Desc : **LIQUID,Sunnyside 4-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710492-06 Sample Desc : **LIQUID,Sunnyside 4-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0080**
Lab No: 9710492-07 Sample Desc : **LIQUID,Sunnyside 7-A**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Sunnyside ES

Lab Proj. ID: 9710492

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710492-08 Sample Desc : **LIQUID,Sunnyside 7-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710492-09 Sample Desc : **LIQUID,Sunnyside 7-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710492-10 Sample Desc : **LIQUID,Sunnyside 7-C (duplicate)**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710492-11 Sample Desc : **LIQUID,Sunnyside Blank**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNNYSIDE ES

Micro Log In **50762**
Total Samples 2
Date Sampled 11/18/97
Date Received 11/18/97
Date Analyzed 11/18/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 50762-01 DRINKING FOUNTAIN SOUTH HALLWAY 1ST FLOOR WEST WALL	7.8	1.0	
Client # 2 Micro 50762-02 DRINKING FOUNTAIN SOUTH HALLWAY 2ND FLOOR WEST WALL	12.4	1.0	

Technical Supervisor: F Ramezanzadeh 11/18/97 Analyst: SL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNNYSIDE ES

Micro Log In 52535
Total Samples 6
Date Sampled 1/31/98
Date Received 2/2/98
Date Analyzed 2/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client SUNNYSIDE 2A Micro 52535-01 DRINKING FOUNTAIN 2 HALL RESAMPLE	2.8	1.0	
Client SUNNYSIDE 2B Micro 52535-02 DRINKING FOUNTAIN 2 HALL RESAMPLE	< 1.0	1.0	
Client SUNNYSIDE 2C Micro 52535-03 DRINKING FOUNTAIN RESAMPLE	2.1	1.0	
Client SUNNYSIDE 11A Micro 52535-04 MULTIPLE DRINKING FOUNTAIN EXT. SE RESAMPLE	4.9	1.0	
Client SUNNYSIDE 11B Micro 52535-05 MULTIPLE DRINKING FOUNTAIN RESAMPLE	4.6	1.0	

Technical Supervisor: 2/4/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNNYSIDE ES

Micro Log In 52535
Total Samples 6
Date Sampled 1/31/98
Date Received 2/2/98
Date Analyzed 2/3/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client SUNNYSIDE 11C Micro 52535-06 MULTIPLE DRINKING FOUNTAIN RESAMPLE	7.6	1.0	

Technical Supervisor: F. Ramezanzadeh 2/4/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1657. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNSET ES

Micro Log In **47578**
Total Samples 12
Date Sampled 8/20/97
Date Received 8/20/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47578-01 **SINK FAUCET** **SMALL KITCHEN AREA - 010C** **FIRST DRAW**	**3.6**	1.0	
Client 2 Micro 47578-02 **DRINKING FOUNTAIN** **CORRIDOR C-92 / FIRST FLOOR** **FIRST DRAW**	**2.7**	1.0	
Client 3 Micro 47578-03 **SINK FAUCET** **KITCHEN AREA - 015A** **FIRST DRAW**	**7.2**	1.0	
Client 4 Micro 47578-04 **DRINKING FOUNTAIN** **CLASSROOM 014** **FIRST DRAW**	**19.6**	1.0	
Client 5 Micro 47578-05 **DRINKING FOUNTAIN** **CLASSROOM 012** **FIRST DRAW**	**10.8**	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNSET ES

Micro Log In **47578**
Total Samples 12
Date Sampled 8/20/97
Date Received 8/20/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47578-06 DRINKING FOUNTAIN OUTSIDE BY ROOM 12 DOOR FIRST DRAW	10.2	1.0	
Client 7 Micro 47578-07 DRINKING FOUNTAIN CLASSROOM 005 FIRST DRAW	88.8	3.3	
Client 8 Micro 47578-08 DRINKING FOUNTAIN CLASSROOM 004 FIRST DRAW	100	3.3	
Client 9 Micro 47578-09 DRINKING FOUNTAIN CLASSROOM 003 FIRST DRAW	9.9	1.0	
Client 10 Micro 47578-10 CLASSROOM 001 FIRST DRAW	49.9	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNSET ES

Micro Log In **47578**
Total Samples 12
Date Sampled 8/20/97
Date Received 8/20/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47578-11 **OUTSIDE YARD BY ROOM 001 FIRST DRAW**	**33.2**	1.0	
Client 12 Micro 47578-12 **BLANK**	**<1.0**	1.0	

Technical Supervisor: 9/8/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUNSET ES

Micro Log In **50653**
Total Samples 12
Date Sampled 11/12/97
Date Received 11/14/97
Date Analyzed 11/14/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **4A** Micro 53653-01 **DRINKING FOUNTAIN ROOM 14 - NORTH WALL BLANK**	**6.3**	1.0	
Client **4B** Micro 53653-02 **DRINKING FOUNTAIN ROOM 14 - NORTH WALL BLANK**	**9.9**	1.0	
Client **4C** Micro 53653-03 **DRINKING FOUNTAIN ROOM 14 - NORTH WALL BLANK**	**24.7**	1.0	
Client **7A** Micro 53653-04 **DRINKING FOUNTAIN ROOM 005 - EAST WALL BLANK**	**15.6**	1.0	
Client **7B** Micro 53653-05 **DRINKING FOUNTAIN ROOM 005 - EAST WALL BLANK**	**13.8**	1.0	

Technical Supervisor: F. Ramezanzadeh 11/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES / CC

Micro Log In **47940**
Total Samples 23
Date Sampled 8/24/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 47940-01 DRINKING FOUNTAIN RM 12 FIRST DRAW	3.0	1.0	
Client # 2 Micro 47940-02 DRINKING FOUNTAIN RM 13 FIRST DRAW	15.2	1.0	
Client # 3 Micro 47940-03 DRINKING FOUNTAIN RM 14 FIRST DRAW	11.6	1.0	
Client # 4 Micro 47940-04 DRINKING FOUNTAIN RM 11 FIRST DRAW	77.4	2.9	
Client # 5 Micro 47940-05 DRINKING FOUNTAIN CORRIDOR 2ND FLOOR FIRST DRAW	6.1	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES / CC

Micro Log In **47940**
Total Samples 23
Date Sampled 8/24/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 6 Micro 47940-06 DRINKING FOUNTAIN RM 8 FIRST DRAW	15.1	1.0	
Client # 7 Micro 47940-07 DRINKING FOUNTAIN RM 9 FIRST DRAW	8.3	1.0	
Client # 8 Micro 47940-08 DRINKING FOUNTAIN RM 7 FIRST DRAW	14.5	1.0	
Client # 9 Micro 47940-09 DRINKING FOUNTAIN RM 10 FIRST DRAW	9.4	1.0	
Client # 10 Micro 47940-10 DRINKING FOUNTAIN RM 1 FIRST DRAW	6.7	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES / CC

Micro Log In **47940**
Total Samples 23
Date Sampled 8/24/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 11 Micro 47940-11 **DRINKING FOUNTAIN RM 4 FIRST DRAW**	**14.4**	1.0	
Client # 12 Micro 47940-12 **DRINKING FOUNTAIN RM 2 FIRST DRAW**	**17.6**	1.0	
Client # 13 Micro 47940-13 **DRINKING FOUNTAIN RM 3 FIRST DRAW**	**2.5**	1.0	
Client # 14 Micro 47940-14 **DRINKING FOUNTAIN RM 5 FIRST DRAW**	**12.4**	1.0	
Client # 15 Micro 47940-15 **DRINKING FOUNTAIN RM 6 FIRST DRAW**	**6.1**	1.0	

Technical Supervisor: 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES / CC

Micro Log In **47940**
Total Samples 23
Date Sampled 8/24/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 16 Micro 47940-16 SINK FAUCET STAFF LUNCH ROOM FIRST DRAW	11.9	1.0	
Client # 17 Micro 47940-17 SINK FAUCET CC KITCHEN FIRST DRAW	91.0	3.3	
Client # 18 Micro 47940-18 DRINKING FOUNTAIN UPPER YARD L - DF FIRST DRAW	1.1	1.0	
Client # 19 Micro 47940-19 DRINKING FOUNTAIN UPPER YARD R - DF FIRST DRAW	< 1.0	1.0	
Client # 20 Micro 47940-20 SINK FAUCET CC INSIDE KITCHEN FIRST DRAW	7.0	1.0	

Technical Supervisor: 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES / CC

Micro Log In **47940**
Total Samples 23
Date Sampled 8/24/97
Date Received 8/29/97
Date Analyzed 9/2/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 21 Micro 47940-21 **MULTIPLE DRINKING FOUNTAIN LOWER YARD FIRST DRAW**	< 1.0	1.0	
Client # 22 Micro 47940-22 **BLANK**	< 1.0	1.0	
Client # 23 Micro 47940-23 **DRINKING FOUNTAIN MAIN OFFICE FIRST DRAW**	11.2	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: AL

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES /CC

Micro Log In **49314**
Total Samples 30
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1-A ~~1-A~~ 14A Micro 49314-01 DRINKING FOUNTAIN ROOM 5 RE-SAMPLE	12.2	1.0	
Client 1-B ~~1-B~~ 14B Micro 49314-02 DRINKING FOUNTAIN ROOM 5 RE-SAMPLE	3.7	1.0	
Client 1-C ~~1-C~~ 14C Micro 49314-03 DRINKING FOUNTAIN ROOM 5 RE-SAMPLE	7.1	1.0	
Client 2-A 12A Micro 49314-04 DRINKING FOUNTAIN ROOM 2 RE-SAMPLE	4.9	1.0	
Client 2-B 12B Micro 49314-05 DRINKING FOUNTAIN ROOM 2 RE-SAMPLE	2.4	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES /CC

Micro Log In **49314**
Total Samples 30
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~2-C~~ 12C Micro 49314-06 **DRINKING FOUNTAIN ROOM 2 RE-SAMPLE**	**5.4**	1.0	
Client ~~3-A~~ 11A Micro 49314-07 **DRINKING FOUNTAIN ROOM 4 RE-SAMPLE**	**2.3**	1.0	
Client ~~2-B~~ 11B Micro 49314-08 **DRINKING FOUNTAIN ROOM 4 RE-SAMPLE**	**2.0**	1.0	
Client ~~3-C~~ 11C Micro 49314-09 **DRINKING FOUNTAIN ROOM 4 RE-SAMPLE**	**3.7**	1.0	
Client ~~4-A~~ 8A Micro 49314-10 **DRINKING FOUNTAIN ROOM 7 RE-SAMPLE**	**2.1**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES /CC

Micro Log In **49314**
Total Samples 30
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~4-B~~ 8B Micro 49314-11 DRINKING FOUNTAIN ROOM 7 RE-SAMPLE	1.9	1.0	
Client ~~4-C~~ 8C Micro 49314-12 DRINKING FOUNTAIN ROOM 7 RE-SAMPLE	2.8	1.0	
Client ~~5-A~~ 6A Micro 49314-13 DRINKING FOUNTAIN ROOM 8 RE-SAMPLE	1.8	1.0	
Client ~~5-B~~ 6B Micro 49314-14 DRINKING FOUNTAIN ROOM 8 RE-SAMPLE	1.7	1.0	
Client ~~5-C~~ 6C Micro 49314-15 DRINKING FOUNTAIN ROOM 8 RE-SAMPLE	2.7	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES /CC

Micro Log In **49314**
Total Samples 30
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~6-A~~ 4A Micro 49314-16 DRINKING FOUNTAIN ROOM 11 RE-SAMPLE	**18.1**	1.0	
Client ~~6-B~~ 4B Micro 49314-17 DRINKING FOUNTAIN ROOM 11 RE-SAMPLE	**5.2**	1.0	
Client ~~6-C~~ 4C Micro 49314-18 DRINKING FOUNTAIN ROOM 11 RE-SAMPLE	**9.8**	1.0	
Client ~~7-A~~ 3A Micro 49314-19 DRINKING FOUNTAIN ROOM 14 RE-SAMPLE	**2.7**	1.0	
Client ~~7-B~~ 3B Micro 49314-20 DRINKING FOUNTAIN ROOM 14 RE-SAMPLE	**2.0**	1.0	

Technical Supervisor: F Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES /CC

Micro Log In **49314**
Total Samples 30
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~7-C~~ 3C Micro 49314-21 DRINKING FOUNTAIN ROOM 14 RE-SAMPLE	5.1	1.0	
Client ~~8-A~~ 2A Micro 49314-22 DRINKING FOUNTAIN ROOM 13 RE-SAMPLE	3.3	1.0	
Client ~~8-B~~ 2B Micro 49314-23 DRINKING FOUNTAIN ROOM 13 RE-SAMPLE	3.0	1.0	
Client ~~8-C~~ 2C Micro 49314-24 DRINKING FOUNTAIN ROOM 13 RE-SAMPLE	6.6	1.0	
Client ~~9-A~~ 10A Micro 49314-25 SINK FAUCET STAFF LUNCH ROOM RE-SAMPLE	4.7	1.0	

Technical Supervisor: F Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
SUTRO ES /CC

Micro Log In **49314**
Total Samples 30
Date Sampled 10/4/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~9-B~~ 16B Micro 49314-26 SINK FAUCET STAFF LUNCH ROOM RE-SAMPLE	4.0	1.0	
Client ~~9-C~~ 16C Micro 49314-27 SINK FAUCET STAFF LUNCH ROOM RE-SAMPLE	6.9	1.0	
Client ~~10-A~~ 17A Micro 49314-28 SINK FAUCET CC / KITCHEN RE-SAMPLE	1.6	1.0	
Client ~~10-B~~ 17B Micro 49314-29 SINK FAUCET CC / KITCHEN RE-SAMPLE	2.2	1.0	
Client ~~10-C~~ 17C Micro 49314-30 SINK FAUCET CC / KITCHEN RE-SAMPLE	3.8	1.0	

Technical Supervisor: _____ 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOHN SWETT ES & PK

Micro Log In 47577
Total Samples 12
Date Sampled 8/20/97
Date Received 8/20/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47577-01 DRINKING FOUNTAIN CAFE ROOM 110 FIRST DRAW	3.2	1.0	
Client 2 Micro 47577-02 SINK FOUNTAIN KITCHEN ROOM 112 FIRST DRAW	5.5	1.0	
Client 3 Micro 47577-03 DRINKING FOUNTAIN PRE-K ROOM 111 FIRST DRAW	3.1	1.0	
Client 4 Micro 47577-04 DRINKING FOUNTAIN PRE-K C92 FIRST DRAW	6.3	1.0	
Client 5 Micro 47577-05 DRINKING FOUNTAIN 1ST FLOOR C90 FIRST DRAW	9.9	1.0	

Technical Supervisor: 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOHN SWETT ES & PK

Micro Log In **47577**
Total Samples 12
Date Sampled 8/20/97
Date Received 8/20/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47577-06 DRINKING FOUNTAIN 2ND FLOOR C90 FIRST DRAW	4.5	1.0	
Client 7 Micro 47577-07 DRINKING FOUNTAIN BASEMENT C90 FIRST DRAW	4.8	1.0	
Client 8 Micro 47577-08 DRINKING FOUNTAIN BASEMENT K-1, ROOM 001 FIRST DRAW	11.0	1.0	
Client 9 Micro 47577-09 DRINKING FOUNTAIN BASEMENT K-2, ROOM 002 FIRST DRAW	5.8	1.0	
Client 10 Micro 47577-10 MULTIPLE DRINKING FOUNTAIN YARD - EAST SIDE OF BUILDING FIRST DRAW	6.1	1.0	

Technical Supervisor: F Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
JOHN SWETT ES & PK

Micro Log In **47577**
Total Samples 12
Date Sampled 8/20/97
Date Received 8/20/97
Date Analyzed 8/20/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47577-11 **MULTIPLE DRINKING FOUNTAIN YARD - WEST SIDE OF BUILDING FIRST DRAW**	**4.6**	1.0	
Client 12 Micro 47577-12 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: ER Taylor ES

Lab Proj. ID: 9708756

Sampled: 08/13/97
Received: 08/13/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708756-01 Sample Desc : **LIQUID,1**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.024**
Lab No: 9708756-02 Sample Desc : **LIQUID,2**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.0072**
Lab No: 9708756-03 Sample Desc : **LIQUID,3**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.0076**
Lab No: 9708756-04 Sample Desc : **LIQUID,4**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.0076**
Lab No: 9708756-05 Sample Desc : **LIQUID,5**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.0063**
Lab No: 9708756-06 Sample Desc : **LIQUID,6**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.011**
Lab No: 9708756-07 Sample Desc : **LIQUID,7**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.021**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: ER Taylor ES
Lab Proj. ID: 9708756

Sampled: 08/13/97
Received: 08/13/97
Analyzed: see below
Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708756-08 Sample Desc : LIQUID,8				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.0065**
Lab No: 9708756-09 Sample Desc : LIQUID,9				
Lead	mg/L	08/20/97	0.0050	N.D.
Lab No: 9708756-10 Sample Desc : LIQUID,10				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.010**
Lab No: 9708756-11 Sample Desc : LIQUID,11				
Lead	mg/L	08/20/97	0.0050	N.D.
Lab No: 9708756-12 Sample Desc : LIQUID,12				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.073**
Lab No: 9708756-13 Sample Desc : LIQUID,13				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.010**
Lab No: 9708756-14 Sample Desc : LIQUID,14				
Lead	**mg/L**	**08/21/97**	**0.0050**	**0.0059**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: ER Taylor ES

Lab Proj. ID: 9708756

Sampled: 08/13/97
Received: 08/13/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708756-15 Sample Desc : **LIQUID,15**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.0072**
Lab No: 9708756-16 Sample Desc : **LIQUID,16**				
Lead	mg/L	08/20/97	0.0050	N.D.
Lab No: 9708756-17 Sample Desc : **LIQUID,17**				
Lead	mg/L	08/20/97	0.0050	N.D.
Lab No: 9708756-18 Sample Desc : **LIQUID,18**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.010**
Lab No: 9708756-19 Sample Desc : **LIQUID,19 (Blank)**				
Lead	mg/L	08/20/97	0.0050	N.D.
Lab No: 9708756-20 Sample Desc : **LIQUID,20**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.0065**
Lab No: 9708756-21 Sample Desc : **LIQUID,6 Duplicate**				
Lead	**mg/L**	**08/20/97**	**0.0050**	**0.010**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: ER Taylor ES

Lab Proj. ID: 9708756

Sampled: 08/13/97
Received: 08/13/97
Analyzed: see below

Reported: 08/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708756-22 Sample Desc : LIQUID,14 Duplicate				
Lead	mg/L	08/20/97	0.0050	0.0059 D
Lab No: 9708756-23 Sample Desc : LIQUID,20 Duplicate				
Lead	mg/L	08/20/97	0.0050	0.0063 D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: ER Taylor
Lab Proj. ID: 9708F18

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below
Reported: 09/03/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708F18-01 Sample Desc : **LIQUID,ER Taylor 2-1**				
Lead	mg/L	09/02/97	0.0050	N.D. R1
Lab No: 9708F18-02 Sample Desc : **LIQUID,ER Taylor 2-2**				
Lead	mg/L	09/02/97	0.0050	R2 N.D.
Lab No: 9708F18-03 Sample Desc : **LIQUID,ER Taylor 2-3**				
Lead	mg/L	09/02/97	0.0050	N.D. R1
Lab No: 9708F18-04 Sample Desc : **LIQUID,ER Taylor 2-4**				
Lead	mg/L	09/02/97	0.0050	R2 N.D.
Lab No: 9708F18-05 Sample Desc : **LIQUID,ER Taylor 2-5**				
Lead	mg/L	09/02/97	0.0050	N.D. R1
Lab No: 9708F18-06 Sample Desc : **LIQUID,ER Taylor 2-6**				
Lead	mg/L	09/02/97	0.0050	R2 N.D.
Lab No: 9708F18-07 Sample Desc : **LIQUID,ER Taylor 2-7**				
Lead	mg/L	09/02/97	0.0050	N.D. R1

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: ER Taylor

Lab Proj. ID: 9708F18

Sampled: 08/29/97
Received: 08/29/97
Analyzed: see below

Reported: 09/03/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708F18-08 Sample Desc : **LIQUID,ER Taylor 2-8**				
Lead	mg/L	09/02/97	0.0050	N.D.
Lab No: 9708F18-09 Sample Desc : **LIQUID,ER Taylor 2-8 Duplicate**				
Lead	mg/L	09/02/97	0.0050	N.D.
Lab No: 9708F18-10 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	09/02/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: ER Taylor ES

Lab Proj. ID: 9709821

Sampled: 09/16/97
Received: 09/16/97
Analyzed: see below

Reported: 09/19/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709821-01 Sample Desc : **LIQUID,ER Taylor 3-1**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709821-02 Sample Desc : **LIQUID,ER Taylor 3-2**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709821-03 Sample Desc : **LIQUID,ER Taylor 3-3**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709821-04 Sample Desc : **LIQUID,ER Taylor 3-3 dup**				
Lead	mg/L	09/19/97	0.0050	N.D.
Lab No: 9709821-05 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	09/19/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: ER Taylor E.S.

Lab Proj. ID: 9710E47

Sampled: 10/23/97
Received: 10/24/97
Analyzed: see below

Reported: 10/30/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710E47-01 Sample Desc : **LIQUID,1-A**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E47-02 Sample Desc : **LIQUID,1-B**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E47-03 Sample Desc : **LIQUID,7-A**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E47-04 Sample Desc : **LIQUID,7-B**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E47-05 Sample Desc : **LIQUID,12-A**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E47-06 Sample Desc : **LIQUID,12-B**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.0065**
Lab No: 9710E47-07 Sample Desc : **LIQUID,1-C**				
Lead	mg/L	10/29/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Gianninl

Client Proj. ID: ER Taylor E.S.

Lab Proj. ID: 9710E47

Sampled: 10/23/97
Received: 10/24/97
Analyzed: see below

Reported: 10/30/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710E47-08 Sample Desc : **LIQUID,7-C**				
Lead	**mg/L**	**10/29/97**	**0.0050**	**0.0083**
Lab No: 9710E47-09 Sample Desc : **LIQUID,12-C**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E47-10 Sample Desc : **LIQUID,12-C Duplicate**				
Lead	mg/L	10/29/97	0.0050	N.D.
Lab No: 9710E47-11 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	10/29/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SCA

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9708B84

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B84-01 Sample Desc : LIQUID,Treasure Island-1				
Lead	mg/L	08/27/97	0.0050	0.0057
Lab No: 9708B84-02 Sample Desc : LIQUID,Treasure Island-1 (DUP)				
Lead	mg/L	08/27/97	0.0050	0.0050 D
Lab No: 9708B84-03 Sample Desc : LIQUID,Treasure Island-2				
Lead	mg/L	08/27/97	0.0050	0.024 ✓
Lab No: 9708B84-04 Sample Desc : LIQUID,Treasure Island-3				
Lead	mg/L	08/27/97	0.0050	0.013
Lab No: 9708B84-05 Sample Desc : LIQUID,Treasure Island-4				
Lead	mg/L	08/27/97	0.0050	0.0071
Lab No: 9708B84-06 Sample Desc : LIQUID,Treasure Island-5				
Lead	mg/L	08/27/97	0.0050	0.013
Lab No: 9708B84-07 Sample Desc : LIQUID,Treasure Island-6				
Lead	mg/L	08/27/97	0.0050	0.0065

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9708B84

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B84-08 Sample Desc : **LIQUID,Treasure Island-7**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0062**
Lab No: 9708B84-09 Sample Desc : **LIQUID,Treasure Island-8**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0065**
Lab No: 9708B84-10 Sample Desc : **LIQUID,Treasure Island-9**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0079**
Lab No: 9708B84-11 Sample Desc : **LIQUID,Treasure Island-10**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-12 Sample Desc : **LIQUID,Treasure Island-11**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-13 Sample Desc : **LIQUID,Treasure Island-11 (DUP)**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-14 Sample Desc : **LIQUID,Treasure Island-12**				
Lead	mg/L	08/27/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9708B84

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B84-15 Sample Desc : **LIQUID,Treasure Island-13**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.090**
Lab No: 9708B84-16 Sample Desc : **LIQUID,Treasure Island-14**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.077**
Lab No: 9708B84-17 Sample Desc : **LIQUID,Treasure Island-15**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.039**
Lab No: 9708B84-18 Sample Desc : **LIQUID,Treasure Island-16**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.025**
Lab No: 9708B84-19 Sample Desc : **LIQUID,Treasure Island-17**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-20 Sample Desc : **LIQUID,Treasure Island-18**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-21 Sample Desc : **LIQUID,Treasure Island-19**				
Lead	mg/L	08/27/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9708B84

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B84-22 Sample Desc : **LIQUID,Treasure Island-20**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-23 Sample Desc : **LIQUID,Treasure Island-21**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-24 Sample Desc : **LIQUID,Treasure Island-21 (DUP)**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-25 Sample Desc : **LIQUID,Treasure Island-22**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-26 Sample Desc : **LIQUID,Treasure Island-23**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0084**
Lab No: 9708B84-27 Sample Desc : **LIQUID,Treasure Island-24**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.019**
Lab No: 9708B84-28 Sample Desc : **LIQUID,Treasure Island-25**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0075**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9708B84

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B84-29 Sample Desc : **LIQUID,Treasure Island-26**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-30 Sample Desc : **LIQUID,Treasure Island-27**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0077**
Lab No: 9708B84-31 Sample Desc : **LIQUID,Treasure Island-28**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0073**
Lab No: 9708B84-32 Sample Desc : **LIQUID,Treasure Island-29**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.021**
Lab No: 9708B84-33 Sample Desc : **LIQUID,Treasure Island-30**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0074**
Lab No: 9708B84-34 Sample Desc : **LIQUID,Treasure Island-31**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0052**
Lab No: 9708B84-35 Sample Desc : **LIQUID,Treasure Island-31 (DUP)**				
Lead	mg/L	08/27/97	0.0050	N.D.

D

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9708B84

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B84-36 Sample Desc : **LIQUID,Treasure Island-32**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.011**
Lab No: 9708B84-37 Sample Desc : **LIQUID,Treasure Island-33**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.038**
Lab No: 9708B84-38 Sample Desc : **LIQUID,Treasure Island-34**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0096**
Lab No: 9708B84-39 Sample Desc : **LIQUID,Treasure Island-35**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-40 Sample Desc : **LIQUID,Treasure Island-36**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-41 Sample Desc : **LIQUID,Treasure Island-37**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B84-42 Sample Desc : **LIQUID,Treasure Island-38**				
Lead	mg/L	08/27/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9708B84

Sampled: 08/20/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B84-43 Sample Desc : **LIQUID,Treasure Island-39**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.018**
Lab No: 9708B84-44 Sample Desc : **LIQUID,Treasure Island-40 (Blank)**				
Lead	mg/L	08/27/97	0.0050	N.D.

S

B

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9710474

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710474-01 Sample Desc : **LIQUID,T.I. 2-A**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.017**
Lab No: 9710474-02 Sample Desc : **LIQUID,T.I. 2-B**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.011**
Lab No: 9710474-03 Sample Desc : **LIQUID,T.I. 2-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.043**
Lab No: 9710474-04 Sample Desc : **LIQUID,T.I. 3-A**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710474-05 Sample Desc : **LIQUID,T.I. 3-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710474-06 Sample Desc : **LIQUID,T.I. 3-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0090**
Lab No: 9710474-07 Sample Desc : **LIQUID,T.I. 5-A**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0060**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9710474

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710474-08 Sample Desc : **LIQUID,T.I. 5-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710474-09 Sample Desc : **LIQUID,T.I. 5-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0080**
Lab No: 9710474-10 Sample Desc : **LIQUID,T.I. 5-C (duplicate)**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0080**
Lab No: 9710474-11 Sample Desc : **LIQUID,T.I. 13-A**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0090**
Lab No: 9710474-12 Sample Desc : **LIQUID,T.I. 13-B**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0080**
Lab No: 9710474-13 Sample Desc : **LIQUID,T.I. 13-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.033**
Lab No: 9710474-14 Sample Desc : **LIQUID,T.I. 13-D**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.010**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES
Lab Proj. ID: 9710474

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below
Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710474-15 Sample Desc : **LIQUID,T.I. 14-A**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0060**
Lab No: 9710474-16 Sample Desc : **LIQUID,T.I. 14-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710474-17 Sample Desc : **LIQUID,T.I. 14-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.026**
Lab No: 9710474-18 Sample Desc : **LIQUID,T.I. 15-A**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0070**
Lab No: 9710474-19 Sample Desc : **LIQUID,T.I. 15-B**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0070**
Lab No: 9710474-20 Sample Desc : **LIQUID,T.I. 15-B (duplicate)**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0070**
Lab No: 9710474-21 Sample Desc : **LIQUID,T.I. 15-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.015**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9710474

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710474-22 Sample Desc : **LIQUID,T.I. 16-A**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0050**
Lab No: 9710474-23 Sample Desc : **LIQUID,T.I. 16-B**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0060**
Lab No: 9710474-24 Sample Desc : **LIQUID,T.I. 16-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.024**
Lab No: 9710474-25 Sample Desc : **LIQUID,T.I. 29-A**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710474-26 Sample Desc : **LIQUID,T.I. 29-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710474-27 Sample Desc : **LIQUID,T.I. 29-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0050**
Lab No: 9710474-28 Sample Desc : **LIQUID,T.I. 33-A**				
Lead	mg/L	10/10/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Shella Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Treasure Island ES

Lab Proj. ID: 9710474

Sampled: 10/07/97
Received: 10/09/97
Analyzed: see below

Reported: 10/13/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710474-29 Sample Desc : **LIQUID,T.I. 33-B**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710474-30 Sample Desc : **LIQUID,T.I. 33-B (duplicate)**				
Lead	mg/L	10/10/97	0.0050	N.D.
Lab No: 9710474-31 Sample Desc : **LIQUID,T.I. 33-C**				
Lead	**mg/L**	**10/10/97**	**0.0050**	**0.0090**
Lab No: 9710474-32 Sample Desc : **LIQUID,T.I. Blank**				
Lead	mg/L	10/10/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Elk Park
Lab Proj. ID: 9708A92

Sampled: 08/14/97
Received: 08/21/97
Analyzed: see below

Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708A92-01 Sample Desc : **LIQUID,Elk Park 1**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-02 Sample Desc : **LIQUID,Elk Park 1 Duplicate**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-03 Sample Desc : **LIQUID,Elk Park 2**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-04 Sample Desc : **LIQUID,Elk Park 2 Duplicate**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-05 Sample Desc : **LIQUID,Elk Park 3**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-06 Sample Desc : **LIQUID,Elk Park 4**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-07 Sample Desc : **LIQUID,Elk Park 5**				
Lead	mg/L	08/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Elk Park
Lab Proj. ID: 9708A92

Sampled: 08/14/97
Received: 08/21/97
Analyzed: see below

Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708A92-08 Sample Desc : **LIQUID,Elk Park 6**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-09 Sample Desc : **LIQUID,Elk Park 7**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-10 Sample Desc : **LIQUID,Elk Park 8**				
Lead	**mg/L**	**08/22/97**	**0.0050**	**0.025**
Lab No: 9708A92-11 Sample Desc : **LIQUID,Elk Park 9**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-12 Sample Desc : **LIQUID,Elk Park 10**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-13 Sample Desc : **LIQUID,Elk Park 11**				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-14 Sample Desc : **LIQUID,Elk Park 12**				
Lead	mg/L	08/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Shella Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

File

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Elk Park
Lab Proj. ID: 9708A92

Sampled: 08/14/97
Received: 08/21/97
Analyzed: see below
Reported: 08/25/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708A92-15 Sample Desc : LIQUID,Elk Park 13				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-16 Sample Desc : LIQUID,Elk Park 14				
Lead	**mg/L**	**08/22/97**	**0.0050**	**0.026**
Lab No: 9708A92-17 Sample Desc : LIQUID,Elk Park 15				
Lead	**mg/L**	**08/22/97**	**0.0050**	**0.019**
Lab No: 9708A92-18 Sample Desc : LIQUID,Elk Park 16				
Lead	mg/L	08/22/97	0.0050	N.D.
Lab No: 9708A92-19 Sample Desc : LIQUID,Elk Park 17				
Lead	**mg/L**	**08/22/97**	**0.0050**	**0.0077**
Lab No: 9708A92-20 Sample Desc : LIQUID,Elk Park 18				
Lead	**mg/L**	**08/22/97**	**0.0050**	**0.031**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Tule Elk Park CC
Lab Proj. ID: 9709992

Sampled: 09/17/97
Received: 09/17/97
Analyzed: see below
Reported: 09/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709992-01 Sample Desc : **LIQUID,2-1**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709992-02 Sample Desc : **LIQUID,2-2**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0051**
Lab No: 9709992-03 Sample Desc : **LIQUID,2-3**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0078**
Lab No: 9709992-04 Sample Desc : **LIQUID,2-4**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0061**
Lab No: 9709992-05 Sample Desc : **LIQUID,2-5**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.0052**
Lab No: 9709992-06 Sample Desc : **LIQUID,2-6**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709992-07 Sample Desc : **LIQUID,2-6 Duplicate**				
Lead	mg/L	09/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Tule Elk Park CC

Lab Proj. ID: 9709992

Sampled: 09/17/97
Received: 09/17/97
Analyzed: see below

Reported: 09/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709992-08 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	09/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Tule Elk Parch CC

Lab Proj. ID: 9709996

Sampled: 09/17/97
Received: 09/17/97
Analyzed: see below

Reported: 09/22/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9709996-01 Sample Desc : **LIQUID,3-1**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709996-02 Sample Desc : **LIQUID,3-2**				
Lead	**mg/L**	**09/22/97**	**0.0050**	**0.011**
Lab No: 9709996-03 Sample Desc : **LIQUID,3-3**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709996-04 Sample Desc : **LIQUID,3-3 Duplicate**				
Lead	mg/L	09/22/97	0.0050	N.D.
Lab No: 9709996-05 Sample Desc : **LIQUID,Blank**				
Lead	mg/L	09/22/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Ulloa Elementary
Lab Proj. ID: 9708B71

Sampled: 08/16/97
Received: 08/22/97
Analyzed: see below
Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B71-01 Sample Desc : **LIQUID,Ulloa 1**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B71-02 Sample Desc : **LIQUID,Ulloa 2**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-03 Sample Desc : **LIQUID,Ulloa 2 Duplicate**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-04 Sample Desc : **LIQUID,Ulloa 3**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-05 Sample Desc : **LIQUID,Ulloa 3 Duplicate**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-06 Sample Desc : **LIQUID,Ulloa 4**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-07 Sample Desc : **LIQUID,Ulloa 4 Duplicate**				
Lead	mg/L	08/26/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Ulloa Elementary
Lab Proj. ID: 9708B71

Sampled: 08/16/97
Received: 08/22/97
Analyzed: see below
Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B71-08 Sample Desc : **LIQUID,Ulloa 5**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-09 Sample Desc : **LIQUID,Ulloa 6**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-10 Sample Desc : **LIQUID,Ulloa 7**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0095**
Lab No: 9708B71-11 Sample Desc : **LIQUID,Ulloa 8**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-12 Sample Desc : **LIQUID,Ulloa 9**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-13 Sample Desc : **LIQUID,Ulloa 10**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0081**
Lab No: 9708B71-14 Sample Desc : **LIQUID,Ulloa 11**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.012**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Ulloa Elementary

Lab Proj. ID: 9708B71

Sampled: 08/16/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B71-15 Sample Desc : LIQUID,Ulloa 12				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-16 Sample Desc : LIQUID,Ulloa 13				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0091**
Lab No: 9708B71-17 Sample Desc : LIQUID,Ulloa 14				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-18 Sample Desc : LIQUID,Ulloa 16				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-19 Sample Desc : LIQUID,Ulloa 17				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.017**
Lab No: 9708B71-20 Sample Desc : LIQUID,Ulloa 18				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0051**
Lab No: 9708B71-21 Sample Desc : LIQUID,Ulloa 19				
Lead	mg/L	08/26/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Ulloa Elementary

Lab Proj. ID: 9708B71

Sampled: 08/16/97
Received: 08/22/97
Analyzed: see below

Reported: 08/27/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B71-22 Sample Desc : **LIQUID,Ulloa 20**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-23 Sample Desc : **LIQUID,Ulloa 21**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0062**
Lab No: 9708B71-24 Sample Desc : **LIQUID,Ulloa 22**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-25 Sample Desc : **LIQUID,Ulloa 24**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-26 Sample Desc : **LIQUID,Ulloa 25**				
Lead	mg/L	08/26/97	0.0050	N.D.
Lab No: 9708B71-27 Sample Desc : **LIQUID,Ulloa 26**				
Lead	**mg/L**	**08/26/97**	**0.0050**	**0.0062**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ULLOA ES

Micro Log In **49184**
Total Samples 7
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **11A** Micro 49184-01 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM 021** **FIRST DRAW**	< **1.0**	1.0	
Client **11B** Micro 49184-02 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM 021** **FIRST DRAW**	< **1.0**	1.0	
Client **11C** Micro 49184-03 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM 021** **FIRST DRAW**	< **1.0**	1.0	
Client **17A** Micro 49184-04 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM 001** **FIRST DRAW**	**1.4**	1.0	
Client **17B** Micro 49184-05 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM 001** **FIRST DRAW**	**4.4**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
ULLOA ES

Micro Log In **49184**
Total Samples 7
Date Sampled 10/2/97
Date Received 10/3/97
Date Analyzed 10/3/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **17C** Micro 49184-06 **DRINKING FOUNTAIN** **FIRST FLOOR, ROOM 001** **FIRST DRAW**	**3.4**	1.0	
Client **BLANK** Micro 49184-07 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY ES

Micro Log In 60516
Total Samples 32
Date Sampled 9/23/98
Date Received 9/23/98
Date Analyzed 9/25/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 60516-01 DRINKING FOUNTAIN HALL BY ROOM 6 - LEFT	< 1	1	
Client 2 Micro 60516-02 SINK FAUCET ROOM 17	4	1	
Client 3 Micro 60516-03 DRINKING FOUNTAIN HALL BY ROOM 6 - RIGHT	2	1	
Client 4 Micro 60516-04 SINK FAUCET ROOM 6	3	1	
Client 5 Micro 60516-05 SINK FAUCET KITCHEN	3	1	

Technical Supervisor: F. R. 9/29/98 Analyst: FR

Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY ES

Micro Log In 60516
Total Samples 32
Date Sampled 9/23/98
Date Received 9/23/98
Date Analyzed 9/25/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 60516-06 DRINKING FOUNTAIN HALL BY ROOM 102 - LEFT	< 1	1	
Client 7 Micro 60516-07 DRINKING FOUNTAIN HALL BY ROOM 102 - RIGHT	< 1	1	
Client 8 Micro 60516-08 SINK FAUCET ROOM 102	< 1	1	
Client 9 Micro 60516-09 SINK FAUCET ROOM 104	1	1	
Client 10 Micro 60516-10 SINK FAUCET ROOM 101	2	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY ES

Micro Log In 60516
Total Samples 32
Date Sampled 9/23/98
Date Received 9/23/98
Date Analyzed 9/25/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 60516-11 SINK FAUCET ROOM 106	2	1	
Client 12 Micro 60516-12 DRINKING FOUNTAIN HALL BY ROOM 106 - LEFT	< 1	1	
Client 13 Micro 60516-13 DRINKING FOUNTAIN HALL BY ROOM 106 - RIGHT	< 1	1	
Client 14 Micro 60516-14 SINK FAUCET ROOM 108	< 1	1	
Client 15 Micro 60516-15 DRINKING FOUNTAIN HALL BY AUDITORIUM	4	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY ES

Micro Log In 60516
Total Samples 32
Date Sampled 9/23/98
Date Received 9/23/98
Date Analyzed 9/25/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 60516-16 SINK FAUCET ROOM 209	2	1	
Client 17 Micro 60516-17 SINK FAUCET ROOM 208	< 1	1	
Client 18 Micro 60516-18 DRINKING FOUNTAIN HALL BY ROOM 208 - LEFT	< 1	1	
Client 19 Micro 60516-19 DRINKING FOUNTAIN HALL BY ROOM 208 - RIGHT	< 1	1	
Client 20 Micro 60516-20 SINK FAUCET ROOM 207	1	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY ES

Micro Log In 60516
Total Samples 32
Date Sampled 9/23/98
Date Received 9/23/98
Date Analyzed 9/25/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 21 Micro 60516-21 SINK FAUCET ROOM 206	1	1	
Client 22 Micro 60516-22 SINK FAUCET TEACHER KITCHEN	< 1	1	
Client 23 Micro 60516-23 SINK FAUCET ROOM 205	< 1	1	
Client 24 Micro 60516-24 SINK FAUCET ROOM 204	< 1	1	
Client 25 Micro 60516-25 SINK FAUCET ROOM 203	1	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY ES

Micro Log In 60516
Total Samples 32
Date Sampled 9/23/98
Date Received 9/23/98
Date Analyzed 9/25/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 26 Micro 60516-26 SINK FAUCET ROOM 202	< 1	1	
Client 27 Micro 60516-27 DRINKING FOUNTAIN HALL BY ROOM 202 - LEFT	< 1	1	
Client 28 Micro 60516-28 DRINKING FOUNTAIN HALL BY ROOM 202 - RIGHT	1	1	
Client 29 Micro 60516-29 SINK FAUCET ROOM 201	2	1	
Client 30 Micro 60516-30 MULTIPLE DRINKING FOUNTAIN EXT LOWER	4	1	

Technical Supervisor: F. Ramezanzadeh 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY ES

Micro Log In **60516**
Total Samples **32**
Date Sampled **9/23/98**
Date Received **9/23/98**
Date Analyzed **9/25/98**

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **31** Micro 60516-31 MULTIPLE DRINKING FOUNTAIN EXT UPPER	< 1	1	
Client **BLANK** Micro 60516-32 BLANK	< 1	1	

Technical Supervisor: _____ 9/29/98 Analyst: FR
Farid Ramezanzadeh, M.S. Date Reported

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY MS

Micro Log In **47521**
Total Samples 22
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **VVMS 1** Micro 47521-01 **WATER-COOLED DRINKING FOUNTAIN CAFETERIA / 225 FIRST DRAW**	**5.3**	1.0	
Client **VVMS 2** Micro 47521-02 **WATER-COOLED DRINKING FOUNTAIN C92 (HALL) / FIRST DRAW**	**3.8**	1.0	
Client **VVMS 3** Micro 47521-03 **WATER-COOLED DRINKING FOUNTAIN C90 (HALL) / FIRST DRAW**	**< 1.0**	1.0	
Client **VVMS 4** Micro 47521-04 **WATER-COOLED DRINKING FOUNTAIN 207 / FIRST DRAW**	**2.2**	1.0	
Client **VVMS 5** Micro 47521-05 **WATER-COOLED DRINKING FOUNTAIN C90 (HALL) / FIRST DRAW**	**16.4**	1.0	

Technical Supervisor: 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY MS

Micro Log In 47521
Total Samples 22
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client VVMS 6 Micro 47521-06 SINK FAUCET 219 B / FIRST DRAW	1.3	1.0	
Client VVMS 7 Micro 47521-07 SINK FAUCET 220 / FIRST DRAW	< 1.0	1.0	
Client VVMS 8 Micro 47521-08 WATER-COOLED DRINKING FOUNTAIN 228 / FIRST DRAW	2.0	1.0	
Client VVMS 9 Micro 47521-09 WATER-COOLED DRINKING FOUNTAIN 228 / FIRST DRAW	2.7	1.0	
Client VVMS 10 Micro 47521-10 WATER-COOLED DRINKING FOUNTAIN 229 / FIRST DRAW	1.3	1.0	

Technical Supervisor: F Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY MS

Micro Log In **47521**
Total Samples 22
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **VVMS 11** Micro 47521-11 **WATER-COOLED DRINKING FOUNTAIN 229A / FIRST DRAW**	**6.2**	1.0	
Client **VVMS 12** Micro 47521-12 **SINK FAUCET 225A / FIRST DRAW**	**< 1.0**	1.0	
Client **VVMS 13** Micro 47521-13 **WATER-COOLED DRINKING FOUNTAIN C92 (HALL) / FIRST DRAW**	**2.2**	1.0	
Client **VVMS 14** Micro 47521-14 **WATER-COOLED DRINKING FOUNTAIN C90 (HALL) / FIRST DRAW**	**1.7**	1.0	
Client **VVMS 15** Micro 47521-15 **WATER-COOLED DRINKING FOUNTAIN C93 (HALL) / FIRST DRAW**	**1.3**	1.0	

Technical Supervisor: 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY MS

Micro Log In **47521**
Total Samples 22
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **VVMS 16** Micro 47521-16 **WATER-COOLED DRINKING FOUNTAIN** **C92 / FIRST DRAW**	**2.4**	1.0	
Client **VVMS 17** Micro 47521-17 **SINK FAUCET** **308 / FIRST DRAW**	**2.9**	1.0	
Client **VVMS 18** Micro 47521-18 **SINK FAUCET** **308 / FIRST DRAW**	**< 1.0**	1.0	
Client **VVMS 19** Micro 47521-19 **SINK FAUCET** **308 / FIRST DRAW**	**< 1.0**	1.0	
Client **VVMS 20** Micro 47521-20 **SINK FAUCET** **308 / FIRST DRAW**	**1.3**	1.0	

Technical Supervisor: F Ramezanzadeh 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
VISITACION VALLEY MS

Micro Log In **47521**
Total Samples 22
Date Sampled 8/16/97
Date Received 8/19/97
Date Analyzed 8/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **VVMS 21** Micro 47521-21 **SINK FAUCET 308 / FIRST DRAW**	**3.7**	1.0	
Client **VVMS 22** Micro 47521-22 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: 9/5/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

ORIGINAL

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WALDEN HOUSE

Micro Log In **50414**
Total Samples 4
Date Sampled 11/6/97
Date Received 11/6/97
Date Analyzed 11/6/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 50414-01 SINK FAUCET MAIN KITCHEN, 1ST FLOOR INITIAL DRAW	< 1.0	1.0	
Client 2 Micro 50414-02 SINK FAUCET SW KITCHEN, 1ST FLOOR INITIAL DRAW	1.4	1.0	
Client 3 Micro 50414-03 WATER-COOLED DRINKING FOUNTAIN NORTH EAST, 2ND FLOOR INITIAL DRAW	< 1.0	1.0	
Client 4 Micro 50414-04 WATER-COOLED DRINKING FOUNTAIN NORTH EAST, 2ND FLOOR INITIAL DRAW	< 1.0	1.0	

Technical Supervisor: _____ 11/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

5900 HOLLIS STREET, SUITE M, EMERYVILLE, CALIFORNIA 94608 - (510) 653-0824

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
R. WALLENBERG HS

Micro Log In **48559**
Total Samples 9
Date Sampled 9/14/97
Date Received 9/16/97
Date Analyzed 9/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48559-01 DRINKING FOUNTAIN CAFE, R-125 NORTH WALL INITIAL SCREENING	4.2	1.0	
Client 2 Micro 48559-02 DRINKING FOUNTAIN 1ST FLOOR C-92 INITIAL SCREENING	2.9	1.0	
Client 3 Micro 48559-03 DRINKING FOUNTAIN 1ST FLOOR C-90, SOUTH INITIAL SCREENING	1.1	1.0	
Client 4 Micro 48559-04 DRINKING FOUNTAIN 1ST FLOOR C-90, NORTH INITIAL SCREENING	9.8	1.0	
Client 5 Micro 48559-05 DRINKING FOUNTAIN 2ND FLOOR C-90, NORTH INITIAL SCREENING	10.2	1.0	

Technical Supervisor: _____ 9/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
R. WALLENBERG HS

Micro Log In **48559**
Total Samples 9
Date Sampled 9/14/97
Date Received 9/16/97
Date Analyzed 9/16/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 48559-06 DRINKING FOUNTAIN 2ND FLOOR C-90, SOUTH INITIAL SCREENING	10.9	1.0	
Client 7 Micro 48559-07 DRINKING FOUNTAIN BASEMENT, GYM R-014 INITIAL SCREENING	7.7	1.0	
Client 8 Micro 48559-08 DRINKING FOUNTAIN BASEMENT LEVEL C-90, SOTH INITIAL SCREENING	22.2	1.0	
Client 9 Micro 48559-09 BLANK	< 1.0	1.0	

Technical Supervisor: 9/16/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE WASHINGTON HS

Micro Log In **47849**
Total Samples 39
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47849-01 DRINKING FOUNTAIN 1ST FLOOR FIRST DRAW (ANGLE DID NOT PERMIT FULL LITER)	< 1.0	1.0	
Client 2 Micro 47849-02 DRINKING FOUNTAIN 1ST FLOOR BY ROOM130 FIRST DRAW	< 1.0	1.0	
Client 3 Micro 47849-03 DRINKING FOUNTAIN 3RD FLOOR BY ROOM 324 FIRST DRAW	9.1	1.0	
Client 4 Micro 47849-04 SINK FAUCET 3RD FLOOR BY ROOM 324 FIRST DRAW	< 1.0	1.0	
Client 5 Micro 47849-05 DRINKING FOUNTAIN 3RD FLOOR BY ELEVATOR FIRST DRAW	< 1.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.


GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE WASHINGTON HS

Micro Log In **47849**
Total Samples 39
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47849-06 DRINKING FOUNTAIN 3RD FLOOR OUTSIDE ROOM 314 FIRST DRAW	< 1.0	1.0	
Client 7 Micro 47849-07 DRINKING FOUNTAIN 3RD FLOOR OUTSIDE ROOM 304 FIRST DRAW	1.7	1.0	
Client 8 Micro 47849-08 DRINKING FOUNTAIN 3RD FLOOR OUTSIDE ROOM FIRST DRAW	< 1.0	1.0	
Client 9 Micro 47849-09 DRINKING FOUNTAIN 2ND FLOOR OUTSIDE ROOM 236 FIRST DRAW	< 1.0	1.0	
Client 10 Micro 47849-10 DRINKING FOUNTAIN 2ND FLOOR OUTSIDE ROOM 232 FIRST DRAW	< 1.0	1.0	

Technical Supervisor:  9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE WASHINGTON HS

Micro Log In **47849**
Total Samples 39
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **11** Micro 47849-11 **SINK FAUCET** **FACULTY LOUNGE 2ND FLOOR** **FIRST DRAW**	< **1.0**	1.0	
Client **12** Micro 47849-12 **DRINKING FOUNTAIN** **2ND FLOOR** **FIRST DRAW**	**1.2**	1.0	
Client **13** Micro 47849-13 **DRINKING FOUNTAIN** **OUTSIDE ROOM 212 - 2ND FLOOR** **FIRST DRAW**	**2.4**	1.0	
Client **14** Micro 47849-14 **DRINKING FOUNTAIN** **OUTSIDE ROOM 203 - 2ND FLOOR** **FIRST DRAW**	< **1.0**	1.0	
Client **15** Micro 47849-15 **DRINKING FOUNTAIN** **OUTSIDE ROOM 105** **FIRST DRAW**	< **1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE WASHINGTON HS

Micro Log In **47849**
Total Samples 39
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47849-16 DRINKING FOUNTAIN OUTSIDE ROOM 119B - 1ST FLOOR FIRST DRAW	< 1.0	1.0	
Client 17 Micro 47849-17 DRINKING FOUNTAIN OUTSIDE 139 1ST FLOOR FIRST DRAW	< 1.0	1.0	
Client 18 Micro 47849-18 DRINKING FOUNTAIN OUTSIDE AUDITORIUM FIRST DRAW	< 1.0	1.0	
Client 19 Micro 47849-19 DRINKING FOUNTAIN 1ST FLOOR NEAR M 24 FIRST DRAW	< 1.0	1.0	
Client 20 Micro 47849-20 DRINKING FOUNTAIN BASEMENT OUTSIDE M06 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE WASHINGTON HS

Micro Log In **47849**
Total Samples 39
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 21 Micro 47849-21 DRINKING FOUNTAIN GIRLS' GYM LOCKER ROOM FIRST DRAW	1.3	1.0	
Client 22 Micro 47849-22 DRINKING FOUNTAIN BOYS LOCKER ROOM FIRST DRAW	< 1.0	1.0	
Client 23 Micro 47849-23 MULTIPLE DRINKING FOUNTAIN OUTSIDE GYM FIRST DRAW	< 1.0	1.0	
Client 24 Micro 47849-24 MULTIPLE DRINKING FOUNTAIN OUTSIDE GYM FIRST DRAW	< 1.0	1.0	
Client 25 Micro 47849-25 MULTIPLE DRINKING FOUNTAIN OUTSIDE MAIN BLDG. FIRST DRAW	< 1.0	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE WASHINGTON HS

Micro Log In **47849**
Total Samples 39
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 26 Micro 47849-26 **BLANK**	< 1.0	1.0	
Client 27 Micro 47849-27 **MULTIPLE DRINKING FOUNTAIN OUTSIDE MAIN BLDG. ROOM102 FIRST DRAW**	< 1.0	1.0	
Client 28 Micro 47849-28 **SINK FAUCET FACULTY LOUNGE FIRST DRAW**	< 1.0	1.0	
Client 29 Micro 47849-29 **SINK FAUCET ROOM 114 FIRST DRAW**	4.4	1.0	
Client 30 Micro 47849-30 **SINK FAUCET ROOM 114 FIRST DRAW**	< 1.0	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE WASHINGTON HS

Micro Log In **47849**
Total Samples 39
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 31 Micro 47849-31 SINK FAUCET ROOM 114 FIRST DRAW	< 1.0	1.0	
Client 32 Micro 47849-32 SINK FAUCET ROOM 114 FIRST DRAW	< 1.0	1.0	
Client 33 Micro 47849-33 SINK FAUCET ROOM 114 FIRST DRAW	< 1.0	1.0	
Client 34 Micro 47849-34 SINK FAUCET ROOM 114 FIRST DRAW	1.6	1.0	
Client 35 Micro 47849-35 SINK FAUCET ROOM 114 FIRST DRAW	< 1.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
GEORGE WASHINGTON HS

Micro Log In **47849**
Total Samples 39
Date Sampled 8/26/97
Date Received 8/27/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 36 Micro 47849-36 SINK FAUCET BASEMENT BY ELEVATOR FIRST DRAW	< 1.0	1.0	
Client 37 Micro 47849-37 SINK FAUCET CAFETERIA S. END FIRST DRAW	< 1.0	1.0	
Client 38 Micro 47849-38 SINK FAUCET CAFETERIA N. END FIRST DRAW	1.7	1.0	
Client 39 Micro 47849-39 SPIKED SAMPLE	49.0	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DANIEL WEBSTER ES

Micro Log In **47483**
Total Samples 25
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47483-01 WATER COOLED DRINKING FOUNTAIN HALL - ADMIN. BLDG. FIRST DRAW	1.7	1.0	
Client 2 Micro 47483-02 SINK FAUCET LOUNGE - ADMIN. BLDG. FIRST DRAW	23.2	1.0	
Client 3 Micro 47483-03 SINK FAUCET LHS SINK AUD. KIT. FIRST DRAW	13.8	1.0	
Client 5 Micro 47483-04 DRINKING FOUNTAIN AUDITORIUM E. WALL FIRST DRAW	10.2	1.0	
Client 6 Micro 47483-05 SINK DRINKING FOUNTAIN 2ND FLOOR - ROOM 16 FIRST DRAW	16.9	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DANIEL WEBSTER ES

Micro Log In **47483**
Total Samples 25
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 7 Micro 47483-06 SINK DRINKING FOUNTAIN ROOM 17 FIRST DRAW	10.1	1.0	
Client 8 Micro 47483-07 SINK DRINKING FOUNTAIN ROOM 14 FIRST DRAW	28.8	1.0	
Client 9 Micro 47483-08 SINK DRINKING FOUNTAIN ROOM 15 FIRST DRAW	41.2	1.0	
Client 10 Micro 47483-09 SINK DRINKING FOUNTAIN ROOM 11 FIRST DRAW	18.8	1.0	
Client 11 Micro 47483-10 SINK DRINKING FOUNTAIN ROOM 10 FIRST DRAW	6.1	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DANIEL WEBSTER ES

Micro Log In 47483
Total Samples 25
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 12 Micro 47483-11 SINK DRINKING FOUNTAIN ROOM 12 FIRST DRAW	30.8	1.0	
Client 13 Micro 47483-12 SINK DRINKING FOUNTAIN 2ND FLOOR - ROOM 13 FIRST DRAW	40.3	1.0	
Client 14 Micro 47483-13 SINK DRINKING FOUNTAIN 1ST FLOOR - ROOM 5 FIRST DRAW	11.6	1.0	
Client 15 Micro 47483-14 SINK DRINKING FOUNTAIN ROOM 8 FIRST DRAW	7.8	1.0	
Client 16 Micro 47483-15 SINK DRINKING FOUNTAIN ROOM 9 FIRST DRAW	6.3	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DANIEL WEBSTER ES

Micro Log In **47483**
Total Samples 25
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 17 Micro 47483-16 SINK DRINKING FOUNTAIN ROOM 6 FIRST DRAW	7.8	1.0	
Client 18 Micro 47483-17 SINK DRINKING FOUNTAIN ROOM 7 FIRST DRAW	5.0	1.0	
Client 19 Micro 47483-18 DRINKING FOUNTAIN 1ST FLOOR CENTER N-S HALL FIRST DRAW RESTRICTED SPACE - FILL 1/2" LOW	1.1	1.0	
Client 20 Micro 47483-19 SINK DRINKING FOUNTAIN ROOM 4 FIRST DRAW	5.0	1.0	
Client 21 Micro 47483-20 SINK DRINKING FOUNTAIN ROOM 3 FIRST DRAW	1.0	1.0	

Technical Supervisor: 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DANIEL WEBSTER ES

Micro Log In **47483**
Total Samples 25
Date Sampled 8/17/97
Date Received 8/18/97
Date Analyzed 8/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **22** Micro 47483-21 **SINK DRINKING FOUNTAIN ROOM 1 FIRST DRAW**	**15.6**	1.0	
Client **23** Micro 47483-22 **SINK DRINKING FOUNTAIN ROOM 2 FIRST DRAW**	**11.5**	1.0	
Client **24** Micro 47483-23 **MULTIPLE DRINKING FOUNTAIN (LHS) EXTERIOR OF ROOM 6 FIRST DRAW**	**4.4**	1.0	
Client **25** Micro 47483-24 **MULTIPLE DRINKING FOUNTAIN (RHS) EXTERIOR OF ROOM 2 FIRST DRAW RESTRICTED SPACE - FILL 1/2" LOW**	**< 1.0**	1.0	
Client **26** Micro 47483-25 **FIELD BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
DANIEL WEBSTER ES

Micro Log In **49276**
Total Samples 25
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **2A** Micro 49276-01 **SINK FAUCET** **LOUNGE ADMN**	**1.9**	1.0	
Client **2B** Micro 49276-02 **SINK FAUCET** **LOUNGE ADMN**	**3.0**	1.0	
Client **2C** Micro 49276-03 **SINK FAUCET** **LOUNGE ADMN** **FIRST DRAW**	**13.7**	1.0	
Client **3A** Micro 49276-04 **SINK FAUCET** **RHS AUD. KITCHEN**	**1.7**	1.0	
Client **3B** Micro 49276-05 **SINK FAUCET** **RHS AUD. KITCHEN**	**2.0**	1.0	

Technical Supervisor: _____ 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
DANIEL WEBSTER ES

Micro Log In **49276**
Total Samples 25
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **3 C** Micro 49276-06 **SINK FAUCET** **RHS AUD. KITCHEN**	**4.8**	1.0	
Client **6 A** Micro 49276-07 **SINK DF** **RM 16**	**6.4**	1.0	
Client **6 B** Micro 49276-08 **SINK DF** **RM 16**	**2.4**	1.0	
Client **6 C** Micro 49276-09 **SINK DF** **RM 16, FIRST DRAW**	**6.8**	1.0	
Client **8 A** Micro 49276-10 **SINK DF** **RM 14**	**4.4**	1.0	

Technical Supervisor: _____ 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
DANIEL WEBSTER ES

Micro Log In **49276**
Total Samples 25
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **8B** Micro 49276-11 **SINK DF RM 14**	**2.7**	1.0	
Client **8C** Micro 49276-12 **SINK DF RM 14, FIRST DRAW**	**16.7**	1.0	
Client **9A** Micro 49276-13 **SINK DF RM 15**	**8.4**	1.0	
Client **9B** Micro 49276-14 **SINK DF RM 15, FIRST DRAW**	**6.6**	1.0	
Client **9C** Micro 49276-15 **SINK DF RM 15, FIRST DRAW**	**33.4**	1.0	

Technical Supervisor: F Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
DANIEL WEBSTER ES

Micro Log In **49276**
Total Samples 25
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **10A** Micro 49276-16 **SINK DF RM 11**	**6.5**	1.0	
Client **10B** Micro 49276-17 **SINK DF RM 11**	**3.0**	1.0	
Client **10C** Micro 49276-18 **SINK DF RM 11, FIRST DRAW**	**11.9**	1.0	
Client **12A** Micro 49276-19 **SINK DF RM 12**	**5.2**	1.0	
Client **12B** Micro 49276-20 **SINK DF RM 12**	**2.5**	1.0	

Technical Supervisor: _____ 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
DANIEL WEBSTER ES

Micro Log In **49276**
Total Samples 25
Date Sampled 10/4/97
Date Received 10/7/97
Date Analyzed 10/7/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **12C** Micro 49276-21 **SINK DF** **RM 12, FIRST DRAW**	**12.1**	1.0	
Client **13A** Micro 49276-22 **SINK DF** **RM 13**	**9.0**	1.0	
Client **13B** Micro 49276-23 **SINK DF** **RM 13**	**7.3**	1.0	
Client **13C** Micro 49276-24 **SINK DF** **RM 13, FIRST DRAW**	**24.6**	1.0	
Client **26A** Micro 49276-25 **FIELD BLANK**	**< 1.0**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/10/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DANIEL WEBSTER ES

Micro Log In **51994**
Total Samples 7
Date Sampled 1/10/98
Date Received 1/12/98
Date Analyzed 1/13/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~A22~~ 22A Micro 51994-01 SINK DRINKING FAUCET ROOM 1	2.7	1.0	
Client ~~B22~~ 22B Micro 51994-02 SINK DRINKING FAUCET ROOM 1	2.0	1.0	
Client ~~C22~~ 22C Micro 51994-03 SINK DRINKING FAUCET ROOM 1	10.1	1.0	
Client ~~A14~~ 14A Micro 51994-04 SINK DRINK FAUCET ROOM 5	2.5	1.0	
Client ~~B14~~ 14B Micro 51994-05 SINK DRINK FAUCET ROOM 5	2.6	1.0	

Technical Supervisor: _____ 1/14/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
DANIEL WEBSTER ES

Micro Log In **51994**
Total Samples 7
Date Sampled 1/10/98
Date Received 1/12/98
Date Analyzed 1/13/98

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client ~~C14~~ 14C Micro 51994-06 SINK DRINK FAUCET ROOM 5	8.7	1.0	
Client ~~A26~~ 26A Micro 51994-07 FIELD BLANK	< 1.0	1.0	

Technical Supervisor: _____ 1/14/98 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Glannini

Client Proj. ID: Weill ES

Lab Proj. ID: 9708B85

Sampled: 08/21/97
Received: 08/22/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B85-01 Sample Desc : **LIQUID,Weil ES-1**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.011**
Lab No: 9708B85-02 Sample Desc : **LIQUID,Weil ES-1 (DUP)**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.011**
Lab No: 9708B85-03 Sample Desc : **LIQUID,Weil ES-2**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-04 Sample Desc : **LIQUID,Weil ES-3**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-05 Sample Desc : **LIQUID,Weil ES-4**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-06 Sample Desc : **LIQUID,Weil ES-5**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-07 Sample Desc : **LIQUID,Weil ES-6**				
Lead	mg/L	08/27/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Weill ES

Lab Proj. ID: 9708B85

Sampled: 08/21/97
Received: 08/22/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B85-08 Sample Desc : **LIQUID,Weil ES-7**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-09 Sample Desc : **LIQUID,Weil ES-8**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-10 Sample Desc : **LIQUID,Weil ES-9**				
Lead	**mg/L**	**08/27/97**	**0.0050**	**0.0053**
Lab No: 9708B85-11 Sample Desc : **LIQUID,Weil ES-10**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-12 Sample Desc : **LIQUID,Weil ES-11**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-13 Sample Desc : **LIQUID,Weil ES-11 (DUP)**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-14 Sample Desc : **LIQUID,Weil ES-12**				
Lead	mg/L	08/27/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Weill ES

Lab Proj. ID: 9708B85

Sampled: 08/21/97
Received: 08/22/97
Analyzed: see below

Reported: 08/29/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708B85-15 Sample Desc : **LIQUID,Weil ES-13**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-16 Sample Desc : **LIQUID,Weil ES-14**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-17 Sample Desc : **LIQUID,Weil ES-15**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-18 Sample Desc : **LIQUID,Weil ES-16**				
Lead	mg/L	08/27/97	0.0050	N.D.
Lab No: 9708B85-19 Sample Desc : **LIQUID,Weil ES-17**				
Lead	**mg/L**	**08/28/97**	**0.0050**	**0.025**
Lab No: 9708B85-20 Sample Desc : **LIQUID,BL (Blank)**				
Lead	mg/L	08/27/97	0.0050	N.D.

97-W 00761 15

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
IDA B. WELLS HS

Micro Log In **47498**
Total Samples 6
Date Sampled 8/18/97
Date Received 8/18/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 1 Micro 47498-01 SINK FAUCET KITCHEN SINK- BASEMENT FIRST DRAW	1.0	1.0	
Client # 2 Micro 47498-02 DRINKING FOUNTAIN CORRIDOR C-91 - BASEMENT FIRST DRAW	3.9	1.0	
Client # 3 Micro 47498-03 DRINKING FOUNTAIN CORRIDOR C-92 - 1ST FLOOR FIRST DRAW	4.4	1.0	
Client # 4 Micro 47498-04 DRINKING FOUNTAIN CORRIDOR C-93 - 2ND FLOOR FIRST DRAW	3.7	1.0	
Client # 5 Micro 47498-05 DRINKING FOUNTAIN OUTSIDE NORTH CORNER FIRST DRAW	4.0	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
IDA B. WELLS HS

Micro Log In **47498**
Total Samples 6
Date Sampled 8/18/97
Date Received 8/18/97
Date Analyzed 8/23/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client # 6 Micro 47498-06 **BLANK**	< 1.0	1.0	

Technical Supervisor: _____ 9/6/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
IDA B. WELLS H.S.

Micro Log In **48825**
Total Samples 9
Date Sampled 9/20/97
Date Received 9/24/97
Date Analyzed 9/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 48825-01 DRINKING FOUNTAIN EAST YARD BASEMENT LEVEL INITIAL SCREENING	5.8	1.0	
Client 2 Micro 48825-02 DRINKING FOUNTAIN BASEMENT LEVEL SOUTH END, CORRIDOR INITIAL SCREENING	5.5	1.0	
Client 3 Micro 48825-03 DRINKING FOUNTAIN BASEMENT LEVEL WEIGHT ROOM INITIAL SCREENING	13.3	1.0	
Client 4 Micro 48825-04 DRINKING FOUNTAIN 1ST FLOOR CORRIDOR, N - END INITIAL SCREENING	9.3	1.0	
Client 5 Micro 48825-05 DRINKING FOUNTAIN 1ST FLOOR CORRIDOR, S - END INITIAL SCREENING	6.7	1.0	

Technical Supervisor: F. Ramezanzadeh 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
IDA B. WELLS H.S.

Micro Log In **48825**
Total Samples 9
Date Sampled 9/20/97
Date Received 9/24/97
Date Analyzed 9/24/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 48825-06 **DRINKING FOUNTAIN** **2ND FLOOR CORRIDOR, S - END** **INITIAL SCREENING**	**7.4**	1.0	
Client 7 Micro 48825-07 **DRINKING FOUNTAIN** **2ND FLOOR R -214, TEACHER LUNCH ROOM** **INITIAL SCREENING**	**10.4**	1.0	
Client 8 Micro 48825-08 **DRINKING FOUNTAIN** **2ND FLOOR CORRIDOR, N - END** **INITIAL SCREENING**	**90.7**	2.9	
Client 9 Micro 48825-09 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WELLS HS

Micro Log In **50617**
Total Samples 6
Date Sampled 11/13/97
Date Received 11/14/97
Date Analyzed 11/14/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **3A** Micro 50617-01 **SINK DRINK FOUNTAIN BASEMENT WEIGHT ROOM BLANK**	**4.5**	1.0	
Client **3B** Micro 50617-02 **SINK DRINK FOUNTAIN BASEMENT WEIGHT ROOM BLANK**	**3.9**	1.0	
Client **3C** Micro 50617-03 **SINK DRINK FOUNTAIN BASEMENT WEIGHT ROOM BLANK**	**5.9**	1.0	
Client **8A** Micro 50617-04 **DRINKING FOUNTAIN 3RD FLOOR NORTH END BLANK**	**2.0**	1.0	
Client **8B** Micro 50617-05 **DRINKING FOUNTAIN 3RD FLOOR NORTH END BLANK**	**2.6**	1.0	

Technical Supervisor: F. Ramezanzadeh 11/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WELLS HS

Micro Log In **50617**
Total Samples 6
Date Sampled 11/13/97
Date Received 11/14/97
Date Analyzed 11/14/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client: **8C** Micro 50617-06 **DRINKING FOUNTAIN 3RD FLOOR NORTH END BLANK**	**3.2**	1.0	

Technical Supervisor: _____ 11/14/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WEST PORTAL ES

Micro Log In **47788**
Total Samples 27
Date Sampled 8/23/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **WEST PORTAL 1** Micro 47788-01 **SINK DRINKING FOUNTAIN ROOM 11 FIRST DRAW**	**2.6**	1.0	
Client **WEST PORTAL 2** Micro 47788-02 **SINK DRINKING FOUNTAIN ROOM 10 FIRST DRAW**	**1.9**	1.0	
Client **WEST PORTAL 3** Micro 47788-03 **SINK DRINKING FOUNTAIN ROOM 12 FIRST DRAW**	**1.0**	1.0	
Client **WEST PORTAL 4** Micro 47788-04 **SINK DRINKING FOUNTAIN ROOM 15 FIRST DRAW**	**< 1.0**	1.0	
Client **WEST PORTAL 5** Micro 47788-05 **WATER FAUCET 190 (HALL) FIRST DRAW**	**2.6**	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WEST PORTAL ES

Micro Log In **47788**
Total Samples 27
Date Sampled 8/23/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **WEST PORTAL 6** Micro 47788-06 **SINK DRINKING FOUNTAIN ROOM 14 FIRST DRAW**	**1.8**	1.0	
Client **WEST PORTAL 7** Micro 47788-07 **SINK DRINKING FOUNTAIN ROOM 17 FIRST DRAW**	**< 1.0**	1.0	
Client **WEST PORTAL 8** Micro 47788-08 **SINK DRINKING FOUNTAIN ROOM 26 FIRST DRAW**	**8.9**	1.0	
Client **WEST PORTAL 9** Micro 47788-09 **SINK DRINKING FOUNTAIN ROOM 24 FIRST DRAW**	**< 1.0**	1.0	
Client **WEST PORTAL 10** Micro 47788-10 **WATER FAUCET 290 (HALL) FIRST DRAW**	**16.6**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WEST PORTAL ES

Micro Log In **47788**
Total Samples 27
Date Sampled 8/23/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **WEST PORTAL 11** Micro 47788-11 **SINK DRINKING FOUNTAIN** **ROOM 22** **FIRST DRAW**	< 1.0	1.0	
Client **WEST PORTAL 12** Micro 47788-12 **SINK FAUCET** **ROOM 19 (CAFE')** **FIRST DRAW**	1.0	1.0	
Client **WEST PORTAL 13** Micro 47788-13 **SINK DRINKING FOUNTAIN** **ROOM 21** **FIRST DRAW**	2.0	1.0	
Client **WEST PORTAL 14** Micro 47788-14 **SINK DRINKING FOUNTAIN** **ROOM 20** **FIRST DRAW**	1.1	1.0	
Client **WEST PORTAL 15** Micro 47788-15 **SINK DRINKING FOUNTAIN** **ROOM 23** **FIRST DRAW**	1.2	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WEST PORTAL ES

Micro Log In **47788**
Total Samples 27
Date Sampled 8/23/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **WEST PORTAL 16** Micro 47788-16 **SINK DRINKING FOUNTAIN ROOM 25 FIRST DRAW**	< 1.0	1.0	
Client **WEST PORTAL 17** Micro 47788-17 **MULTIPLE DRINKING FOUNTAIN EXT. 1 FIRST DRAW**	< 1.0	1.0	
Client **WEST PORTAL 18** Micro 47788-18 **SINK DRINKING FOUNTAIN ROOM 18 FIRST DRAW**	32.1	1.0	
Client **WEST PORTAL 19** Micro 47788-19 **SINK DRINKING FOUNTAIN ROOM 19 FIRST DRAW**	11.5	1.0	
Client **WEST PORTAL 20** Micro 47788-20 **SINK DRINKING FOUNTAIN ROOM 20 FIRST DRAW**	15.9	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WEST PORTAL ES

Micro Log In **47788**
Total Samples 27
Date Sampled 8/23/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **WEST PORTAL 21** Micro 47788-21 **SINK DRINKING FOUNTAIN ROOM 21 FIRST DRAW**	**11.8**	1.0	
Client **WEST PORTAL 22** Micro 47788-22 **SINK FAUCET OFFICE SINK 1 FIRST DRAW**	**11.7**	1.0	
Client **WEST PORTAL 23** Micro 47788-23 **SINK FAUCET OFFICE SINK 2 FIRST DRAW**	**1.1**	1.0	
Client **WEST PORTAL 24** Micro 47788-24 **MULTIPLE DRINKING FOUNTAIN EXT. 3 FIRST DRAW**	**1.4**	1.0	
Client **WEST PORTAL 25** Micro 47788-25 **MULTIPLE DRINKING FOUNTAIN EXT. 2 FIRST DRAW**	**2.8**	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
WEST PORTAL ES

Micro Log In **47788**
Total Samples 27
Date Sampled 8/23/97
Date Received 8/26/97
Date Analyzed 9/1/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **WEST PORTAL 26** Micro 47788-26 **MULTIPLE DRINKING FOUNTAIN EXT. 4 FIRST DRAW**	**32.3**	1.0	
Client **WEST PORTAL 27** Micro 47788-27 **BLANK**	**< 1.0**	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: West Portal ES

Lab Proj. ID: 9710477

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710477-01 Sample Desc : **LIQUID,WP 10-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-02 Sample Desc : **LIQUID,WP 10-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-03 Sample Desc : **LIQUID,WP 10-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-04 Sample Desc : **LIQUID,WP 18-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-05 Sample Desc : **LIQUID,WP 18-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-06 Sample Desc : **LIQUID,WP 18-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-07 Sample Desc : **LIQUID,WP 19-A**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: West Portal ES

Lab Proj. ID: 9710477

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710477-08 Sample Desc : **LIQUID,WP 19-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-09 Sample Desc : **LIQUID,WP 19-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-10 Sample Desc : **LIQUID,WP 19-C (duplicate)**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-11 Sample Desc : **LIQUID,WP 20-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-12 Sample Desc : **LIQUID,WP 20-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-13 Sample Desc : **LIQUID,WP 20-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-14 Sample Desc : **LIQUID,WP 21-A**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: West Portal ES

Lab Proj. ID: 9710477

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710477-15 Sample Desc : **LIQUID,WP 21-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-16 Sample Desc : **LIQUID,WP 21-C**				
Lead	**mg/L**	**10/11/97**	**0.0050**	**0.0051**
Lab No: 9710477-17 Sample Desc : **LIQUID,WP 22-A**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-18 Sample Desc : **LIQUID,WP 22-B**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-19 Sample Desc : **LIQUID,WP 22-C**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-20 Sample Desc : **LIQUID,WP 22-C (duplicate)**				
Lead	mg/L	10/11/97	0.0050	N.D.
Lab No: 9710477-21 Sample Desc : **LIQUID,WP Blank**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: West Portal ES

Lab Proj. ID: 9710477

Sampled: 10/03/97
Received: 10/09/97
Analyzed: see below

Reported: 10/14/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710477-22				
Sample Desc : **LIQUID,WP Blank**				
Lead	mg/L	10/11/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **47729**
Total Samples 23
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 47729-01 SINK DRINKING FOUNTAIN ROOM 104 FIRST DRAW	45.3	1.0	
Client 2 Micro 47729-02 SINK DRINKING FOUNTAIN RM. 103 FIRST DRAW	13.7	1.0	
Client 3 Micro 47729-03 SINK DRINKING FOUNTAIN 102 FIRST DRAW	3.1	1.0	
Client 4 Micro 47729-04 SINK DRINKING FOUNTAIN 101 FIRST DRAW	8.4	1.0	
Client 5 Micro 47729-05 SINK DRINKING FOUNTAIN FACULTY FIRST DRAW	10.2	1.0	

Technical Supervisor: F. Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In 47729
Total Samples 23
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 47729-06 SINK FAUCET NURSES' FIRST DRAW	4.8	1.0	
Client 7 Micro 47729-07 SINK DRINKING FOUNTAIN HALL FIRST DRAW	12.6	1.0	
Client 8 Micro 47729-08 SINK DRINKING FOUNTAIN 202 FIRST DRAW	15.8	1.0	
Client 9 Micro 47729-09 SINK DRINKING FOUNTAIN HALL FIRST DRAW	6.9	1.0	
Client 10 Micro 47729-10 SINK DRINKING FOUNTAIN MULTI - PURPOSE FIRST DRAW	6.8	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In 47729
Total Samples 23
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 47729-11 SINK FAUCET KITCHEN FIRST DRAW	10.3	1.0	
Client 12 Micro 47729-12 SINK DRINKING FOUNTAIN OUTSIDE FIRST DRAW	7.2	1.0	
Client 13 Micro 47729-13 BLANK	< 1.0	1.0	
Client 14 Micro 47729-14 SINK DRINKING FOUNTAIN 201 FIRST DRAW	24.8	1.0	
Client 15 Micro 47729-15 SINK DRINKING FOUNTAIN 210 FIRST DRAW	13.0	1.0	

Technical Supervisor: 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **47729**
Total Samples 23
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 47729-16 SINK DRINKING FOUNTAIN 209 FIRST DRAW	18.5	1.0	
Client 17 Micro 47729-17 SINK DRINKING FOUNTAIN 208 FIRST DRAW	12.3	1.0	
Client 18 Micro 47729-18 SINK DRINKING FOUNTAIN 207 FIRST DRAW	18.7	1.0	
Client 19 Micro 47729-19 SINK DRINKING FOUNTAIN 206 FIRST DRAW	36.7	1.0	
Client 20 Micro 47729-20 SINK DRINKING FOUNTAIN 205 FIRST DRAW	48.5	1.0	

Technical Supervisor: F Ramezanzadeh 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **47729**
Total Samples 23
Date Sampled 8/19/97
Date Received 8/25/97
Date Analyzed 8/25/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 21 Micro 47729-21 SINK DRINKING FOUNTAIN 204 FIRST DRAW	26.9	1.0	
Client 22 Micro 47729-22 SINK DRINKING FOUNTAIN 203 FIRST DRAW	13.2	1.0	
Client 23 Micro 47729-23 SPIKED	47.5	1.0	

Technical Supervisor: _____ 9/7/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **49293**
Total Samples 44
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **8A** Micro 49293-01 **SINK DRINKING FOUNTAIN 202 FIRST DRAW**	**7.2**	1.0	
Client **8B** Micro 49293-02 **SINK DRINKING FOUNTAIN 202 FIRST DRAW**	**3.2**	1.0	
Client **8C** Micro 49293-03 **SINK DRINKING FOUNTAIN 202 FIRST DRAW**	**7.3**	1.0	
Client **BLANK** Micro 49293-04 **BLANK**	**< 1.0**	1.0	
Client **1A** Micro 49293-05 **SINK DRINKING FOUNTAIN 104 FIRST DRAW**	**5.7**	1.0	

Technical Supervisor: 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **49293**
Total Samples 44
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **1B** Micro 49293-06 **SINK DRINKING FOUNTAIN** **104** **FIRST DRAW**	**5.0**	1.0	
Client **1C** Micro 49293-07 **SINK DRINKING FOUNTAIN** **104** **FIRST DRAW**	**15.8**	1.0	
Client **2A** Micro 49293-08 **SINK DRINKING FOUNTAIN** **103** **FIRST DRAW**	**1.3**	1.0	
Client **2B** Micro 49293-09 **SINK DRINKING FOUNTAIN** **103** **FIRST DRAW**	**1.3**	1.0	
Client **2C** Micro 49293-10 **SINK DRINKING FOUNTAIN** **103** **FIRST DRAW**	**4.9**	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **49293**
Total Samples 44
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **7A** Micro 49293-11 **DRINKING FOUNTAIN HALL FIRST DRAW**	**7.6**	1.0	
Client **7B** Micro 49293-12 **DRINKING FOUNTAIN HALL FIRST DRAW**	**3.9**	1.0	
Client **7C** Micro 49293-13 **DRINKING FOUNTAIN HALL FIRST DRAW**	**7.8**	1.0	
Client **14A** Micro 49293-14 **SINK DRINKING FOUNTAIN 201 FIRST DRAW**	**3.8**	1.0	
Client **14B** Micro 49293-15 **SINK DRINKING FOUNTAIN 201 FIRST DRAW**	**3.9**	1.0	

Technical Supervisor: 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **49293**
Total Samples 44
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **14C** Micro 49293-16 **SINK DRINKING FOUNTAIN** 201 **FIRST DRAW**	**10.6**	1.0	
Client **15A** Micro 49293-17 **SINK DRINKING FOUNTAIN** 210 **FIRST DRAW**	**3.7**	1.0	
Client **15B** Micro 49293-18 **SINK DRINKING FOUNTAIN** 210 **FIRST DRAW**	**2.9**	1.0	
Client **15C** Micro 49293-19 **SINK DRINKING FOUNTAIN** 210 **FIRST DRAW**	**5.5**	1.0	
Client **16A** Micro 49293-20 **SINK DRINKING FOUNTAIN** 209 **FIRST DRAW**	**3.8**	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **49293**
Total Samples 44
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **16B** Micro 49293-21 **SINK DRINKING FOUNTAIN 209 FIRST DRAW**	**6.0**	1.0	
Client **16C** Micro 49293-22 **SINK DRINKING FOUNTAIN 209 FIRST DRAW**	**6.4**	1.0	
Client **17A** Micro 49293-23 **SINK DRINKING FOUNTAIN 208 FIRST DRAW**	**3.8**	1.0	
Client **17B** Micro 49293-24 **SINK DRINKING FOUNTAIN 208 FIRST DRAW**	**4.6**	1.0	
Client **17C** Micro 49293-25 **SINK DRINKING FOUNTAIN 208 FIRST DRAW**	**10.1**	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **49293**
Total Samples 44
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **18A** Micro 49293-26 **SINK DRINKING FOUNTAIN** **207** **FIRST DRAW**	**3.3**	1.0	
Client **18B** Micro 49293-27 **SINK DRINKING FOUNTAIN** **207** **FIRST DRAW**	**3.9**	1.0	
Client **18C** Micro 49293-28 **SINK DRINKING FOUNTAIN** **207** **FIRST DRAW**	**12.6**	1.0	
Client **19A** Micro 49293-29 **SINK DRINKING FOUNTAIN** **206** **FIRST DRAW**	**3.5**	1.0	
Client **19B** Micro 49293-30 **SINK DRINKING FOUNTAIN** **206** **FIRST DRAW**	**3.3**	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **49293**
Total Samples 44
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **19C** Micro 49293-31 **SINK DRINKING FOUNTAIN 206 FIRST DRAW**	**17.8**	1.0	
Client **20A** Micro 49293-32 **SINK DRINKING FOUNTAIN 205 FIRST DRAW**	**5.1**	1.0	
Client **20B** Micro 49293-33 **SINK DRINKING FOUNTAIN 205 FIRST DRAW**	**4.3**	1.0	
Client **20C** Micro 49293-34 **SINK DRINKING FOUNTAIN 205 FIRST DRAW**	**17.2**	1.0	
Client **21A** Micro 49293-35 **SINK DRINKING FOUNTAIN 204 FIRST DRAW**	**4.4**	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **49293**
Total Samples 44
Date Sampled 10/5/97
Date Received 10/8/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **21B** Micro 49293-36 **SINK DRINKING FOUNTAIN 204 FIRST DRAW**	3.7	1.0	
Client **21C** Micro 49293-37 **SINK DRINKING FOUNTAIN 204 FIRST DRAW**	11.7	1.0	
Client **22A** Micro 49293-38 **SINK DRINKING FOUNTAIN 203 FIRST DRAW**	3.7	1.0	
Client **22B** Micro 49293-39 **SINK DRINKING FOUNTAIN 203 FIRST DRAW**	3.7	1.0	
Client **22C** Micro 49293-40 **SINK DRINKING FOUNTAIN 203 FIRST DRAW**	5.5	1.0	

Technical Supervisor: F. Ramezanzadeh 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YICK WO ES

Micro Log In **49293**
Total Samples 44
Date Sampled
Date Received 10/13/97
Date Analyzed 10/8/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client **SPIKE** Micro 49293-41	**21.1**	1.0	
Client **SPIKE** Micro 49293-42	**21.0**	1.0	
Client **SPIKE** Micro 49293-43	**21.7**	1.0	
Client **SPIKE** Micro 49293-44	**21.0**	1.0	

Technical Supervisor: _____ 10/13/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Yoey

Lab Proj. ID: 9708D05

Sampled: 08/24/97
Received: 08/25/97
Analyzed: see below

Reported: 08/28/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9708D05-01 Sample Desc : LIQUID,Yoey Blank				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D05-02 Sample Desc : LIQUID,Yoey 1				
Lead	mg/L	08/28/97	0.0050	N.D.
Lab No: 9708D05-03 Sample Desc : LIQUID,Yoey 1 Duplicate				
Lead	mg/L	08/28/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Youth for Service

Lab Proj. ID: 9710G08

Sampled: 10/29/97
Received: 10/29/97
Analyzed: see below

Reported: 11/03/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710G08-01 Sample Desc : **LIQUID,1**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.026**
Lab No: 9710G08-02 Sample Desc : **LIQUID,2**				
Lead	mg/L	10/31/97	0.0050	N.D.
Lab No: 9710G08-03 Sample Desc : **LIQUID,3**				
Lead	mg/L	10/31/97	0.0050	N.D.
Lab No: 9710G08-04 Sample Desc : **LIQUID,4**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.0054**
Lab No: 9710G08-05 Sample Desc : **LIQUID,5**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.0061**
Lab No: 9710G08-06 Sample Desc : **LIQUID,6**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.0075**
Lab No: 9710G08-07 Sample Desc : **LIQUID,7**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.0052**

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Youth for Service

Lab Proj. ID: 9710G08

Sampled: 10/29/97
Received: 10/29/97
Analyzed: see below

Reported: 11/03/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9710G08-08 Sample Desc : **LIQUID,8**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.0060**
Lab No: 9710G08-09 Sample Desc : **LIQUID,9**				
Lead	mg/L	10/31/97	0.0050	N.D.
Lab No: 9710G08-10 Sample Desc : **LIQUID,9-Duplicate**				
Lead	mg/L	10/31/97	0.0050	N.D.
Lab No: 9710G08-11 Sample Desc : **LIQUID,10**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.0077**
Lab No: 9710G08-12 Sample Desc : **LIQUID,11**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.023**
Lab No: 9710G08-13 Sample Desc : **LIQUID,11-Duplicate**				
Lead	**mg/L**	**10/31/97**	**0.0050**	**0.021**
Lab No: 9710G08-14 Sample Desc : **LIQUID,12-Blank**				
Lead	mg/L	10/31/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

Sequoia Analytical

680 Chesapeake Drive, Redwood City, CA 94063, (650) 364-9600, FAX (650) 364-9233
404 N. Wiget Lane, Walnut Creek, CA 94598, (510) 988-9600, FAX (510) 988-9673
819 Striker Avenue, Suite 8, Sacramento, CA 95834, (916) 921-9600, FAX (916) 921-0100

SFUSD
1551 Newcomb Ave., Rm. 103
San Francisco, CA 94124

Attention: Bruce Giannini

Client Proj. ID: Youth for Service

Lab Proj. ID: 9712590

Sampled: 12/10/97
Received: 12/10/97
Analyzed: see below

Reported: 12/17/97

LABORATORY ANALYSIS

Analyte	Units	Date Analyzed	Detection Limit	Sample Results
Lab No: 9712590-01 Sample Desc : **LIQUID,Youth for Service 3-1**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.026**
Lab No: 9712590-02 Sample Desc : **LIQUID,Youth for Service 3-2**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.025**
Lab No: 9712590-03 Sample Desc : **LIQUID,Youth for Service 3-3**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.029**
Lab No: 9712590-04 Sample Desc : **LIQUID,Youth for Service 3-3 dup**				
Lead	**mg/L**	**12/16/97**	**0.0050**	**0.029**
Lab No: 9712590-05 Sample Desc : **LIQUID,Youth for Service Blank**				
Lead	mg/L	12/16/97	0.0050	N.D.

Analytes reported as N.D. were not present above the stated limit of detection.

SEQUOIA ANALYTICAL - ELAP #1210

Sheila Flynn
Project Manager

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YOUTH GUIDANCE CENTER

Micro Log In **50891**
Total Samples 20
Date Sampled 11/22/97
Date Received 11/22/97
Date Analyzed 11/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 1 Micro 50891-01 DRINKING FOUNTAIN KITCHEN AREA - RU - HALL INITIAL	1.6	1.0	
Client 2 Micro 50891-02 SINK FAUCET KITCHEN AREA - RU - HALL INITIAL	< 1.0	1.0	
Client 3 Micro 50891-03 DRINKING FOUNTAIN LOBBY AREA - G2 / COED HALL INITIAL	< 1.0	1.0	
Client 4 Micro 50891-04 DRINKING FOUNTAIN LOBBY AREA G2 / COED HALL INITIAL	< 1.0	1.0	
Client 5 Micro 50891-05 SINK FAUCET KITCHEN AREA - G2 / COED HALL INITIAL	1.8	1.0	

Technical Supervisor: _____ 11/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YOUTH GUIDANCE CENTER

Micro Log In 50891
Total Samples 20
Date Sampled 11/22/97
Date Received 11/22/97
Date Analyzed 11/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 6 Micro 50891-06 DRINKING FOUNTAIN B-1 / G1 - LOBBY AREA INITIAL	< 1.0	1.0	
Client 7 Micro 50891-07 DRINKING FOUNTAIN B-1 / G1 - LOBBY AREA INITIAL	< 1.0	1.0	
Client 8 Micro 50891-08 SINK FAUCET B-1 / G1 KITCHEN AREA INITIAL	1.3	1.0	
Client 9 Micro 50891-09 DRINKING FOUNTAIN B-2 LOBBY AREA INITIAL	2.1	1.0	
Client 10 Micro 50891-10 DRINKING FOUNTAIN B-2 LOBBY AREA INITIAL	< 1.0	1.0	

Technical Supervisor: F. Ramezanzadeh 11/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YOUTH GUIDANCE CENTER

Micro Log In 50891
Total Samples 20
Date Sampled 11/22/97
Date Received 11/22/97
Date Analyzed 11/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 11 Micro 50891-11 SINK FAUCET B-2 KITCHEN INITIAL	2.4	1.0	
Client 12 Micro 50891-12 DRINKING FOUNTAIN B-2 LOBBY AREA INITIAL	1.1	1.0	
Client 13 Micro 50891-13 DRINKING FOUNTAIN B-3 LOBBY AREA INITIAL	< 1.0	1.0	
Client 14 Micro 50891-14 SINK FAUCET B-3 KITCHEN INITIAL	2.0	1.0	
Client 15 Micro 50891-15 DRINKING FOUNTAIN B-4 LOBBY AREA INITIAL	< 1.0	1.0	

Technical Supervisor: F Ramezanzadeh 11/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.

MICRO ANALYTICAL LABORATORIES, INC.

GRAPHITE FURNACE AA - LEAD IN DRINKING WATER - STANDARD METHOD 3113B

1063
SFUSD - Asbestos Control Program
1551 Newcomb Avenue, Rm. 103
San Francisco, CA 94124

PROJECT:
S.F.U.S.D.
YOUTH GUIDANCE CENTER

Micro Log In 50891
Total Samples 20
Date Sampled 11/22/97
Date Received 11/22/97
Date Analyzed 11/22/97

Client Sample ID	Lead Concentration (ppb)	Detection Limit (ppb)	Comments
Client 16 Micro 50891-16 DRINKING FOUNTAIN B-4 LOBBY AREA INITIAL	< 1.0	1.0	
Client 17 Micro 50891-17 SINK FAUCET B-4 KITCHEN INITIAL	1.6	1.0	
Client 18 Micro 50891-18 DRINKING FOUNTAIN B-4 LOBBY AREA INITIAL	1.4	1.0	
Client 19 Micro 50891-19 SINK FAUCET B-5 LOBBY AREA INITIAL	< 1.0	1.0	
Client 20 Micro 50891-20 SINK FAUCET KITCHEN B-5 INITIAL	1.2	1.0	

Technical Supervisor: _____ 11/25/97 Analyst: FR

Farid Ramezanzadeh, M.S.

Micro Analytical Laboratories, Inc. is accredited for lead analysis in drinking water by the California Department of Health Services, Environmental Laboratory Accreditation Program (ELAP), Certificate #1037. Samples are analyzed by Graphite Furnace Atomic Absorption Spectrometry in accordance with Method 3113B (Standard Methods for the Examination of Water and Wastewater, 18th edition, 1992, American Public Health Association, American Water Works Association, Water Pollution Control Federation). This report must not be reproduced except in full, with the approval of Micro Analytical Laboratories, Inc., and pertains only to the samples analyzed. Unit explanation: ppb = parts per billion.